Oscar Smit

From:

Oscar Smit

Sent:

Tuesday, 14 May 2019 3:01 PM

To:

Mark Renalson

Subject:

26 Isis Street, Oamaru - leakage from footpath and carriageway

Hi Mark

I spoke with

of 26 Isis Street on site today.

There is water seeping from the footpath directly outside the steps into his property, and also weeping from the carriageway just below the intersection of Wye Street and Isis Street. He has had a plumber investigate, and that plumber does not believe it is coming from the water supply or sewerage reticulation. I agree with this assessment, and believe it is simply ground water finding the path of least resistance following rain.

There are mudtanks on the intersection of Wye and Isis, which discharge to the SIMTR corridor. thinks the two issues may be related, and I agreed that they may be, or if not directly related then certainly the same sort of phenomenon. As far as I can ascertain they are ground water issues affecting a carriageway and a footpath, and therefore a Roading matter.

Can you please call him to discuss? His number is



Regards

Oscar Smit

Development and Service Delivery Engineer

Email: osmit@waitaki.govt.nz Web: www.waitaki.govt.nz Mobile:+64 21 818 306

Tel: +64 3 433 0300

Waitaki District Council 20 Thames Street Private Bag 50058 Oamaru Waitaki District Otago 9444 New Zealand



The information transmitted, including attachments, is intended only for the person(s) or entity to which it is addressed and may contain confidential and/or privileged material. Any review, retransmission, dissemination or other use of, or taking of any action in reliance upon this information by persons or entities other than the intended recipient is prohibited. If you received this in error please contact the sender and destroy any copies of this information.