

SMS Incident Report

25/10/2019 11:08:27


Summary

CAD Number F2702612 **Status** Closed
Station Newtown Station
Incident Started 03/02/2019 17:32:48 **Incident Ended** 04/02/2019 06:33:22
Incident Type 1101: Structure fire with damage
Common Name WELLINGTON HOSPITAL PSYCHIATRIC UNIT
Address / Mein Street Newtown
Alarm Method 111 Telephone **Alarm Level** 3
PFA Number
Zone 29221105
Map Grid E 1749133 **Map Grid N** 5425301
First Caller **First Caller Contact**
Incident Closed 04/02/2019 07:16:49
Report Completed 8:42, Sat 09 Feb 2019 by [REDACTED]

Responses

Call Sign	Type	Station Alert	Enroute Time	Arrival Time	Departed
NEWT225	HPNP	17:34:37 03 Feb 2019	17:36:19 03 Feb 2019	17:38:50 03 Feb 2019	22:38:46 03 Feb 2019
NEWT221	P1	17:34:38 03 Feb 2019	17:36:29 03 Feb 2019	17:39:12 03 Feb 2019	00:51:46 04 Feb 2019
WELL2118	CUHU	17:34:40 03 Feb 2019	17:36:47 03 Feb 2019	17:41:04 03 Feb 2019	20:56:17 03 Feb 2019
WELL217	PR	17:36:52 03 Feb 2019	17:37:13 03 Feb 2019	17:41:36 03 Feb 2019	19:29:29 03 Feb 2019
KILB241	P1	17:34:43 03 Feb 2019	17:37:29 03 Feb 2019	17:42:29 03 Feb 2019	02:35:30 04 Feb 2019
THOR231	P1	17:52:18 03 Feb 2019	17:53:57 03 Feb 2019	18:00:30 03 Feb 2019	20:34:26 03 Feb 2019
BROO251	P1	17:34:45 03 Feb 2019	17:36:43 03 Feb 2019	18:01:20 03 Feb 2019	06:36:01 04 Feb 2019
WELLINGTN2	OF	17:54:03 03 Feb 2019	17:56:23 03 Feb 2019	18:02:10 03 Feb 2019	19:59:46 03 Feb 2019
THOR235	TL	17:52:18 03 Feb 2019	17:54:14 03 Feb 2019	18:02:17 03 Feb 2019	18:57:09 03 Feb 2019
KARO261	P1	17:54:11 03 Feb 2019	17:56:15 03 Feb 2019	18:04:56 03 Feb 2019	04:40:55 04 Feb 2019
JOHN287	PR	17:54:17 03 Feb 2019	17:58:23 03 Feb 2019	18:08:59 03 Feb 2019	20:58:18 03 Feb 2019

KILB2426	SV	17:52:35 03 Feb 2019	18:06:06 03 Feb 2019	18:11:31 03 Feb 2019	20:44:17 03 Feb 2019
JOHN281	P1	17:58:59 03 Feb 2019	18:04:15 03 Feb 2019	18:14:10 03 Feb 2019	18:59:27 03 Feb 2019
AVAL4115	BA	17:52:20 03 Feb 2019	17:55:19 03 Feb 2019	18:15:12 03 Feb 2019	19:35:17 03 Feb 2019
AVAL414	PM	17:54:09 03 Feb 2019	17:56:27 03 Feb 2019	18:15:42 03 Feb 2019	18:59:58 03 Feb 2019
FIHUTT1	FSO	17:58:37 03 Feb 2019	18:39:48 03 Feb 2019	19:10:57 03 Feb 2019	19:38:32 03 Feb 2019
HUTT407	PR	21:01:03 03 Feb 2019	21:01:17 03 Feb 2019	21:01:18 03 Feb 2019	22:26:10 03 Feb 2019
PORI311	P1	21:02:20 03 Feb 2019	21:02:28 03 Feb 2019	21:02:29 03 Feb 2019	22:05:14 03 Feb 2019
HUTTWA12	OF	17:58:15 03 Feb 2019	18:05:23 03 Feb 2019		18:26:19 03 Feb 2019



Elapsed Times

Call Sign	Start To Alert	Alert To Arrival	Start To Arrival	Start To Departed
NEWT225	00:01:49	00:04:13	00:06:02	05:05:58
NEWT221	00:01:50	00:04:34	00:06:24	07:18:58
WELL2118	00:01:52	00:06:24	00:08:16	03:23:29
WELL217	00:04:04	00:04:44	00:08:48	01:56:41
KILB241	00:01:55	00:07:46	00:09:41	09:02:42
THOR231	00:19:30	00:08:12	00:27:42	03:01:38
BROO251	00:01:57	00:26:35	00:28:32	13:03:13
WELLINGTN2	00:21:15	00:08:07	00:29:22	02:26:58
THOR235	00:19:30	00:09:59	00:29:29	01:24:21
KARO261	00:21:23	00:10:45	00:32:08	11:08:07
JOHN287	00:21:29	00:14:42	00:36:11	03:25:30
KILB2426	00:19:47	00:18:56	00:38:43	03:11:29
JOHN281	00:26:11	00:15:11	00:41:22	01:26:39
AVAL4115	00:19:32	00:22:52	00:42:24	02:02:29
AVAL414	00:21:21	00:21:33	00:42:54	01:27:10
FIHUTT1	00:25:49	01:12:20	01:38:09	02:05:44
HUTT407	03:28:15	00:00:15	03:28:30	04:53:22
PORI311	03:29:32	00:00:09	03:29:41	04:32:26

HUTTWA12	00:25:27		00:53:31
----------	----------	--	----------

Notifications

Date	Time	Party Notified
03 Feb 2019	17:39:44	AREA WGTN/HUTT CONFIRMED FIRE IN HOSPITAL
03 Feb 2019	17:40:03	AMBULANCE VIA INTERCAD
03 Feb 2019	17:42:41	AAM ██████ CALLS IN AS ON CALL AREA WGTN - WILL MONITER RADIO AND RESPOND
03 Feb 2019	17:53:10	AREA WGTN/HUTT 3RD ALARM
03 Feb 2019	17:53:37	WRC Environmental Protection Duty Officer 3RD ALARM
03 Feb 2019	17:54:21	FI WELLINGTON/HUTT DUTY PAGED
03 Feb 2019	17:54:23	AAC ██████ COPYS 3RD ALARM AND IS RESPONDING
03 Feb 2019	17:54:58	RFO WELLINGTON RE 3RD ALARM
03 Feb 2019	17:55:54	WATER ENGINEER WCC
03 Feb 2019	17:55:57	AREA WGTN/HUTT RE WGTN 3 RESPONSE
03 Feb 2019	17:56:47	REGION 3 MGMT RE 3RD ALARM
03 Feb 2019	17:56:51	POLICE VIA INTERCAD
03 Feb 2019	17:57:43	FI ██████ - WILL RESPOND IN HALF HOUR
03 Feb 2019	17:58:29	AAM ██████ CALLS IN WILL RESPOND TO CALL
03 Feb 2019	17:59:06	WREMO LEFT MESSAGE
03 Feb 2019	18:00:06	████████ CALLS IN FOR REGION 3 DETAILS PASSED
03 Feb 2019	18:03:25	WREMO PHONED IN FOR FURTHER INFORMATION = PASSED
03 Feb 2019	18:04:55	AREA WGTN/HUTT RE HUTTWAI2 RESPONSE TO CALL
03 Feb 2019	18:13:16	WCC WATER ENGINEER 2ND CONTACT AS NO REPLY
03 Feb 2019	19:43:18	POR1311 SPOKEN TO VIA PHONE- ADVISED TO RESPOND ROAD SPEED TO WELLINGTON HO
03 Feb 2019	20:06:18	FROM MEIN COMMAND HUTT407 REQUIRED NORMAL TRAFFIC FOR CREW RELIEF
03 Feb 2019	22:16:41	SSO ██████ STATES THAT ALL CREWS NO OF THESE STANDBYS AND COMMS DONT REALL

Message Log

Time	Message
17:34:01	** ELOI search completed at 02/03/19 17:34:01 - 2 results
17:34:02	INC INFO: FIRE ON ROOF
17:34:02	** LOI search completed at 03/02/19 17:34:02
17:34:14	INC INFO: FIRE ON ROOF ABOVE THE DS UNIT
17:34:17	** Recommended unit NEWT225 for requirement AERIAL (>0.8 km) ** Recommended uni
17:34:17	t WELL2118 for requirement COMU (>1.9 km) ** Recommended unit NEWT221 for requi

17:34:17 rement PUMP (>3.5 km)
** Recommended unit KILB241 for requirement PUMP (>2.0 km)

17:34:17)
** Recommended unit BROO251 for requirement PUMP (>1.5 km)

17:34:20 PA Selcal used to Initiate Alerting.(██████)

17:34:21 PA Selcal used to Initiate Alerting.(██████)

17:34:21 PA Selcal used to Initiate Alerting.(██████)

17:34:22 PA Selcal used to Initiate Alerting.(██████)

17:34:22 PA Selcal used to Initiate Alerting.(██████)

17:34:38 ALERTING_COMPLETED

17:34:38 ALERTING_COMPLETED

17:34:40 ALERTING_COMPLETED

17:34:42 CALL FROM THE HOSPITAL

17:34:43 ALERTING_COMPLETED

17:34:45 ALERTING_COMPLETED

17:34:54 Pager turnout error - request Id 0

17:34:54 Pager turnout error - request Id 0

17:34:55 Pager turnout error - request Id 0

17:34:55 Pager turnout error - request Id 0

17:34:55 Pager turnout error - request Id 0

17:35:29 DIDNT KNOW WHAT WAS ON FIRE

17:36:19 KCODE [K1 : PROCEEDING TO INCIDENT]

17:36:19 Unit NEWT225 [K1 : PROCEEDING TO INCIDENT]

17:36:29 KCODE [K1 : PROCEEDING TO INCIDENT]

17:36:29 Unit NEWT221 [K1 : PROCEEDING TO INCIDENT]

17:36:32 KCODE [K1 : PROCEEDING TO INCIDENT]

17:36:32 Unit NEWT225 [K1 : PROCEEDING TO INCIDENT]

17:36:43 KCODE [K1 : PROCEEDING TO INCIDENT]

17:36:43 Unit BROO251 [K1 : PROCEEDING TO INCIDENT]

17:36:47 KCODE [K1 : PROCEEDING TO INCIDENT]

17:36:47 Unit WELL2118 [K1 : PROCEEDING TO INCIDENT]

17:36:48 MSU Selcal used to Initiate Alerting.(██████)

17:36:53 ALERTING_COMPLETED

17:36:59 KCODE [K7 : AT NORMAL STATION]

17:36:59 Unit BROO251 [K7 : AT NORMAL STATION]

17:37:13 KCODE [K1 : PROCEEDING TO INCIDENT]

17:37:13 Unit WELL217 [K1 : PROCEEDING TO INCIDENT]

17:37:29 KCODE [K1 : PROCEEDING TO INCIDENT]

17:37:30 Unit KILB241 [K1 : PROCEEDING TO INCIDENT]

17:37:46 AL: PAGING ACK TIMED OUT FOR STATION: 2924 at 03/02/19 17:37:46

17:38:50 KCODE [K2 : IN ATTENDANCE AT INCIDENT]
17:38:50 Unit NEWT225 [K2 : IN ATTENDANCE AT INCIDENT]
17:38:55 Unit NEWT221 [COMCEN COM : MESSAGE] FIRE ABOVE DS UNIT
17:39:12 KCODE [K88 : PROPERTY SMALL]
17:39:12 Unit NEWT221 [K88 : PROPERTY SMALL]
17:39:57 FIR2AMB - CONFIRMED FIRE ON ROOF OF DS BUILDING/BLOCK
17:40:01 Unit NEWT221 [KP : PRIORITY MESSAGE]
17:40:05 AMBO EVENT 0371-2-2019/02/03-FIR LINKED AT 03/02/2019 17:40:05
17:40:19 INC INFO: FIRE ON ROOF ABOVE THE DS UNIT
17:40:32 KCODE [K88 : PROPERTY SMALL]
17:40:33 Unit NEWT221 [K88 : PROPERTY SMALL]
17:40:55 Unit NEWT221 [KP : PRIORITY MESSAGE] CAN WE GET CITY APPLIANCE TO RESPOND SPRIN
17:40:55 KLER HOUSE AND SET UP THERE (WELL217 COPIED)
17:41:04 KCODE [K2 : IN ATTENDANCE AT INCIDENT]
17:41:04 Unit WELL2118 [K2 : IN ATTENDANCE AT INCIDENT]
17:41:24 FIR2AMB - OUR PROCEDURES ARE TO RESPOND AMBO TO CONFIRMED FIRES IN HOSPITALS
17:41:36 KCODE [K2 : IN ATTENDANCE AT INCIDENT]
17:41:36 Unit WELL217 [K2 : IN ATTENDANCE AT INCIDENT]
17:41:44 KCODE [K2 : IN ATTENDANCE AT INCIDENT]
17:41:45 Unit WELL217 [K2 : IN ATTENDANCE AT INCIDENT]
17:42:29 KCODE [K2 : IN ATTENDANCE AT INCIDENT]
17:42:30 Unit KILB241 [K2 : IN ATTENDANCE AT INCIDENT]
17:42:41 IF UPGRADED
17:48:56 FIR2POL - AT THIS STAGE, MEIN STREET
17:49:10 FIR2AMB AT THIS STAGE MEIN STREET
17:49:17 IGNORE ABOVE FIR2POL
17:51:23 Unit NEWT221 [COMCEN COM : MESSAGE] BE ADVISED RECEIVED 2 FURTHER SPRINKLER ACTI
17:51:23 VATIONS
17:51:41 INC INFO: ROOF ON FIRE DS UNIT TX 3RD ALARM
17:51:45 Unit NEWT221 [SITREP :] TX 3RD ALARM
17:52:08 ** Alarm level updated to 2
17:52:08 ** Recommended unit THOR235 for requirement AERIAL (>3.8 km)
17:52:08 ** Recommended uni
17:52:08 t AVAL4115 for requirement BAT (>18.9 km)
17:52:08 ** Recommended unit KILB2426 for requ
17:52:08 irement SUPPT (>2.0 km)
17:52:08 ** Recommended unit BROO251 for requirement PUMP (>1.5
17:52:08 km)
17:52:08 ** Recommended unit THOR231 for requirement PUMP (>3.9 km)
17:52:13 PA Selcal used to Initiate Alerting. ()

17:52:14 PA Selcal used to Initiate Alerting.(██████)

17:52:14 Pager used to Initiate Alerting.

17:52:14 PA Selcal used to Initiate Alerting.(██████)

17:52:15 PA Selcal used to Initiate Alerting.(██████)

17:52:17 Selcal turnout error

17:52:18 ALERTING_COMPLETED

17:52:18 ALERTING_COMPLETED

17:52:21 ALERTING_COMPLETED

17:52:23 ALERTING_COMPLETED

17:52:24 FIR2AMB THIS HAS BEEN UPGRADED TO A 3RD ALARM STRUCTURE FIRE - IF YOU
COULD RESP

17:52:24 OND PLEASE

17:52:35 ALERTING_COMPLETED

17:52:47 Pager turnout error - request Id 0

17:52:48 Pager turnout error - request Id 0

17:52:48 Pager turnout error - request Id 0

17:53:48 KCODE [K1 : PROCEEDING TO INCIDENT]

17:53:48 Unit BROO251 [K1 : PROCEEDING TO INCIDENT]

17:53:57 KCODE [K1 : PROCEEDING TO INCIDENT]

17:53:57 Unit THOR231 [K1 : PROCEEDING TO INCIDENT]

17:54:01 ** Alarm level updated to 3

17:54:01 ** Recommended unit AVAL414 for requirement AERIAL (>18.9 km)
** Recommended un

17:54:01 Radio used to Initiate Alerting.

17:54:01 it KARO261 for requirement PUMP (>4.1 km)
** Recommended unit JOHN287 for requi

17:54:01 rement PUMP (>10.1 km)

17:54:03 ALERTING_COMPLETED

17:54:04 ALERTING_COMPLETED

17:54:05 PA Selcal used to Initiate Alerting.(██████)

17:54:06 PA Selcal used to Initiate Alerting.(██████)

17:54:06 PA Selcal used to Initiate Alerting.(██████)

17:54:07 Unit NEWT221 [KC : UNIT CALLING]

17:54:09 ALERTING_COMPLETED

17:54:12 ALERTING_COMPLETED

17:54:14 KCODE [K1 : PROCEEDING TO INCIDENT]

17:54:14 Unit THOR235 [K1 : PROCEEDING TO INCIDENT]

17:54:15 Unit NEWT221 [KC : UNIT CALLING]

17:54:17 ALERTING_COMPLETED

17:54:21 KCODE [K1 : PROCEEDING TO INCIDENT]

17:54:21 Unit THOR235 [K1 : PROCEEDING TO INCIDENT]

17:54:37 Pager turnout error - request Id 0

17:55:19 KCODE [K1 : PROCEEDING TO INCIDENT]

17:55:19 Unit AVAL4115 [K1 : PROCEEDING TO INCIDENT]

17:55:22 Unit NEWT221 [KC : UNIT CALLING]

17:55:39 AL: PAGING ACK TIMED OUT FOR STATION: 2924 at 03/02/19 17:55:39

17:56:15 KCODE [K1 : PROCEEDING TO INCIDENT]

17:56:15 Unit KARO261 [K1 : PROCEEDING TO INCIDENT]

17:56:23 KCODE [K1 : PROCEEDING TO INCIDENT]

17:56:23 Unit WELLINGTN2 [K1 : PROCEEDING TO INCIDENT]

17:56:27 KCODE [K1 : PROCEEDING TO INCIDENT]

17:56:27 Unit AVAL414 [K1 : PROCEEDING TO INCIDENT]

17:56:32 FIR2POL - POLICE REQUIRED FOR CONFIRMED FIRE AT THE HOSPITAL. NEED TRAFFIC CONTR

17:56:32 OL

17:56:54 Unit WELL2118 [KC : UNIT CALLING]

17:57:02 Unit NEWT221 [SITREP :] POLICE REQUIRED TO CLOSE OF MEIN ST -- SSO
[REDACTED] -

17:57:02 EAST SIDE ROOF VOID AREA OF 10X10 BURNING CURRENTLY IN OFFENSIVE EXTERNAL AND IN

17:57:02 TERNAL CUT OFF MODE USING LPD WORKING OFF AREIAL APPLIANCE

17:57:19 Unit NEWT221 [SITREP :] SFP - BY APPLIANCES ON MEIN ST

17:57:29 Unit THOR235 [KP : PRIORITY MESSAGE]

17:57:29 AL: PAGING ACK TIMED OUT FOR STATION: 2928 at 03/02/19 17:57:29

17:57:55 Unit THOR235 [KP : PRIORITY MESSAGE] CAN YOU ATTACH BASE PUMP FOR 235

17:58:05 ** Requirement PUMP added for alarm level 3

17:58:12 Radio used to Initiate Alerting.

17:58:15 ALERTING_COMPLETED

17:58:16 Unit WELL2118 [KC : UNIT CALLING]

17:58:18 ** Recommended unit JOHN281 for requirement ADHOC PUMP (>10.0 km)

17:58:23 KCODE [K1 : PROCEEDING TO INCIDENT]

17:58:23 Unit JOHN287 [K1 : PROCEEDING TO INCIDENT]

17:58:35 Radio used to Initiate Alerting.

17:58:37 ALERTING_COMPLETED

17:58:49 INC INFO: ROOF ON FIRE DS UNIT TX 3RD ALARM - BASE PUMP REQUIRED

17:58:57 PA Selcal used to Initiate Alerting. ([REDACTED])

17:58:59 FIR2AMB SFP MEIN STREET BY APPLIANCES

17:59:00 ALERTING_COMPLETED

18:00:01 Unit WELL2118 [K44 : COMMAND OR CONTROL POINT ESTABLISHED - OIC AND LOCATION] M

18:00:01 EIN ST COMMAND SSO [REDACTED] SFO OWEN ST AND MEIN ST

18:00:15 Unit WELL2118 [K45 : COMMAND RESPONSIBILITY CHANGED TO - NAME] SSO
[REDACTED]

18:00:30 kcode [K2 : IN ATTENDANCE AT INCIDENT]
18:00:30 Unit THOR231 [K2 : IN ATTENDANCE AT INCIDENT]
18:01:14 FIR2AMB SFP OWEN/MEIN
18:01:20 kcode [K2 : IN ATTENDANCE AT INCIDENT]
18:01:21 Unit BROO251 [K2 : IN ATTENDANCE AT INCIDENT]
18:02:10 kcode [K2 : IN ATTENDANCE AT INCIDENT]
18:02:10 Unit WELLINGTN2 [K2 : IN ATTENDANCE AT INCIDENT]
18:02:17 COVERING UNIT HUTT407 DISPATCHED TO STATION WELLINGTON CITY AT 03/02/19 18:02:16
18:02:17 kcode [K2 : IN ATTENDANCE AT INCIDENT]
18:02:17 Unit THOR235 [K2 : IN ATTENDANCE AT INCIDENT]
18:02:20 AL: PAGING ACK TIMED OUT FOR STATION: 2928 at 03/02/19 18:02:20
18:03:16 COVERING UNIT TAWA331 DISPATCHED TO STATION JOHNSONVILLE AT 03/02/19 18:03:15 >>
18:04:15 KCODE [K1 : PROCEEDING TO INCIDENT]
18:04:15 Unit JOHN281 [K1 : PROCEEDING TO INCIDENT]
18:04:21 ** Cross Referenced to Event # F2702621 at: 03/02/19 18:04:21
18:04:23 ** Cross Referenced to Event # F2702624 at: 03/02/19 18:04:23
18:04:56 KCODE [K2 : IN ATTENDANCE AT INCIDENT]
18:04:56 Unit KARO261 [K2 : IN ATTENDANCE AT INCIDENT]
18:05:23 KCODE [K1 : PROCEEDING TO INCIDENT]
18:05:23 Unit HUTTWA12 [K1 : PROCEEDING TO INCIDENT]
18:05:45 FIR2POL SAFE FORWARD POINT FOR FIRE IS INTERSECTION OF OWEN AND MEIN ST
18:06:06 KCODE [K1 : PROCEEDING TO INCIDENT]
18:06:06 Unit KILB2426 [K1 : PROCEEDING TO INCIDENT]
18:08:59 KCODE [K2 : IN ATTENDANCE AT INCIDENT]
18:08:59 Unit JOHN287 [K2 : IN ATTENDANCE AT INCIDENT]
18:11:31 KCODE [K2 : IN ATTENDANCE AT INCIDENT]
18:11:31 Unit KILB2426 [K2 : IN ATTENDANCE AT INCIDENT]
18:13:33 Unit WELL2118 [KC : UNIT CALLING]
18:14:10 KCODE [K2 : IN ATTENDANCE AT INCIDENT]
18:14:10 Unit JOHN281 [K2 : IN ATTENDANCE AT INCIDENT]
18:14:38 Unit WELL2118 [SITREP :] K45 AREA MANAGER [REDACTED] ALL 3RD ALARM APPLIANACES
18:14:38 ASTAY IN STAGING AREA DUE TO CONGESTION IN FIRE GROUND
18:15:07 Unit WELL2118 [K45 : COMMAND RESPONSIBILITY CHANGED TO - NAME] [REDACTED]
18:15:12 KCODE [K2 : IN ATTENDANCE AT INCIDENT]
18:15:12 Unit AVAL4115 [K2 : IN ATTENDANCE AT INCIDENT]
18:15:42 KCODE [K2 : IN ATTENDANCE AT INCIDENT]
18:15:42 Unit AVAL414 [K2 : IN ATTENDANCE AT INCIDENT]
18:16:49 Unit KARO261 [KC : UNIT CALLING]

18:17:19 ** Cross Referenced to Event # F2702642 at: 03/02/19 18:17:19

18:18:54 Unit KARO261 [SITREP :] ALL OTHER RESPONDING APPLIANCES COME LEFT INTO OWENS S

18:18:54 T AND PARK BEHIND KARORI 261

18:20:24 Unit WELL2118 [KC : UNIT CALLING]

18:21:01 Alarm Timer Extended: 0

18:21:02 Alarm Timer Extended: 0

18:21:02 Alarm Timer Extended: 0

18:21:03 Alarm Timer Extended: 0

18:21:04 Alarm Timer Extended: 0

18:21:48 Unit THOR235 [SITREP :] AAM [REDACTED] BUILDING OF TWO FLOORS 80X60 FIRE IN ROO

18:21:48 F VOID HAS BEEN CONTAINED USING 1HPD AND 1 LPD AND AREAL APP 4 SECTORS OPRERTAIN

18:21:48 G HOSPITAL MANAGEMENT AND POL ATTENDANCE ALL PERSONS ACCOUNTED FOR OFFENCIVE

18:22:17 Alarm Timer Extended: 0

18:26:19 KCODE [K6 : ON TELEPAGER]

18:26:19 Unit HUTTWA12 [K6 : ON TELEPAGER]

18:29:18 Alarm Timer Extended: 0

18:37:36 KCODE [K22-1 : UNIT AVAILABLE FOR A FURT

18:37:36 Unit THOR235 [K22-1 : UNIT AVAILABLE FOR A FURTHER EVENT]

18:39:48 KCODE [K1 : PROCEEDING TO INCIDENT]

18:39:48 Unit FIHUTT1 [K1 : PROCEEDING TO INCIDENT]

18:42:55 Alarm Timer Extended: 0

18:42:57 Alarm Timer Extended: 0

18:42:57 Alarm Timer Extended: 0

18:42:58 Alarm Timer Extended: 0

18:47:12 Unit WELL2118 [KC : UNIT CALLING]

18:48:37 Unit WELL2118 [SITREP :] FIRE CONTAINED TO ROOF VOID EAT BLOCK AWAITING POWER

18:48:37 TO COMPLETE EXTINGUISHING AND OVERHALL SALAVAGE OPERATIONS IN PROGRESS PATIENTS

18:48:37 BACK IN WESTERN BLOCK

18:57:10 KCODE [K3 : ON RT OUTSIDE NORMAL TURNOUT

18:57:10 Unit THOR235 [K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]

18:58:52 Unit AVAL414 [KC : UNIT CALLING]

18:59:27 KCODE [K3 : ON RT OUTSIDE NORMAL TURNOUT

18:59:27 Unit JOHN281 [K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]

18:59:58 KCODE [K3 : ON RT OUTSIDE NORMAL TURNOUT

18:59:59 Unit AVAL414 [K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]

19:00:52 Unit AVAL414 [COMCEN COM : MESSAGE] PROCEED TO HUTT CITY

19:03:25 COVERING UNIT JOHN281 DISPATCHED TO STATION JOHNSONVILLE AT 03/02/19 19:03:24 >>

19:07:47 Alarm Timer Extended: 0
19:07:47 Alarm Timer Extended: 0
19:07:47 Alarm Timer Extended: 0
19:07:47 Alarm Timer Extended: 0
19:10:57 KCODE [K2 : IN ATTENDANCE AT INCIDENT]
19:10:57 Unit FIHUTT1 [K2 : IN ATTENDANCE AT INCIDENT]
19:15:13 Unit WELL2118 [KC : UNIT CALLING]
19:16:49 Unit KILB241 [KC : UNIT CALLING]
19:16:57 Unit WELL2118 [SITREP :] CURRENTLY LIAING WITH BUILDING MANAGERS IN
REGARDS TO
19:16:57 ISOLATING POWER AND RESETING FIRE SYSTEMS ALSO SARTING TO RELAESE
APPLIANACES F
19:16:57 ROM SCENE
19:17:25 KCODE [K10 : RECOMMISSIONING]
19:17:25 Unit KILB241 [K10 : RECOMMISSIONING]
19:29:07 Unit WELL217 [KC : UNIT CALLING]
19:29:29 KCODE [K10 : RECOMMISSIONING]
19:29:30 Unit WELL217 [K10 : RECOMMISSIONING]
19:30:22 Unit KARO261 [KC : UNIT CALLING]
19:31:12 KCODE [K10 : RECOMMISSIONING]
19:31:12 Unit KARO261 [K10 : RECOMMISSIONING]
19:35:17 KCODE [K4 : ON RT INSIDE NORMAL TURNOUT
19:35:17 Unit AVAL4115 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
19:38:32 kcode [K6 : ON TELEPAGER]
19:38:33 Unit FIHUTT1 [K6 : ON TELEPAGER]
19:41:45 Unit NEWT221 [KC : UNIT CALLING]
19:42:15 Unit WELL2118 [KC : UNIT CALLING]
19:42:43 Unit WELL2118 [COMCEN COM : MESSAGE] (VIA PHONE) CAN PORI311 RESPOND AT
ROAD SPE
19:42:43 ED TO SCENE TO RELIEVE A CREW. THEN ONCE THIS HAS HAPPENED - HUTT407 TO
RESPOND
19:42:43 TO SCENE AT ROAD SPEED TO RELEASE A CREW
19:42:54 Unit WELL2118 [K45 : COMMAND RESPONSIBILITY CHANGED TO - NAME] SSO
[REDACTED]
19:43:18 SPITAL TO RELEASE A CREW
19:59:47 kcode [K6 : ON TELEPAGER]
19:59:47 Unit WELLINGTN2 [K6 : ON TELEPAGER]
20:15:25 Unit BROO251 [KC : UNIT CALLING]
20:15:44 KCODE [K10 : RECOMMISSIONING]
20:15:44 Unit BROO251 [K10 : RECOMMISSIONING]
20:34:11 Unit THOR231 [KC : UNIT CALLING]
20:34:26 KCODE [K10 : RECOMMISSIONING]
20:34:26 Unit THOR231 [K10 : RECOMMISSIONING]

20:44:17 kcode [K4 : ON RT INSIDE NORMAL TURNOUT
20:44:17 Unit KILB2426 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
20:47:06 Unit WELL2118 [KC : UNIT CALLING]
20:48:29 Unit WELL2118 [K45 : COMMAND RESPONSIBILITY CHANGED TO - NAME] SO [REDACTED]
ALL C
20:48:29 OMMS THRU PORI311 WELL2118 CLOSING DOWN
20:56:17 KCODE [K4 : ON RT INSIDE NORMAL TURNOUT
20:56:17 Unit WELL2118 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
20:57:42 Unit NEWT221 [KC : UNIT CALLING]
20:58:18 KCODE [K3 : ON RT OUTSIDE NORMAL TURNOUT
20:58:18 Unit JOHN287 [K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]
21:01:03 Radio used to Initiate Alerting.
21:01:04 ALERTING_COMPLETED
21:01:18 KCODE [K2 : IN ATTENDANCE AT INCIDENT]
21:01:18 Unit HUTT407 [K2 : IN ATTENDANCE AT INCIDENT]
21:02:19 Radio used to Initiate Alerting.
21:02:20 ALERTING_COMPLETED
21:02:29 KCODE [K2 : IN ATTENDANCE AT INCIDENT]
21:02:29 Unit PORI311 [K2 : IN ATTENDANCE AT INCIDENT]
21:05:42 AL: PAGING ACK TIMED OUT FOR STATION: 2931 at 03/02/19 21:05:42
21:09:37 KCODE [K7 : AT NORMAL STATION]
21:09:37 Unit NEWT221 [K7 : AT NORMAL STATION]
21:23:42 KILB241 CALLED REQUESTING STANDBY TIMES ADVISED WE HAVENT BEEN
PROVIDED ANY THEY
21:23:42 WILL CONTACT NEWT221
22:04:49 Unit PORI311 [KC : UNIT CALLING]
22:05:14 KCODE [K3 : ON RT OUTSIDE NORMAL TURNOUT
22:05:14 Unit PORI311 [K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]
22:05:50 NEWT221 ON STANDBY
22:06:15 KCODE [K2 : IN ATTENDANCE AT INCIDENT]
22:06:15 Unit NEWT221 [K2 : IN ATTENDANCE AT INCIDENT]
22:15:28 Unit NEWT221 [SITREP :] FROM SSO [REDACTED] STANDBY TIMES AS FOLLOWS:
NEWT221 NO
22:15:28 W TO 1230- KILB241 1230HRS TO 0230HRS KARO261 0230HRS TO 0430HRS BROO251
0430HRS
22:15:28 TO 0630HRS
22:16:41 Y HAVE TO DO ANYTHING: ADVISED SSO THAT WE WILL WATCH TO ENSURE THAT
THE STANDB
22:16:41 Y CREWS ARE RESPONDED
22:25:10 Unit HUTT407 [KC : UNIT CALLING]
22:26:00 Unit HUTT407 [SITREP :] BOTH CEILING VOIDS EXPOSED CHECKED WITH TIC NO
SIGN OF
22:26:00 HEAT K45 [REDACTED] COMMS THROUGH NEWT221

22:26:10 KCODE [K3 : ON RT OUTSIDE NORMAL TURNOUT
22:26:10 Unit HUTT407 [K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]
22:26:19 Unit HUTT407 [K45 : COMMAND RESPONSIBILITY CHANGED TO - NAME] [REDACTED]
22:38:22 Unit NEWT225 [KC : UNIT CALLING]
22:38:46 KCODE [K10 : RECOMMISSIONING]
22:38:46 Unit NEWT225 [K10 : RECOMMISSIONING]
00:24:30 PA Selcal used to Initiate Alerting. ([REDACTED])
00:24:33 ALERTING_COMPLETED
00:27:54 AL: PAGING ACK TIMED OUT FOR STATION: 2924 at 04/02/19 00:27:54
00:28:43 KCODE [K4 : ON RT INSIDE NORMAL TURNOUT
00:28:43 Unit KILB241 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
00:29:35 KCODE [K1 : PROCEEDING TO INCIDENT]
00:29:35 Unit KILB241 [K1 : PROCEEDING TO INCIDENT]
00:29:44 KCODE [K1 : PROCEEDING TO INCIDENT]
00:29:44 Unit KILB241 [K1 : PROCEEDING TO INCIDENT]
00:34:25 KCODE [K2 : IN ATTENDANCE AT INCIDENT]
00:34:25 Unit KILB241 [K2 : IN ATTENDANCE AT INCIDENT]
00:51:46 KCODE [K7 : AT NORMAL STATION]
00:51:46 Unit NEWT221 [K7 : AT NORMAL STATION]
02:10:39 Unit KARO261 [KC : UNIT CALLING]
02:11:06 KCODE [K1 : PROCEEDING TO INCIDENT]
02:11:06 Unit KARO261 [K1 : PROCEEDING TO INCIDENT]
02:22:51 KCODE [K2 : IN ATTENDANCE AT INCIDENT]
02:22:51 Unit KARO261 [K2 : IN ATTENDANCE AT INCIDENT]
02:35:30 KCODE [K4 : ON RT INSIDE NORMAL TURNOUT
02:35:30 Unit KILB241 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
04:16:08 PA Selcal used to Initiate Alerting. ([REDACTED])
04:16:11 ALERTING_COMPLETED
04:18:18 KCODE [K4 : ON RT INSIDE NORMAL TURNOUT
04:18:18 Unit BROO251 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
04:19:01 KCODE [K1 : PROCEEDING TO INCIDENT]
04:19:01 Unit BROO251 [K1 : PROCEEDING TO INCIDENT]
04:28:26 KCODE [K2 : IN ATTENDANCE AT INCIDENT]
04:28:26 Unit BROO251 [K2 : IN ATTENDANCE AT INCIDENT]
04:40:55 KCODE [K3 : ON RT OUTSIDE NORMAL TURNOUT
04:40:55 Unit KARO261 [K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]
05:29:55 Alarm Timer Extended: 0
06:33:00 Unit BROO251 [KC : UNIT CALLING]
06:33:22 Unit BROO251 [K47 : STOP MESSAGE: MESSAGE UNCHANGED FROM INFORMATIVE]
LEFT IN H

06:33:22	ANDS OF HOSPITAL STAFF
06:36:02	kcode [K3 : ON RT OUTSIDE NORMAL TURNOUT
06:36:02	Unit BROO251 [K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]
07:16:46	UNIT HUTT407 RESPONSE TIME [NULL] ADJUSTED TO 20190203210117ND AT 04/02/2019 07:
07:16:47	UNIT PORI311 RESPONSE TIME [NULL] ADJUSTED TO 20190203210228ND AT 04/02/2019 07:
07:16:49	** Assigned Result Code: STRU, Detailed Event Type: 1100
11:26:20	FIRE INVESTIGATION
11:26:33	** Event F2702612 has been reopened at: 04/02/19 11:26:33
11:26:34	** ELOI search completed at 02/04/19 11:26:34 - 2 results
11:26:34	INC INFO: ROOF ON FIRE
11:26:35	** LOI search completed at 04/02/19 11:26:34
11:27:06	Radio used to Initiate Alerting.
11:27:08	ALERTING_COMPLETED
11:28:07	kcode [K1 : PROCEEDING TO INCIDENT]
11:28:08	Unit FIHUTT1 [K1 : PROCEEDING TO INCIDENT]
14:10:10	KCODE [K2 : IN ATTENDANCE AT INCIDENT]
14:10:10	Unit FIHUTT1 [K2 : IN ATTENDANCE AT INCIDENT]
14:10:16	KCODE [K6 : ON TELEPAGER]
14:10:16	Unit FIHUTT1 [K6 : ON TELEPAGER]
14:14:19	** Assigned Result Code: STRU, Detailed Event Type: 1100

Incident

CAD Number	F2702612
Incident Reporter	██████████
Incident Controller	
Distance Travelled (km)	
Delay In Receiving Call	

Property Details

Occupant	Wellington regional Hospital Ward 27
Building Owner	State owned
General Property Use	Hospital, Hospice, Rest home, Rehab centre
Special Property Use	Psychiatric institution
Purpose Group	

Actions

Persons Reported	
Trapped	

Evacuation Status Evacuation in progress
Action Prior 1
Action Prior 2
Action Taken Extinguishment, salvage and ventilation

Civilians

Civilians Rescued	0
Civilians Extricated	0
Civilians Assisted	0
Civilians Evacuated	40

Origin

Location Ceiling and roof assembly
Level Ground level

Equipment Used

Quantity	Equipment
1	Low pressure delivery
1	Aerial Ladder/Platform

Equipment Involved

Equipment Involved

Year

Make

Model

Fire

Arrival Condition Large fire
Heat Source Unable to classify
Termination Stage
First Object Ignited
First Object Material
Second Object Ignited
Second Object Material
Indicated Cause Unable to classify
Certainty of Cause Low
Age of Person Unknown
Ethnicity Unknown
Gender ██████

FAIP Service Offered Unknown

Alarms

Type of Alarm	Smoke Detector System (Monitored)
Initiating Call	
Performance of System	Alerted occupants - detector in room of origin
Failure/Ineffectiveness of system	
Number of sprinkler heads operated	0

Comments

2/9/2019 8:42:22 AM **Reporter Comments**

Cause undetermined. Awaiting Fire Investigators assessment

[REDACTED]

3/29/2019 12:56:31 PM **Reporter Comments**

FSO Requested at incident F2702612 on 03 Feb 2019 17:32

[REDACTED]

Released under the Official Information Act