

# SMS Incident Report

29/04/2021 09:28:50


## Summary

**CAD Number** F3211897 **Status** Closed  
**Station** Woolston Station  
**Incident Started** 30/03/2021 01:13:04 **Incident Ended**  
**Incident Type** 1101: Structure fire with damage  
**Common Name** ROMANOS FOODS  
**Address** 3 Foundry Drive Hillsborough  
**Alarm Method** Manual PFA Call **Alarm Level** 4  
**PFA Number** 514101  
**Zone** 342408  
**Map Grid E** 1574112 **Map Grid N** 5176864  
**First Caller** **First Caller Contact**  
**Incident Closed**  
**Report Completed** 14:6, Tue 27 Apr 2021 by [REDACTED]

## Responses

Call Sign	Type	Station Alert	Enroute Time	Arrival Time	Departed
WOOL241	P1	01:13:19 30 Mar 2021	01:15:26 30 Mar 2021	01:18:36 30 Mar 2021	15:57:52 01 Apr 2021
SPRE221	P1	01:13:22 30 Mar 2021	01:16:11 30 Mar 2021	01:24:14 30 Mar 2021	18:09:26 30 Mar 2021
CHRI214	PM	01:17:42 30 Mar 2021	01:19:46 30 Mar 2021	01:26:40 30 Mar 2021	23:05:04 30 Mar 2021
CHRI217	PR	01:17:41 30 Mar 2021	01:18:55 30 Mar 2021	01:42:23 30 Mar 2021	20:02:07 30 Mar 2021
ANZA271	P1	01:44:57 30 Mar 2021	01:47:49 30 Mar 2021	01:57:14 30 Mar 2021	13:20:29 30 Mar 2021
LYTT292	P2	01:44:54 30 Mar 2021	01:51:07 30 Mar 2021	01:57:31 30 Mar 2021	04:54:59 30 Mar 2021
ANZA272	P2	01:44:57 30 Mar 2021	01:50:50 30 Mar 2021	02:00:31 30 Mar 2021	04:53:10 30 Mar 2021
CHRI216	TL	01:42:51 30 Mar 2021	01:44:39 30 Mar 2021	02:01:40 30 Mar 2021	08:55:18 30 Mar 2021
CHRI2518	CUHU	01:45:00 30 Mar 2021	01:49:09 30 Mar 2021	02:01:45 30 Mar 2021	15:39:27 30 Mar 2021
CHRISTCH1	OF		01:52:13 30 Mar 2021	02:08:43 30 Mar 2021	05:31:00 30 Mar 2021
HARE261	P1	02:20:50 30 Mar 2021	02:22:43 30 Mar 2021	02:28:29 30 Mar 2021	05:58:59 30 Mar 2021

REDW231	P1	02:20:53 30 Mar 2021	02:22:14 30 Mar 2021	02:41:17 30 Mar 2021	16:30:22 30 Mar 2021
CHRISTCH2	OF		03:45:46 30 Mar 2021	03:56:25 30 Mar 2021	09:07:39 30 Mar 2021
FICHRI1	FSO		03:39:53 30 Mar 2021	03:58:53 30 Mar 2021	14:51:13 01 Apr 2021
ANZA2726	SV	04:02:12 30 Mar 2021	04:14:25 30 Mar 2021	04:30:18 30 Mar 2021	05:52:55 30 Mar 2021
CHRI212	P2		04:27:22 30 Mar 2021	04:37:11 30 Mar 2021	08:44:24 30 Mar 2021
GOVE3326	SV		05:05:55 30 Mar 2021	05:24:33 30 Mar 2021	07:09:44 30 Mar 2021
FICHRI3	FSO		11:17:42 30 Mar 2021	11:33:41 30 Mar 2021	11:29:27 31 Mar 2021
EVENTSCC2	OT				15:58:00 01 Apr 2021



### Elapsed Times

Call Sign	Start To Alert	Alert To Arrival	Start To Arrival	Start To Departed
WOOL241	00:00:15	00:05:17	00:05:32	62:44:48
SPRE221	00:00:18	00:10:52	00:11:10	16:56:22
CHRI214	00:04:38	00:08:58	00:13:36	21:52:00
CHRI217	00:04:37	00:24:42	00:29:19	18:49:03
ANZA271	00:31:53	00:12:17	00:44:10	12:07:25
LYTT292	00:31:50	00:12:37	00:44:27	03:41:55
ANZA272	00:31:53	00:15:34	00:47:27	03:40:06
CHRI216	00:29:47	00:18:49	00:48:36	07:42:14
CHRI2518	00:31:56	00:16:45	00:48:41	14:26:23
CHRISTCH1			00:55:39	04:17:56
HARE261	01:07:46	00:07:39	01:15:25	04:45:55
REDW231	01:07:49	00:20:24	01:28:13	15:17:18
CHRISTCH2			02:43:21	07:54:35
FICHRI1			02:45:49	61:38:09
ANZA2726	02:49:08	00:28:06	03:17:14	04:39:51
CHRI212			03:24:07	07:31:20
GOVE3326			04:11:29	05:56:40
FICHRI3			10:20:37	34:16:23

EVENTSCC2			62:44:56
-----------	--	--	----------

## Notifications

Date	Time	Party Notified
30 Mar 2021	01:18:03	POLICE VIA INTERCAD
30 Mar 2021	01:18:03	AMBULANCE VIA INTERCAD
30 Mar 2021	01:18:32	ORION
30 Mar 2021	01:20:02	AREA CHCH PAGED RE 2ND ALARM
30 Mar 2021	01:23:27	AREA CHCH ( ) ACK PAGE
30 Mar 2021	01:44:55	AREA CHCH PAGED RE 3RD ALARM
30 Mar 2021	01:45:33	FI CHCH PAGED
30 Mar 2021	01:46:16	REGION 4 REC ( ) PAGED RE 3RD ALARM
30 Mar 2021	01:47:46	AREA CHCH ACKD PAGE IS RESPONDING
30 Mar 2021	01:47:52	CANTERBURY CITY DEFENCE DUTY OFFICER RE 3RD ALARM
30 Mar 2021	01:49:46	FI CHRISTCHURCH FICHR1 ACK PAGE
30 Mar 2021	01:50:01	REGION 4 DUTY PAGED RE 3RD ALARM
30 Mar 2021	01:53:24	REGION 4 DUTY ACKD PAGE
30 Mar 2021	01:54:01	REGION 4 ( ) ACK PAGE
30 Mar 2021	01:54:01	REGION 4 REC ACK PAGE RE 3RD ALARM
30 Mar 2021	01:57:48	DUTY HPO CHRISTCHURCH
30 Mar 2021	02:05:21	CHRISTCHURCH CITY COUNCIL PUMPING STATION
30 Mar 2021	02:13:26	KIWIRAIL
30 Mar 2021	02:21:08	REGION 4 DUTY PAGED RE 4TH ALARM
30 Mar 2021	02:23:31	REGION 4 ACK PAGE RE 4TH ALARM
30 Mar 2021	02:23:53	REGION 4 ACKD PAGE
30 Mar 2021	02:23:57	NATIONAL COMMANDERS GROUP RE 4TH ALARM
30 Mar 2021	02:24:32	CANTERBURY CIVIL DEFENCE DUTY OFFICER UPDATED RE 4TH ALARM
30 Mar 2021	02:25:25	NATIONAL MEDIA SUPPORT PAGED
30 Mar 2021	02:27:16	NATIONAL COMCEN MANAGER DUTY ( ) PAGED RE 4TH ALARM
30 Mar 2021	02:30:15	NATIONAL COMCEN MANAGER ( ) ACK
30 Mar 2021	02:33:53	NATIONAL MEDIA ACK PAGE ( )
30 Mar 2021	02:48:44	NATIONAL MEDIA -
30 Mar 2021	02:50:11	CCC WATER - HAVE BOOSTED WATER - FIRE CAN ALSO GET WATER FROM PORT HILLS RD
30 Mar 2021	03:21:09	SSO RE AVAILABILITY
30 Mar 2021	03:27:00	FI CHCH PAGED TO RESPOND
30 Mar 2021	03:55:21	RAPID RELIEF TEAM (RRT)
30 Mar 2021	04:02:24	FROM SSO AT CITY STATION COULD WE RESPOND ANZAC VAN WITH DRIVER TO CI

30 Mar 2021	04:44:11	WIGRAM STATION - LINCOLN HAPPY TO STAY ON FOR A COUPLE OF HOURS
30 Mar 2021	04:45:31	████████ FROM CHCH CITY COUNCIL WATER SUPPLY PHONED TO ENQUIRE WHETHER THERE WAS
30 Mar 2021	05:07:09	NIWA - 12 HOUR WEATHER FORECAST LOOKING AT WIND AND RAIN
30 Mar 2021	05:10:14	HPO UPDATED
30 Mar 2021	05:18:54	RUNG WIGRAM STATION TO STAND DOWN LINCOLN AS SPREYDON IS BACK AT THEIR STATION
30 Mar 2021	05:25:04	ECAN RE WATER RUNOFF
30 Mar 2021	05:34:32	NIWA WEATHER REPORT EMAILED THROUGH CHR12518
30 Mar 2021	07:09:58	CONTACTED SOUTHERN DEMO ..... GAVE ██████████ PHONE NUMBER
30 Mar 2021	07:24:08	HPO ON CALL CHCH - ORGANISING NOW, BACK TO US WITH 10 MINS WITH ETA
30 Mar 2021	07:43:08	CCC
30 Mar 2021	08:49:51	HPO ETA FOR ██████████ - SHOULD BE ON SITE BY 0900HRS
30 Mar 2021	18:55:32	CCC

### Message Log

Time	Message
01:13:04	AL: 514101 01:13:04 INITIAL - ALARM
01:13:04	PANEL: CAFETERIA
01:13:05	** LOI search completed at 30/03/21 01:13:04
01:13:13	** Recommended unit WOOL241 for requirement PUMP (>1.5 km)
01:13:13	** Recommended unit SPRE221 for requirement PUMP (>4.9 km)
01:13:16	PA Selcal used to Initiate Alerting. (WOOL241 at 3424 WOOLSTON 193241)
01:13:16	PA Selcal used to Initiate Alerting. (SPRE221 at 3422 SPREYDON 192221)
01:13:19	ALERTING COMPLETED WOOL241
01:13:22	ALERTING COMPLETED SPRE221
01:13:48	INC INFO: FIRE IN FACTORY
01:15:26	Unit WOOL241 [ K1 : PROCEEDING TO INCIDENT]
01:15:35	INC INFO: FACTORY FIRE - RAMANO FOOD FACTORY
01:15:47	** Event Location changed from "3 FOUNDRY DR,HILLSBOROUGH,CHRISTCHURCH CITY: @RO
01:15:47	MANOS FOODS: : @ROMANOS FOODS #5" to "3 FOUNDRY DR,HILLSBOROUGH,CHRISTCHURCH CIT
01:15:47	Y: @ROMANOS FOODS" at: 30/03/21 01:15:47
01:16:11	Unit SPRE221 [ K1 : PROCEEDING TO INCIDENT]
01:16:18	CALLER STATED MACHINE ON FIRE INSIDE FACTORY
01:16:20	Unit WOOL241 [COMCEN COM : MESSAGE] 111 CALL FROM STAFF ON SITE REPORTS CONFIRME
01:16:20	D FIRE INSIDE FACTORY

01:17:02 Unit WOOL241 [ KC : UNIT CALLING]  
01:17:20 Unit WOOL241 [ SITREP : ] SMOKE SHOWING, MAKE SECOND ALARM  
01:17:36 \*\* Alarm level updated to 2  
01:17:36 \*\* Recommended unit CHRI217 for requirement PUMP (>3.8 km)  
01:17:36 \*\* Recommended unit  
01:17:36 CHRI214 for requirement PUMP (>3.8 km)  
01:17:38 PA Selcal used to Initiate Alerting. (CHRI217 at 3421 CHRISTCHURCH 193211)  
01:17:38 PA Selcal used to Initiate Alerting. (CHRI214 at 3421 CHRISTCHURCH 193211)  
01:17:39 FIR2POL  
01:17:41 ALERTING\_COMPLETED CHRI217  
01:17:42 FIR2AMB  
01:17:42 ALERTING\_COMPLETED CHRI214  
01:17:45 FYI  
01:17:53 2ND ALARM BUILDING FIRE  
01:18:02 AMBO EVENT 0015-3-2021/03/30-FIR LINKED AT 30/03/2021 01:18:02  
01:18:34 .  
01:18:36 Unit WOOL241 [ K88 : PROPERTY FIRE APPARENTLY SMALL]  
01:18:55 Unit CHRI217 [ K1 : PROCEEDING TO INCIDENT]  
01:19:39 .  
01:19:46 Unit CHRI214 [ K1 : PROCEEDING TO INCIDENT]  
01:22:29 Unit WOOL241 [ SITREP : ] TO SPREYDON: WE ARE RIGHT AROUND THE BACK, CAN YOU RUN  
01:22:29 A FEEDER IN  
01:22:43 Unit CHRI214 [COMCEN.COM : MESSAGE] MAP SHOWS A HYDRANT RIGHT AT THE ENTRANCE  
01:23:01 CORRECTION, ABOVE MESSAGE WAS TO SPRE221 TO CHRI214  
01:23:05 .  
01:24:14 Unit SPRE221 [ K2 : IN ATTENDANCE AT INCIDENT]  
01:26:40 Unit CHRI214 [ K2 : IN ATTENDANCE AT INCIDENT]  
01:42:14 Unit SPRE221 [ KP : PRIORITY MESSAGE]  
01:42:23 Unit CHRI217 [ K2 : IN ATTENDANCE AT INCIDENT]  
01:42:37 Unit SPRE221 [ SITREP : ] MAKE AERIALS ONE  
01:42:42 \*\* Requirement AERIAL added for alarm level 2  
01:42:44 \*\* Recommended unit CHRI216 for requirement AERIAL (>4.9 km)  
01:42:48 PA Selcal used to Initiate Alerting. (CHRI216 at 3422 SPREYDON 192221)  
01:42:52 ALERTING\_COMPLETED CHRI216  
01:43:37 Unit SPRE221 [ KP : PRIORITY MESSAGE]  
01:43:53 Unit SPRE221 [ SITREP : ] MAKE THIRD ALARM  
01:44:01 \*\* Requirement AERIAL removed for alarm level 2  
01:44:11 \*\* Alarm level updated to 3

01:44:11 \*\* Recommended unit ANZA271 for requirement PUMP (>6.6 km)  
\*\* Recommended unit

01:44:11 ANZA272 for requirement PUMP (>6.6 km)  
\*\* Recommended unit CHRI2518 for require

01:44:11 ment COMU (>12.0 km)

01:44:17 FIR2POL

01:44:19 FIR2AMB

01:44:21 INC INFO: BUILDING FIRE - TX 3RD ALARM

01:44:27 FIRE IS NOW AT 3RD ALARM

01:44:37 YOUR RESPONSE IS REQUIRED

01:44:39 Unit CHRI216 [ K1 : PROCEEDING TO INCIDENT]

01:44:41 \*\* Requirement PUMP added for alarm level 3

01:44:44 \*\* Recommended unit LYTT292 for requirement PUMP (>5.6 km)

01:44:50 PA Selcal used to Initiate Alerting. (ANZA271 at 3427 ANZAC 193271)

01:44:51 PA Selcal used to Initiate Alerting. (ANZA272 at 3427 ANZAC 193271)

01:44:51 PA Selcal used to Initiate Alerting. (CHRI2518 at 3425 WIGRAM 193251)

01:44:52 Station Selcal used to Initiate Alerting. (LYTT292 at 3429 LYTTELTON 193291)

01:44:54 ALERTING\_COMPLETED LYTT292

01:44:57 ALERTING\_COMPLETED ANZA271

01:44:57 ALERTING\_COMPLETED ANZA272

01:45:00 ALERTING\_COMPLETED CHRI2518

01:45:58 AL: PAGING ACK RECEIVED FROM STATION 3429 at 03-30-21 01:45:58

01:46:28 Unit CHRI217 [ K2 : IN ATTENDANCE AT INCIDENT]

01:46:32 ANZA272 BACKED UP WITH NEXT PUMP ON BEATLIST - LYTT292

01:46:35 .

01:47:49 Unit ANZA271 [ K1 : PROCEEDING TO INCIDENT]

01:48:04 Unit CHRI217 [ KC : UNIT CALLING]

01:48:10 COVERING UNIT HARE261 DISPATCHED TO STATION CHRISTCHURCH AT 30/03/21  
01:48:09 >>

01:48:14 AL: 514101 01:48:14 UPDATE - ALARM

01:49:01 Unit CHRI217 [ SITREP : ] SFP CNR OF CURRIES AND FOUNDARY DR

01:49:09 Unit CHRI2518 [ K1 : PROCEEDING TO INCIDENT]

01:49:32 Unit CHRI217 [ KC : UNIT CALLING]

01:49:41 Unit CHRI217 [ SITREP : ] CHRI216 TO ENTER FROM PORT HILLS ROAD

01:49:51 Unit CHRI216 [ SITREP : ] COPY

01:50:09 Unit CHRI217 [ SITREP : ] LOCATION OF CHRI216?

01:50:19 Unit CHRI216 [ SITREP : ] BROUGHAM/WALTHAM

01:50:50 Unit ANZA272 [ K1 : PROCEEDING TO INCIDENT]

01:51:00 Unit ANZA271 [COMCEN COM : MESSAGE] SFP FOUNDARY/CURRIES

01:51:01 Unit CHRI2518 [COMCEN COM : MESSAGE] SFP FOUNDARY/CURRIES

01:51:07 Unit LYTT292 [ K1 : PROCEEDING TO INCIDENT]

01:51:25 Unit ANZA272 [COMCEN COM : MESSAGE] SFP FOUNDARY/CURRIES

01:51:43 Unit ANZA272 [ SITREP : ] SFF AND FIVE

01:51:52 Unit LYTT292 [COMCEN COM : MESSAGE] SFP FOUNDARY/CURRIES

01:52:13 Unit CHRISTCH1 [ K1 : PROCEEDING TO INCIDENT]

01:52:45 Unit CHRISTCH1 [COMCEN COM : MESSAGE] SFP FOUNDARY/CURRIES

01:56:03 FIR2POL - NOTHING SUSPICIOUS AT THIS STAGE. REQUEST POLICE RESPONSE FOR TRAFFIC

01:56:03 MANAGEMENT AND INTER AGENCY LIAISON FOR SCALE OF EVENT.

01:56:28 .

01:56:35 Unit CHRI217 [ KC : UNIT CALLING]

01:57:14 Unit ANZA271 [ K2 : IN ATTENDANCE AT INCIDENT]

01:57:31 Unit LYTT292 [ K2 : IN ATTENDANCE AT INCIDENT]

01:58:44 Unit CHRI217 [ SITREP : ] SSO [REDACTED] 1 COMMERCIAL STRUCTURE APPROX 800 BY 400,

01:58:44 LARGE FIRE DEVELOPING WITHIN, MADE OF PANELING, GTWW TYPE 5 AERIAL, ALL CREWS W

01:58:44 ITHDRAWN FIREFIGHTING DUE TO SAFETY, AWAITING FURTHER RESOURCES

01:59:08 Alarm Timer Extended: 0

01:59:39 Unit CHRISTCH1 [COMCEN COM : MESSAGE] CONFIRM YOU COPIED SITREP (AFFIRM)

02:00:31 Unit ANZA272 [ K2 : IN ATTENDANCE AT INCIDENT]

02:01:04 INC INFO: LARGE FIRE SEEN

02:01:40 Unit CHRI216 [ K2 : IN ATTENDANCE AT INCIDENT]

02:01:45 Unit CHRI2518 [ K2 : IN ATTENDANCE AT INCIDENT]

02:03:34 Unit CHRI2518 [ K2 : IN ATTENDANCE AT INCIDENT]

02:03:42 INC INFO: LARGE FIRE SEEN

02:05:07 Alarm Timer Extended: 0

02:06:03 CCC PUMPING STATION WILL DO THEIR BEST TO MAINTAIN HIGH PRESSURE IN THE AREA. SH

02:06:03 OULDN'T HAVE ANY ISSUES WITH SUPPLYING LARGE AMOUNTS OF WATER FOR A LONG DURATION

02:06:03

02:08:18 Alarm Timer Extended: 0

02:08:43 Unit CHRISTCH1 [ K2 : IN ATTENDANCE AT INCIDENT]

02:09:33 INC INFO: LARGE FIRE SEEN

02:09:50

02:19:16 Unit CHRI2518 [ KP : PRIORITY MESSAGE]

02:19:48 Unit CHRI2518 [ K45 : COMMAND RESPONSIBILITY CHANGED TO (STATE NAME)]  
[REDACTED]

02:19:58 Unit CHRI2518 [ SITREP : ] TX 4TH ALARM

02:20:04 INC INFO: BUILDING FIRE - TX 4TH ALARM

02:20:20 \*\* Requirement PUMP removed for alarm level 3

02:20:27 \*\* Requirement PUMP added for alarm level 3

02:20:32 \*\* Requirement PUMP added for alarm level 3

02:20:41 \*\* Recommended unit HARE261 for requirement PUMP (>3.9 km)

02:20:47 PA Selcal used to Initiate Alerting. (HARE261 at 3421 CHRISTCHURCH 193211)

02:20:47 PA Selcal used to Initiate Alerting. (REDW231 at 3423 REDWOOD 193231)

02:20:50 ALERTING\_COMPLETED HARE261

02:20:53 ALERTING\_COMPLETED REDW231

02:20:58 ..

02:22:08 COVERING UNIT WIGR257 DISPATCHED TO STATION CHRISTCHURCH AT 30/03/21  
02:22:08 >>

02:22:14 Unit REDW231 [ K1 : PROCEEDING TO INCIDENT]

02:22:21 ..

02:22:43 Unit HARE261 [ K1 : PROCEEDING TO INCIDENT]

02:23:44 ..

02:25:22 \*\* Alarm level updated to 4

02:26:40 Unit HARE261 [COMCEN COM : MESSAGE] SFP FOUNDARY/CURRIES

02:26:41 Unit REDW231 [COMCEN COM : MESSAGE] SFP FOUNDARY/CURRIES

02:26:45 Alarm Timer Extended: 0

02:28:29 Unit HARE261 [ K2 : IN ATTENDANCE AT INCIDENT]

02:36:14 Unit CHRI2518 [ KC : UNIT CALLING]

02:37:06 Unit CHRI2518 [ K44 : COMMAND OR CONTROL POINT ESTABLISHED (STATE OIC AND  
LOCATI  
ON)] FONDARY COMMAND, CORNER OF FOUNDARY AND CURRIES

02:37:06 INC INFO:

02:37:38 Unit CHRI2518 [ K45 : COMMAND RESPONSIBILITY CHANGED TO (STATE NAME)] AC  
██████████

02:37:38 ██████████

02:37:52 Unit CHRI2518 [ SITREP : ] ALL FURTHER RESPONDING CREWS TO REPORT TO  
COMMAND UNI  
T ON ARRIVAL

02:37:52 T ON ARRIVAL

02:38:03 Unit REDW231 [ SITREP : ] COPY

02:38:08 Alarm Timer Extended: 0

02:38:10 Alarm Timer Extended: 0

02:41:17 Unit REDW231 [ K2 : IN ATTENDANCE AT INCIDENT]

02:41:18 Alarm Timer Extended: 0

02:42:46 Alarm Timer Extended: 0

02:43:47 Alarm Timer Extended: 0

02:45:05 ..

02:45:10 Unit CHRI2518 [ KC : UNIT CALLING]

02:45:33 Unit CHRI2518 [ SITREP : ] STAND BY

02:45:38 Unit CHRI2518 [ KC : UNIT CALLING]

02:48:12 ...

02:48:46 ..



02:48:58 Unit CHRI2518 [ SITREP : ] AC [REDACTED] 1 LARGE FACTORY FULLY INVOLVED, HAZARD

02:48:58 S ARE NITROUS GAS SANDWICH PANELS, WE ARE USING AERIALS, MULTIPLE LPDS AND GROUND

02:48:58 D BASED MONITORS, REQUIREMENTS: IS IT POSSIBLE TO BOOST THE MAINS PRESSURE IN THE

02:48:58 E AREA, TACTICAL MODE DEFENSIVE AND HAZARD PROTECTION, STRUCTURE: OIC AC [REDACTED]

02:48:58 [REDACTED] OPERATIONS SSO [REDACTED] SAFETY OFFICER SO [REDACTED]

02:49:51 Unit CHRI2518 [COMCEN COM : MESSAGE] WE HAVE ALREADY CONTACTED CITY COUNCIL WATER

02:49:51 SERVICES WHO WERE MONITORING THE DRAW ON THE HYDRANTS AND WERE ATTEMPTING TO MAINTAIN

02:49:51 HIGH PRESSURE, WERE NOT ANTICIPATING ANY ISSUES, WE WILL GET BACK IN TOUCH WITH THEM

02:49:51 .

02:50:11 [REDACTED] OR FROM [REDACTED] - BUT SHOULD BE RIGHT FOR NOW

02:54:37 Unit CHRI2518 [COMCEN COM : MESSAGE] CITY COUNCIL WATER SERVICES ADVISE HYDRANT

02:54:37 PRESSURE ALREADY BOOSTED AND SHOULD HOLD FOR THE TIME BEING, IF REQUIRED THEY HAVE

02:54:37 SUGGESTED SEPARATE MAIN ON PORT HILLS ROAD OR CHAPMANS ROAD

02:54:41 Alarm Timer Extended: 0

02:55:30 Unit CHRI2518 [ KC : UNIT CALLING]

02:56:49 Unit CHRI2518 [ SITREP : ] CAN WE PLEASE NOTIFY THE DHB ABOUT SMOKE DRIFT IN THE

02:56:49 AREA (CDHB HPO HAS ALREADY BEEN NOTIFIED)

03:06:21 Unit CHRI2518 [ KC : UNIT CALLING]

03:06:48 Unit CHRI2518 [ SITREP : ] MAKE AVAILABILITY

03:08:53 CALLED WIGR257 SSO [REDACTED] - WILL ORGANISE AVAILABILITY

03:08:55 .

03:08:58 Alarm Timer Extended: 0

03:12:10 Unit CHRI2518 [ KC : UNIT CALLING]

03:13:18 Unit CHRI2518 [ SITREP : ] CAN YOU CONFIRM WHAT PARTS WE HAVE IN THE CITY (WIGRAM

03:13:18 AT CITY AND LINCOLN AT WIGRAM)

03:18:28 Unit CHRI2518 [ KC : UNIT CALLING]

03:20:14 Unit CHRI2518 [ SITREP : ] LIASE SSO [REDACTED] RE AVAILABILITY AND WHERE THE AVAILABILITY TRUCK IS AS CITY & SSO [REDACTED] ACTS AS SSO CITY WHILE THIS JOB IS ON

03:25:58 Unit CHRI2518 [ KC : UNIT CALLING]

03:26:25 Unit CHRI2518 [ SITREP : ] ONCALL FI ATTEND THIS CALL

03:28:09 Alarm Timer Extended: 0

03:29:15 Unit FICHR1 [ SITREP : ] WILL BE K1 SHORTLY

03:35:59 Unit CHRI2518 [ KC : UNIT CALLING]

03:39:53 Unit FICHR1 [ K1 : PROCEEDING TO INCIDENT]

03:40:07 Unit CHR12518 [ SITREP : ] AC [REDACTED] 1 FULLY INVOLVED FOOD PROCESSING FACTORY, HAZARDS ARE NITROUS GAS SANDWICH PANEL AND BUILDING COLLAPSE, WE ARE CURRENTLY USING MULTIPLE LPDS AND GROUND BASED MONITORS, REQUIREMENTS ARE NIL, TACTICAL MODE IS DEFENSIVE WITH HAZARD PROTECTION, STRUCTURE IS OIC [REDACTED] OPERATION

03:40:07 S [REDACTED] SECTOR 2 [REDACTED] SECTOR 3 [REDACTED] SECTOR 4 [REDACTED] LOGISTICS [REDACTED], SAFETY OFFICER [REDACTED] COMMAND OFFICER [REDACTED] WE ARE CURRENTLY MAKING ONE FIRE APPLIANCE AVAILABLE IF REQUIRED, CAN WE ALSO ATTACH AAC [REDACTED] TO THIS JOB FOR LOGISTICAL REASONS

03:45:47 Unit CHRISTCH2 [ K1 : PROCEEDING TO INCIDENT]

03:48:06 Unit CHR12518 [ KC : UNIT CALLING]

03:48:19 Unit CHRISTCH2 [COMCEN COM : MESSAGE] COMMAND POINT IS AT THE CORNER OF FOUNDRY AND CURRIES

03:48:19 Unit FICHR1 [COMCEN COM : MESSAGE] COMMAND POINT IS AT THE CORNER OF FOUNDRY AND CURRIES

03:48:20 Unit CHR12518 [ SITREP : ] BUILDING SIZE IS APPROX 2000SQM AND SINGLE STOREY

03:51:30 Unit CHRISTCH2 [ SITREP : ] VIA PH - RESPOND RAPID RELIEF TEAM FOR HOT DRINKS AND FOOD

03:51:36 ..

03:56:26 Unit CHRISTCH2 [ K2 : IN ATTENDANCE AT INCIDENT]

03:57:59 RRT IS GOING TO CALL BACK SHORTLY WITH CONFIRMATION THAT THEY CAN PROVIDE FOOD AND DRINKS FOR THOSE ON SCENE

03:58:53 Unit FICHR1 [ K2 : IN ATTENDANCE AT INCIDENT]

04:01:38 INC INFO: BUILDING FIRE - TX 4TH ALARM - ANZAC VAN REQUIRED FOR LOGISTICS

04:02:11 Phone used to Initiate Alerting.

04:02:12 ALERTING\_COMPLETED ANZA2726

04:02:22 INC INFO: BUILDING FIRE - TX 4TH ALARM CITY STATION SO WE CAN MOVE SOME PEOPLE AROUND

04:02:24

04:14:25 Unit ANZA2726 [ K1 : PROCEEDING TO INCIDENT]

04:15:23 Unit ANZA2726 [COMCEN COM : MESSAGE] RESPOND TO CITY STATION, LIAISE WITH SSO [REDACTED]

04:15:23 [REDACTED]

04:26:11 \*\*\*

04:27:22 Unit CHR1212 [ K1 : PROCEEDING TO INCIDENT]

04:27:25 RRT IS HAVING TROUBLE GETTING HOLD OF THEIR CHCH REP AND ARE STILL LOOKING TO LO

04:27:25 CATE THEIR FOOD TRAILER TO MAKE SURE THEY CAN DO FOOD FOR CREWS ON  
SCENE. AT THI

04:27:25 S STAGE THEY CAN LIKELY DO FOOD BETWEEN 0600 AND 0700HRS

04:27:29 \*\*\*

04:29:49 Unit CHRI2518 [COMCEN COM : MESSAGE] (VIA PHONE) RRT IS HAVING TROUBLE  
FINDING T

04:29:49 HEIR FOOD TRAILER. AT THIS STAGE THEY ARE POSSIBLY LOOKING AT GETTING TO  
SCENE A

04:29:49 ROUND 0600-0700HRS. DO YOU REQUIRE FOOD BEFORE THEN? (WILL LIASIE WITH  
YOU SHORT

04:29:49 LY RE FOOD)

04:30:18 Unit ANZA2726 [ K2 : IN ATTENDANCE AT INCIDENT]

04:34:38 ..

04:37:11 Unit CHRI212 [ K2 : IN ATTENDANCE AT INCIDENT]

04:37:19 Unit CHRI2518 [ KC : UNIT CALLING]

04:38:07 Unit SPRE221 [ KC : UNIT CALLING]

04:38:10 Unit CHRI2518 [ SITREP : ] AC [REDACTED] WE ARE BEGINNING TO SCALE DOWN  
THIS IN

04:38:10 CIDENT AND ORGANISING A RELIEF PLAN

04:38:29 Unit SPRE221 [ SITREP : ] WE WILL BE RETURNING TO SPREYDON STATION

04:38:36 Unit SPRE221 [ K10 : RE-COMMISSIONING APPLIANCE]

04:38:42 Alarm Timer Extended: 0

04:38:58 Alarm Timer Extended: 0

04:40:38 \*\*\*\*\*

04:41:10 INC INFO:

04:42:05 CFO [REDACTED] OF GOVERNORS BAY IS GOING TO RING ROUND FOR A CREW TO  
SUPPLY TEA AND

04:42:05 COFFEE. WILL ALSO TAKE THE FUEL TRAILER TO ASSIST

04:42:07 \*\*\*\*\*

04:42:27 Unit CHRI2518 [ SITREP : ] VIA PH - GOVES BAY TO RESPOND AND [REDACTED] WILL  
ARRANGE

04:42:27 FOOD, 10-20 STAFF, TRUCKS WILL START TO BE RELEASED

04:45:31 ENOUGH WATER SUPPLY FOR THIS EVENT: WAS ADVISED THAT AT 0438HRS THE  
LATEST SITR

04:45:31 EP WAS THAT THE EVENT WAS BEING SCALED DOWN. ENTERED BY SM  
CENTRALCOMMS

04:51:19 .

04:53:11 Unit ANZA272 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]

04:53:43 [REDACTED] IS RESPONDING TO FIRE GROUND TO ARRANGE FOOD, AFTER  
SPEAKING WITH

04:53:43 [REDACTED] THE 24HR BAKERY ON FERRY RD HAS BEEN RUNG TO CHECK ON  
AVAILBLITY OF FOO

04:53:43 D, THEY HAVE PLENTY AND ARE PACKING IT UP FOR 20 STAFF NOW READY FOR  
COLLECTION

04:53:45 .

04:55:00 Unit LYTT292 [ K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]

04:55:08 KIWIRAIL ABOUT TO TRAVEL THROUGH WITH A TRAIN. THEY WILL GO SLOWLY PAST THE SCEN

04:55:08 E AND HAVE BEEN ADVISED OF SMOKE HAZARD AND HEAT FROM THE FIRE

04:56:56 Unit CHRI2518 [ SITREP : ] VIA PH - WE ARE RELEASING APPLIANCES NOW AND CHRI214

04:56:56 GOING BACK TO RELEASE WIGR257 ONCE RECOM, WHO WILL RETURN TO THEIR STN AND CAN R

04:56:56 ELEASE LINCOLN VOLLIES

04:59:32 RRT STOOD DOWN

05:03:15 Unit CHRI2518 [ KC : UNIT CALLING]

05:03:50 Unit CHRI2518 [ SITREP : ] CAN YOU PLEASE EMAIL THE COMMAND UNIT A WEATHER FOREC

05:03:50 AST

05:05:55 Unit GOVE3326 [ K1 : PROCEEDING TO INCIDENT]

05:06:10 Unit GOVE3326 [ KC : UNIT CALLING]

05:07:15 Unit GOVE3326 [ SITREP : ] WE ARE K1, CONFIRM WHERE WE ARE TO RESPOND TO (COMMAN

05:07:15 D UNIT IS SET UP AT THE CORNER OF CURRIES AND FOUNDARY) ETA 20 MINUTES

05:13:21 HPO PUT THROUGH TO NATIONAL MEDIA REP TO DISCUSS MEDIA BROADCAST RE THE SMOKE DR

05:13:21 IFT

05:13:48 Alarm Timer Extended: 0

05:15:15 \*\* Cross Referenced to Event # F3211927 at: 30/03/21 05:15:15

05:15:18 \*\* Cross Referenced to Event # F3211926 at: 30/03/21 05:15:18

05:18:54 ON

05:22:14 Unit CHRI212 [ KC : UNIT CALLING]

05:22:32 Alarm Timer Extended: 0

05:22:42 Unit CHRI212 [ K10 : RE-COMMISSIONING APPLIANCE]

05:23:48 Unit CHRI2518 [COMCEN COM : MESSAGE] [VIA PHONE] IS THERE ANY ISSUE RE WATER RUN

05:23:48 OFF GOING INTO DRAINS?

05:24:23 Unit CHRI2518 [ SITREP : ] NOTIFY COUNCIL/ECAN TO SEE IF THEY CAN GET A REP HERE

05:24:23 TO CHECK THE WATER RUN OFF. JUST AS A PRECAUTION

05:24:33 Unit GOVE3326 [ K2 : IN ATTENDANCE AT INCIDENT]

05:26:05 Unit CHRI2518 [ KC : UNIT CALLING]

05:26:27 Unit CHRI2518 [ K45 : COMMAND RESPONSIBILITY CHANGED TO (STATE NAME)] AAC [REDACTED]

05:31:00 Unit CHRISTCH1 [ K6 : ON PAGER (STATE LOCATION)]

05:52:56 Unit ANZA2726 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]

05:58:35 Unit HARE261 [ KC : UNIT CALLING]

05:59:00 Unit HARE261 [ K10 : RE-COMMISSIONING APPLIANCE]

05:59:12 HARE261 K10 ONE HOUR

06:27:34 Unit CHRI216 [ K2 : IN ATTENDANCE AT INCIDENT]

06:28:46 Unit REDW231 [ K2 : IN ATTENDANCE AT INCIDENT]

06:28:51 Unit REDW231 [ K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]

06:30:19 Alarm Timer Extended: 0

06:42:23 Unit CHRI2518 [ KC : UNIT CALLING]

06:44:49 Unit CHRI2518 [ KC : UNIT CALLING]

06:45:27 Unit CHRI2518 [ KC : UNIT CALLING]

06:48:48 Unit CHRI2518 [ SITREP : ] FM COMMAND POINT OFFICER █████ CONTINUING TO SCALE DOW

06:48:48 N MONITOR AND SUPPRESS WHILE AWAITING FOR DAYLIGHT HOURS ALSO HAVE BUILDING OWNE

06:48:48 RS AND INSURANCE AGENTS ON SITE

06:49:27 FM AMEND COMMAND POINT OFFICER TO █████

06:57:09 Unit CHRI2518 [ KC : UNIT CALLING]

06:58:33 \*\* Cross Referenced to Event # F3211949 at: 30/03/21 06:58:33

06:59:55 Unit CHRISTCH2 [ SITREP : ] REQUIRE A DIGGER ON SITE WITH A LONG REACH ARM TO PU

06:59:55 LL IT APART

07:09:44 Unit GOVE3326 [ K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]

07:09:51 Alarm Timer Extended: 0

07:20:28 ECAN CALLED IN - UNABLE TO CONTACT ON CALL NIGHT REP SO DAY SHIFT JUST PICKED TH

07:20:28 IS UP -WILL TRY AND GET SOMEONE CLOSE TO RESPOND - OTHERWISE IT WILL BE █████ FRO

07:20:28 M RANGIORA, ETA APPROX 0800 HRS

07:20:34 .

07:20:55 CMD UNIT NOTIFIED - REQUESTS TO STILL GET ECAN ON SITE AND ALSO HEALTH REP TO MO

07:20:55 NITOR SMOKE POLLUTION

07:20:56 .

07:21:38 Unit CHRI2518 [COMCEN COM : MESSAGE] ECAN WILL TRY AND GET SOMEONE CLOSE TO RESP

07:21:38 OND - OTHERWISE IT WILL BE █████ FROM RANGIORA, ETA APPROX 0800 HRS (ACK)

07:22:46 Unit CHRI217 [ KC : UNIT CALLING]

07:23:08 Unit CHRI217 [ K10 : RE-COMMISSIONING APPLIANCE]

07:23:50 .

07:24:11

07:24:30 Unit CHRI2518 [COMCEN COM : MESSAGE] NOT HPO ON CALL CHCH - ORGANISING NOW, BACK

07:24:30 TO US IN 10 MINS WITH ETA

07:27:53 Unit CHRI214 [ K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]

07:42:41 Unit CHRI2518 [ SITREP : ] (VIA PHONE) COUNCIL/WATER REQUIRED, HYDRANT IN THE DR

07:42:41 IVEWAY, ISN" T WORKING AT ALL - AND WE NEED IT OPERATING, LOOKS LIKE A NEW HYDRAN

07:42:41 T AS IT LOOKS LIKE IT" S BEEN REPAIRED

07:45:08 Unit CHRI2518 [ SITREP : ] FM AAM █████ CURRENTLY WORKING WITH CREW CHANGEOVER

07:45:08 CHRI214 ANZA271 AND WOOL241 GREEN WATCH WILL BE RETURNING TO SITE CURRENTLY WORK

07:45:08 ING WITH SOUTHERN DEMOLITION

07:58:02 INC INFO: SMOKE IN AREA

08:05:37 Unit CHRI214 [ K1 : PROCEEDING TO INCIDENT]

08:05:51 FROM CHRI214 ATTACH OURSELVES AND CHRI212 TO THE FOUNDARY DRIVE INCIDENT

08:12:05 Unit CHRI212 [ K1 : PROCEEDING TO INCIDENT]

08:12:06 Unit CHRI212 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]

08:12:26 Unit CHRI212 [ K1 : PROCEEDING TO INCIDENT]

08:12:38 Unit CHRI212 [ K1 : PROCEEDING TO INCIDENT]

08:14:37 Unit CHRI214 [ K2 : IN ATTENDANCE AT INCIDENT]

08:15:20 Unit CHRI212 [ K2 : IN ATTENDANCE AT INCIDENT]

08:44:24 Unit CHRI212 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]

08:54:15 Unit CHRI2518 [ KC : UNIT CALLING]

08:54:48 INC INFO: SMOKE IN AREA

08:55:18 Unit CHRI216 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]

08:55:21 Unit CHRI2518 [ SITREP : ] ROAD CONES WITH HIGGINS ON OPAWA ROAD CAN WE GET THEM

08:55:21 REMOVED

08:57:08 Alarm Timer Extended: 0

09:07:39 Unit CHRISTCH2 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]

10:02:27 Unit CHRI2518 [ KC : UNIT CALLING]

10:07:29 Unit CHRI2518 [ K45 : COMMAND RESPONSIBILITY CHANGED TO (STATE NAME)] CHRISTCHUR

10:07:29 CH4 [REDACTED] MULTIPLE SECTORS IN USE SALVAGE AND OVERHAUL UNDER WAY MINOR FIRE FIGHTI

10:07:29 NG IN ONE SECTOR INTERIOR AND EXTERIOR ONGOING MULTIPLE EXTERNAL AUTHORITIES ON

10:07:29 SITE

10:23:44 Unit CHRI2518 [ KC : UNIT CALLING]

10:24:57 Unit CHRI2518 [ SITREP : ] SSO [REDACTED] VSO TO GET BOXES OF WATER AND BRING TO TH

10:24:57 E FIRE GROUND

10:26:27 FROM VSO CHCH2 [REDACTED] HEARD THE MSG ON THE RADIO NEAR CITY STATION [REDACTED] WILL SORT IT O

10:26:27 UT

10:27:15 TO VSO CHCH2 DO YOU WANT TO BE ATTACHED TO THE INCIDENT OR STAY K4

10:27:34 FM VSO CHCH2 WILL STAY AS I AM

10:46:25 INC INFO: SMOKE IN AREA OF HILLS

11:17:42 Unit FICHRI3 [ K1 : PROCEEDING TO INCIDENT]

11:19:28 Unit CHRI2518 [ KC : UNIT CALLING]

11:23:11 Unit CHRI2518 [ SITREP : ] FM AAC [REDACTED] MULTIPLE SECTORS IN USE SALVAGE AND OVERH

11:23:11 AUL OPERATIONS UNDER WAY MINOR FIRE FIGHTING STILL CURRENTLY IN SECTORS ONE AND

11:23:11 TWO INTERNAL AND EXTERNAL OPERATIONS ONGOING MULTIPLE EXTERNAL AUTHORITIES ON SI

11:23:11 TE MULTIPLE EXCAVATORS NOW ON SITE

11:25:55 FIRECOM RANG BOTH SPEYDON AND REDWOOD RE RELIEF CREW ARRIVAL AT 1300

11:26:59 \*

11:33:41 Unit FICHRI3 [ K2 : IN ATTENDANCE AT INCIDENT]

12:17:38 Alarm Timer Extended: 0

12:55:42 Unit REDW231 [ K1 : PROCEEDING TO INCIDENT]

13:00:10 Unit SPRE221 [ K1 : PROCEEDING TO INCIDENT]

13:00:25 Unit SPRE221 [ K2 : IN ATTENDANCE AT INCIDENT]

13:09:24 Unit FICHRI1 [ K6 : ON PAGER (STATE LOCATION)]

13:20:12 Unit ANZA271 [ KC : UNIT CALLING]

13:20:30 Unit ANZA271 [ K10 : RE-COMMISSIONING APPLIANCE]

13:20:37 Unit REDW231 [ K2 : IN ATTENDANCE AT INCIDENT]

13:46:11 Alarm Timer Extended: 0

13:46:47 Unit WOOL241 [ KC : UNIT CALLING]

14:04:20 Alarm Timer Extended: 0

14:29:09 Unit CHRI2518 [ KC : UNIT CALLING]

14:31:21 Unit CHRI2518 [ SITREP : ] FM AAC [REDACTED] MULTIPLE SECTORS IN USE SALVAGE AND OVERH

14:31:21 ALUL MINOR FIRE FIGHTING ONE SECTOR INTERIOR AND EXTERIOR OPERATIONS ONGOING MUL

14:31:21 TIPLE EXTERNAL SERVICES ON SITE MULTIPLE EXCAVATORS ON SITE APPLIANCE CHANGES FO

14:31:21 R THE AFTERNOON COMPLETE

14:52:05 Unit WOOL241 [ KC : UNIT CALLING]

14:52:22 Unit WOOL241 [ K7 : AT NORMAL STATION]

15:10:48 Unit FICHRI3 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]

15:27:07 Unit CHRI2518 [ KC : UNIT CALLING]

15:29:16 Unit CHRI2518 [ SITREP : ] FOUNDRY COMMAND SHUTTING DOWN ALL FURTHER MSGS THRU

15:29:16 CHRI214

15:39:27 Unit CHRI2518 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]

16:30:04 Unit REDW231 [ KC : UNIT CALLING]

16:30:22 Unit REDW231 [ K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]

16:46:07 Unit CHRI214 [ K45 : COMMAND RESPONSIBILITY CHANGED TO (STATE NAME)] SSO [REDACTED]

16:46:07 [REDACTED]

17:17:45 Unit CHRI214 [ KC : UNIT CALLING]

17:18:40 Unit CHRI214 [ SITREP : ] FM SSO [REDACTED] BRIGADE STILL DAMPENING DOWN HOT SPOTS

17:19:04 Unit CHR1214 [ K45 : COMMAND RESPONSIBILITY CHANGED TO (STATE NAME)] SO  
██████████ SP

17:19:04 RE221

17:19:12 Unit CHR1214 [ K10 : RE-COMMISSIONING APPLIANCE]

17:37:47 MSU Selcal used to Initiate Alerting. (CHR1217 D9FDE2)

17:37:50 ALERTING\_COMPLETED CHR1217

17:38:12 Unit CHR1217 [ K2 : IN ATTENDANCE AT INCIDENT]

17:58:51 Unit SPRE221 [ KC : UNIT CALLING]

17:59:20 Unit SPRE221 [ K45 : COMMAND RESPONSIBILITY CHANGED TO (STATE NAME)] SO  
██████████

17:59:20 ON CHR1217

18:09:27 Unit SPRE221 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]

18:48:34 Alarm Timer Extended: 0

18:55:20 Unit CHR1217 [ SITREP : ] RE-RESPOND CITY CARE PITS ARE FILLING UP AGAIN

19:12:09 CHCH CITY COUNCIL ORGANISING, ALSO LIAISING WITH ECAN RE THE DRAINAGE PITS

19:30:09 .

19:32:29 ██████████ AT CITY CARE ██████████ CAN BE CONTACTED DIRECTLY IF ANY MORE RESOURCES

19:32:29 REQUIRED OVERNIGHT. SUCKER TRUCKS ON THE WAY BACK IN.

19:32:32 .

19:41:54 Unit WOOL241 [ K1 : PROCEEDING TO INCIDENT]

19:42:02 Unit WOOL241 [ K2 : IN ATTENDANCE AT INCIDENT]

19:58:48 Unit CHR1217 [ K22-1 : APPLIANCE AVAILABLE FOR A FURTHER INCIDENT]

20:02:07 Unit CHR1217 [ K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]

20:22:28 Unit CHR1214 [ K38 : ASSOCIATE THIS APPLIANCE TO EVENT (STATE EVENT ADDRESS)]

20:22:35 Unit CHR1214 [ K39-1 : TRANSMIT K1]

20:22:44 Unit CHR1214 [ K1 : PROCEEDING TO INCIDENT]

20:23:04 Unit CHR1214 [ K2 : IN ATTENDANCE AT INCIDENT]

20:41:09 Alarm Timer Extended: 0

21:04:21 Unit CHR1214 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]

21:26:00 Unit WOOL241 [ SITREP : ] CEASING OPS FOR REST OF NIGHT, WILL HEAD BACK IN MORN

21:26:00 NG. IF ANYMORE CALLS TONIGHT RESPOND WOOL241 AND CHR1214

21:27:10 Unit WOOL241 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]

21:50:32 INC INFO: FLAMES SEEN IN MIDDLE OF BUILDING

21:50:39 INC INFO: BUILDING FIRE - FLAMES SEEN IN CENTRE OF BUILDING

21:50:50 PA Selcal used to Initiate Alerting. (WOOL241 at 3424 WOOLSTON 193241)

21:50:51 PA Selcal used to Initiate Alerting. (CHR1214 at 3421 CHRISTCHURCH 193211)

21:50:56 ALERTING\_COMPLETED WOOL241

21:51:00 ALERTING\_COMPLETED CHR1214

21:51:18 WORKER FOR CITY CARE WAS OINSTRUCTED BY DEPARTING CREWS TO PHONE 111 IF THEY SAW



21:51:18 ANY FLAMES AT THE SITE - FLAMES SEEN IN THE MIDDLE OF THE BUILDING

21:51:44 Unit WOOL241 [ K1 : PROCEEDING TO INCIDENT]

21:52:27 Unit CHRI214 [ K1 : PROCEEDING TO INCIDENT]

21:53:14 Unit WOOL241 [COMCEN COM : MESSAGE] CALLS COME VIA CITY CARE WORKER ON SCENE

21:57:10 Unit WOOL241 [ K77 : NOTHING SHOWING]

21:59:12 Unit CHRI214 [ K2 : IN ATTENDANCE AT INCIDENT]

22:02:02 Unit WOOL241 [ KC : UNIT CALLING]

22:02:41 Unit WOOL241 [ SITREP : ] SSO [REDACTED] - SMALL FLARE UP IN CENTRE OF BUILDING - G

22:02:41 TWW AERIAL

22:40:26 Alarm Timer Extended: 0

22:40:26 Alarm Timer Extended: 0

22:50:18 Unit WOOL241 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]

22:50:49 Unit CHRI214 [ SITREP : ] SMALL FLARE UP - HAVE GIVEN IT A GOOD GO WITH THE AERI

22:50:49 AL . WILL CEASE OPERATIONS OVERNIGHT - JUST CHRI214 AD WOOL241 IF ANY OTHER VISI

22:50:49 BLE FLAMES CALLED IN UNTIL THE MORNING

23:05:04 Unit CHRI214 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]

07:57:28 Unit FICHRI1 [ K1 : PROCEEDING TO INCIDENT]

08:06:58 Unit WOOL241 [ K1 : PROCEEDING TO INCIDENT]

08:11:51 Unit WOOL241 [ K2 : IN ATTENDANCE AT INCIDENT]

08:52:09 Unit FICHRI1 [ K2 : IN ATTENDANCE AT INCIDENT]

08:56:57 Alarm Timer Extended: 0

09:33:43 Alarm Timer Extended: 0

09:56:41 Unit FICHRI3 [ K1 : PROCEEDING TO INCIDENT]

10:11:09 Unit FICHRI3 [ K2 : IN ATTENDANCE AT INCIDENT]

10:55:32 Alarm Timer Extended: 0

11:29:27 Unit FICHRI3 [ K6 : ON PAGER (STATE LOCATION)]

11:33:54 Unit WOOL241 [ KC : UNIT CALLING]

11:34:37 Unit WOOL241 [ SITREP : ] JUST LEAVING THE ROMANOS INCIDENT - LEAVE THE JOB OPEN

11:34:37 BECAUSE WE"LL BE RETURNING AS NEEDED

11:34:45 Unit WOOL241 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]

12:16:16 .

12:17:08 Unit FICHRI1 [ SITREP : ] SPEAKING WITH SOUTHERN DEMOLITION - CAN YOU CONTACT [REDACTED]

12:17:08 [REDACTED] AND HAVE THEM COME BACK AROUND 4/4:30

12:18:43 .

12:19:00 SSO [REDACTED] UPDATED - [REDACTED] WILL CONTACT AAC [REDACTED] AND FI [REDACTED]

12:19:02 .

14:51:55 Unit WOOL241 [ K1 : PROCEEDING TO INCIDENT]

14:55:42	Unit WOOL241 [ K2 : IN ATTENDANCE AT INCIDENT]
15:51:20	Alarm Timer Extended: 0
15:58:25	.
15:59:08	Unit WOOL241 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]
15:59:33	Unit WOOL241 [ SITREP : ] WE ARE DEPARTING - WOOLSTON CREW WILL BE RETURNING TOM
15:59:33	ORROW FOR THE LAST OF THE HOTSPOTS - SCENE GUARD WILL BE ON SCENE TONIGHT AND WI
15:59:33	LL RING 111 IF HOT SPOTS TURN INTO A FIRE - WILL ADV THE BLUE WATCH OFFICER AND
15:59:33	GET THEM TO DO A DRIVEBY TONIGHT
17:00:03	Unit FICHRI1 [ K6 : ON PAGER (STATE LOCATION)]
17:02:13	Unit FICHRI1 [ SITREP : ] - MANUAL TIME ENTERED 31/03/21 17:01:47 LEAVING SCENE
17:02:13	- BACK TOMORROW - SCENE GUARD WILL BE ON SITE ALL WEEKEND - HOT SPOTS WILL BE EX
17:02:13	T TOMORROW MORNING
06:51:58	Unit FICHRI1 [ K1 : PROCEEDING TO INCIDENT]
08:09:38	Unit FICHRI1 [ K2 : IN ATTENDANCE AT INCIDENT]
08:56:24	Alarm Timer Extended: 0
14:16:17	Unit FICHRI1 [ SITREP : ] CAN YOU CONTACT WOOL241 AND ASK THEM IF THEY CAN RESPO
14:16:17	ND BETWEEN 1500 AND 1600 TO EXTINGUISH THE FINAL HOTSPOT ( PHONED [REDACTED]
14:16:17	AT WOOLST
14:16:17	ON AND THEY WILL CALL ON THE RADIO WHEN THEY ARE RESPONDING)
14:51:14	Unit FICHRI1 [ K6 : ON PAGER (STATE LOCATION)]
14:51:26	Unit FICHRI1 [ SITREP : ] INVESTIGATION COMPLETE- WOOLSTON WILL BE HERE SHORTLY
14:51:26	TO EXTINGUISH LAST HOT SPOTS AND PUT IN A STOP MESSAGE - SECURITY GUARD WILL BE
14:51:26	HERE ALL WEEKEND
15:57:47	Unit WOOL241 [ STOP : MESSAGE] SCENE HANDED TO PROPERTY MANAGER
15:57:53	Unit WOOL241 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]
15:58:00	Unit EVENTSCC2 [ K7 : AT NORMAL STATION]

## Incident

**CAD Number** F3211897

**Incident Reporter** [REDACTED]

**Incident Controller**

**Distance Travelled (km)**

**Delay In Receiving Call**

## Property Details

**Occupant** Romanos Foods

**Building Owner****General Property Use** Industrial, Manufacturing**Special Property Use** Bread, Bakery products, Biscuits, Pies etc**Purpose Group****Actions****Persons Reported****Trapped****Evacuation Status** Fully evacuated**Action Prior 1****Action Prior 2****Action Taken** Extinguishment, salvage and ventilation**Civilians****Civilians Rescued** 0**Civilians Extricated** 0**Civilians Assisted** 0**Civilians Evacuated** 30**Origin****Location** Manufacturing, Process, Work room**Level** Ground level**Equipment Used**

Quantity	Equipment
4	Low pressure delivery
2	Monitor
1	Aerial Ladder/Platform

**Equipment Involved**

Equipment Involved

**Year****Make****Model****Fire****Arrival Condition** Large fire**Heat Source** Heat from electrical equip: Defective or faulty**Termination Stage****First Object Ignited**

**First Object Material**

**Second Object Ignited**

**Second Object Material**

**Indicated Cause** Part failure, leak or break

**Certainty of Cause**

**Age of Person**

**Ethnicity**

**Gender**

**FAIP Service Offered** Unknown

---

## Alarms

Type of Alarm Heat detector, Thermal detector

Initiating Call

Performance of System Alerted occupants - detector in room of origin

Failure/Ineffectiveness of system

Number of sprinkler heads operated

Released Under the Official Information Act