

SMS Incident Report


10/05/2021 10:15:58

Summary

CAD Number F3239258 **Status** Closed
Station Nelson Station
Incident Started 09/05/2021 11:16:37 **Incident Ended** 09/05/2021 11:41:19
Incident Type 7104: False Alarm: Accidental Operation K-46-2
Common Name ABBEYFIELD HOUSE TAHUNANUI
Address / Tahunanui
Alarm Method 111 Telephone **Alarm Level** 1
PFA Number
Zone 322176
Map Grid E 1620451 **Map Grid N** 5429694
First Caller [REDACTED] **First Caller Contact** [REDACTED]
Incident Closed 09/05/2021 13:06:49
Report Completed 15:26, Sun 09 May 2021 by [REDACTED]

Responses

Call Sign	Type	Station Alert	Enroute Time	Arrival Time	Departed
NELS214	PM	11:17:06 09 May 2021	11:18:05 09 May 2021	11:24:09 09 May 2021	11:31:27 09 May 2021
NELS217	PR	11:17:06 09 May 2021	11:17:58 09 May 2021	11:24:13 09 May 2021	11:42:26 09 May 2021



Elapsed Times

Call Sign	Start To Alert	Alert To Arrival	Start To Arrival	Start To Departed
NELS214	00:00:29	00:07:03	00:07:32	00:14:50
NELS217	00:00:29	00:07:07	00:07:36	00:25:49

Message Log

Time	Message
11:16:52	INC INFO: ALARM ACTIVATION - COMMERCIAL
11:16:54	** LOI search completed at 09/05/21 11:16:54
11:17:00	** Recommended unit NELS217 for requirement PUMP (>2.9 km) ** Recommended unit
11:17:00	NELS214 for requirement PUMP (>2.9 km)
11:17:03	PA Selcal used to Initiate Alerting. (NELS217 at 3221 NELSON 191211)
11:17:03	.
11:17:03	PA Selcal used to Initiate Alerting. (NELS214 at 3221 NELSON 191211)
11:17:04	NSOF
11:17:05	.
11:17:06	ALERTING_COMPLETED NELS217
11:17:06	ALERTING_COMPLETED NELS214
11:17:12	AL: PAGING ACK RECEIVED FROM STATION 3221 at 05-09-21 11:17:12
11:17:18	AL: PAGING ACK RECEIVED FROM STATION 3221 at 05-09-21 11:17:18
11:17:58	Unit NELS217 [K1 : PROCEEDING TO INCIDENT]
11:18:05	Unit NELS214 [K1 : PROCEEDING TO INCIDENT]
11:24:10	Unit NELS214 [K2 : IN ATTENDANCE AT INCIDENT]
11:24:14	Unit NELS217 [K77 : NOTHING SHOWING]
11:27:20	Unit NELS217 [KC : UNIT CALLING]
11:28:23	Unit NELS217 [SITREP :] SO [REDACTED] PAN IND KITCHEN AREA. ALARM ACT BY BURNT C
11:28:23	OOKING. INV FURTH
11:31:27	Unit NELS214 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
11:40:52	Unit NELS217 [KC : UNIT CALLING]
11:41:19	Unit NELS217 [K46-2 : STOP MESSAGE: FALSE ALARM ACCIDENTAL]
11:42:26	Unit NELS217 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
13:06:49	** Assigned Result Code: STRU, Detailed Event Type: 7100

Incident

CAD Number F3239258

Incident Reporter [REDACTED]

Incident Controller

Distance Travelled (km)

Delay In Receiving Call

False Alarm

False Alarm Type	Smoke alarm (mains powered)
Good Intent Type	General Detector Description - Add details to Additional Comment
Additional comment	Sunday lunch over flowed in oven creating smoke that escaped the oven once door was opened. Smoke travelled through to dinning area activating alarm.

Property Details

Occupant	
Building Owner	
General Property Use	Hospital, Hospice, Rest home, Rehab centre
Special Property Use	Rest home: Without nursing care
Purpose Group	

Civilians

Civilians Rescued	0
Civilians Extricated	0
Civilians Assisted	0
Civilians Evacuated	0

Released Under the Official Information Act