

Water Quality Testing Christchurch Central

PressureZone	LocationID	Address	Determinand	Result	Units	Date	Sample Time	COMMENTS
Rocky Point	CHR001RP	Chapmans Rd 10 Sampling Point	E. coli Enumeration	2	MPN/100 mL	6/3/2018	14.18	
Central	TP00179	Keyes Pump Stn	E. coli Enumeration	16	MPN/100 mL	20/12/2019	13.39	
Central	CHR001CE	Webb St 23 Sampling Point	Lead acid soluble	0.011	mg/L	16/2/2021	11.4	1st sample of 24. 24 hour- sampling
Central	CHR001CE	Bradford Ave 3 Sampling Point	Lead acid soluble	0.03	mg/L	22/2/2021	14.25	1st sample of 24. 24 hour- sampling
Central	CHR001CE	Hutcheson St 46 Sampling Point	Lead acid soluble	0.021	mg/L	24/2/2021	12.45	1st sample of 7. 7 minutes- sampling

- The information corresponds to Laboratory analysis collected from Central Zone (including Rocky Point) from Christchurch water supply system between 1/1/2018 and 30/10/2022. Water supply zones can be found here: [Water chlorination : Christchurch City Council \(ccc.govt.nz\)](https://www.ccc.govt.nz/water-chlorination)
- The reported results exceeded the maximum acceptable values set in Section 2, Tables 2.1, 2.2 and 2.3 of the Drinking Water Standards New Zealand 2005 (revised 2018).
- This information was reported to the Drinking Water Assessor (appointed by the Ministry of Health) until 14 November 2021 and to Taumata Arowai since 15 November 2021.
- Compliance information is publicly available in the Ministry of Health website:
2017-2018: [Annual Report on Drinking-water Quality 2017-2018 \(health.govt.nz\)](https://www.health.govt.nz/publication/annual-report-drinking-water-quality-2017-2018)
2018-2019: [Annual Report on Drinking-water Quality \(health.govt.nz\)](https://www.health.govt.nz/publication/annual-report-drinking-water-quality-2018-2019)
2019-2020: [Annual Report on Drinking Water Quality 2019-2020 \(health.govt.nz\)](https://www.health.govt.nz/publication/annual-report-drinking-water-quality-2019-2020)
2020-2021: [Annual Report on Drinking Water Quality 2020-2021 \(health.govt.nz\)](https://www.health.govt.nz/publication/annual-report-drinking-water-quality-2020-2021)
- Protozoa compliance is assessed against treatment effectiveness assessment as required in the DWSNZ 2005 (rev.2018).