

SMS Incident Report

18/11/2024 08:07:14


Summary

CAD Number F4083978 **Status** Closed
Station Huntly Volunteer Fire Brigade
Incident Started 09/11/2024 00:41:48 **Incident Ended** 09/11/2024 08:43:07
Incident Type 1101: Structure fire with damage
Common Name
Address 9(2)(a) Riverview Road Huntly
Alarm Method 111 Telephone **Alarm Level** 2
PFA Number
Zone 163201
Map Grid E 1790087 **Map Grid N** 5838631
First Caller 9(2)(a) **First Caller Contact** 9(2)(a)
Incident Closed 09/11/2024 12:45:10
Report Completed 6:29, Sat 09 Nov 2024 by Out of Scope

Responses

Call Sign	Type	Station Alert	Enroute Time	Arrival Time	Departed
HUNT321	P1	00:42:31 09 Nov 2024	00:53:18 09 Nov 2024	00:58:22 09 Nov 2024	08:43:09 09 Nov 2024
HUNT3211	WT	00:57:32 09 Nov 2024	01:00:29 09 Nov 2024	01:06:56 09 Nov 2024	05:06:44 09 Nov 2024
NGAR331	P1	00:53:50 09 Nov 2024	00:58:19 09 Nov 2024	01:16:08 09 Nov 2024	03:26:56 09 Nov 2024
NGAR3311	WT	01:03:48 09 Nov 2024	01:08:12 09 Nov 2024	01:23:26 09 Nov 2024	03:21:40 09 Nov 2024
TEKA317	PR	01:12:54 09 Nov 2024	01:18:33 09 Nov 2024	01:35:39 09 Nov 2024	02:52:48 09 Nov 2024
NGAR337	PR	01:28:28 09 Nov 2024	01:33:03 09 Nov 2024	01:45:34 09 Nov 2024	05:09:13 09 Nov 2024
GMWAIKA03	OF	01:31:08 09 Nov 2024	01:33:46 09 Nov 2024	01:53:54 09 Nov 2024	02:54:46 09 Nov 2024
TEKA3111	WT	01:25:06 09 Nov 2024	01:25:11 09 Nov 2024	02:46:19 09 Nov 2024	02:52:52 09 Nov 2024
NGAR3326	CV	02:15:49 09 Nov 2024	02:34:51 09 Nov 2024	03:23:08 09 Nov 2024	04:15:24 09 Nov 2024
VSOWAIKA06	VSO	02:17:38 09 Nov 2024	02:29:36 09 Nov 2024	05:00:18 09 Nov 2024	09:46:52 09 Nov 2024
FIWAIKA02	FSO	06:44:27 09 Nov 2024	06:46:19 09 Nov 2024	07:47:09 09 Nov 2024	11:30:08 09 Nov 2024

HUNT327	PR	00:42:31 09 Nov 2024	02:00:18 09 Nov 2024
EVENTNCC2	OT		12:08:43 09 Nov 2024



Elapsed Times

Call Sign	Start To Alert	Alert To Arrival	Start To Arrival	Start To Departed
HUNT321	00:00:43	00:15:51	00:16:34	08:01:21
HUNT3211	00:15:44	00:09:24	00:25:08	04:24:56
NGAR331	00:12:02	00:22:18	00:34:20	02:45:08
NGAR3311	00:22:00	00:19:38	00:41:38	02:39:52
TEKA317	00:31:06	00:22:45	00:53:51	02:11:00
NGAR337	00:46:40	00:17:06	01:03:46	04:27:25
GMWAIKA03	00:49:20	00:22:46	01:12:06	02:12:58
TEKA3111	00:43:18	01:21:13	02:04:31	02:11:04
NGAR3326	01:34:01	01:07:19	02:41:20	03:33:36
VSOWAIKA06	01:35:50	02:42:40	04:18:30	09:05:04
FIWAIKA02	06:02:39	01:02:42	07:05:21	10:48:20
HUNT327	00:00:43			01:18:30
EVENTNCC2				11:26:55

Notifications

Date	Time	Party Notified
09 Nov 2024	00:58:43	WEL NETWORKS
09 Nov 2024	00:59:09	DISTRICT WAIKATO RE K99
09 Nov 2024	00:59:31	GMWAIKA03 Out of Scope ACKNOWLEDGED VIA AMS
09 Nov 2024	00:59:54	CFO/DCFO HUNTY K99
09 Nov 2024	01:05:17	GMWAIKA06 Out of Scope ACKNOWLEDGED VIA AMS
09 Nov 2024	01:08:12	GMWAIKA03 PAGED SITREP
09 Nov 2024	01:08:17	GMWAIKA03 Out of Scope ACKNOWLEDGED VIA AMS
09 Nov 2024	01:14:10	GMWAIKA03 PAGED RE MP3
09 Nov 2024	01:14:11	GMWAIKA03 Out of Scope ACKNOWLEDGED VIA AMS
09 Nov 2024	01:18:13	EVENT COPIED TO POLICE
09 Nov 2024	01:29:45	DISTRICT WAIKATO RE 2ND ALARM

09 Nov 2024	01:29:53	GMWAIKA03 Out of Scope ACKNOWLEDGED VIA AMS
09 Nov 2024	01:29:54	GMWAIKA06 Out of Scope ACKNOWLEDGED VIA AMS
09 Nov 2024	01:29:55	GMWAIKA03 Out of Scope ACKNOWLEDGED VIA AMS
09 Nov 2024	01:30:01	GMWAIKA03 Out of Scope ACKNOWLEDGED VIA AMS
09 Nov 2024	01:30:26	AMBULANCE VIA INTERCAD
09 Nov 2024	01:31:03	HEALTH PROTECTION OFFICER
09 Nov 2024	02:11:50	FI WAIKATO GROUP PAGED
09 Nov 2024	02:12:12	FIWAIKA08 Out of Scope ACKNOWLEDGED VIA AMS
09 Nov 2024	02:12:26	FIWAIKA08 Out of Scope ACKNOWLEDGED VIA AMS
09 Nov 2024	02:14:04	FIWAIKA02 Out of Scope ACKNOWLEDGED VIA AMS
09 Nov 2024	02:14:16	VSOWAIKA06 (Out of Scope) PAGED RE GEAR
09 Nov 2024	02:25:16	FI Out of Scope WILL ATTEND IN THE MORNING

Message Log

Time	Message
00:42:19	https://web.pcl.govt.nz/?ecn= 9(2)(a)
00:42:20	** LOI search completed at 09/11/24 00:42:20
00:42:21	INC INFO: FIRE IN ROOF
00:42:27	** Recommended unit HUNT321 for requirement PUMP (>2.4 km) ** Recommended unit
00:42:27	HUNT327 for requirement PUMP (>2.4 km)
00:42:28	Station Selcal used to Initiate Alerting. (HUNT321 at 1632 HUNTLY 184323)
00:42:28	Station Selcal used to Initiate Alerting. (HUNT327 at 1632 HUNTLY 184323)
00:42:31	ALERTING_COMPLETED HUNT321
00:42:31	ALERTING_COMPLETED HUNT327
00:50:44	9(2)(a) HOUSE IS ON FIRE ALL PERSONS OUTSIDE UNSURE WHAT HAS CAUSED THE
00:50:44	FIRE
00:51:17	CALLER WONDERING WHY THE BRIGADE ISNT THERE THE SIRENT WENT OFF AGES AGO
00:51:36	ADV CALL THE VOLUNTEER BRIGADE WILL BE THERE ASAP
00:53:18	Unit HUNT321 [K1 : PROCEEDING TO INCIDENT]
00:53:26	Unit HUNT321 [K1 : PROCEEDING TO INCIDENT]
00:53:43	** Requirement PUMP added for alarm level 1
00:53:45	** Recommended unit NGAR331 for requirement PUMP (>10.1 km)
00:53:47	Station Selcal used to Initiate Alerting. (NGAR331 at 1633 NGARUAWAHIA 184333)
00:53:50	ALERTING_COMPLETED NGAR331
00:54:04	Unit HUNT321 [COMCEN COM : MESSAGE] WILL YOU GET A CREW FOR HUNT327?
00:54:11	Unit HUNT321 [SITREP :] NEGATIVE
00:56:28	Unit HUNT321 [KC : UNIT CALLING]

00:56:51 Unit HUNT321 [SITREP :] ATTACH HUNT3211

00:57:04 INC INFO: HOUSE FIRE - HUNT3211 REQUIRED

00:57:10 ** Requirement HUNT3211 added for alarm level 1

00:57:12 ** Recommended unit HUNT3211 for requirement HUNT3211 (>2.3 km)

00:57:31 Phone used to Initiate Alerting.

00:57:32 ALERTING_COMPLETED HUNT3211

00:58:19 Unit NGAR331 [K1 : PROCEEDING TO INCIDENT]

00:58:23 Unit HUNT321 [K99 : PROPERTY FIRE WELL INVOLVED]

00:58:53 INC INFO: HOUSE FIRE - K99 - HUNT3211 REQUIRED

00:58:59 Unit NGAR331 [K1 : PROCEEDING TO INCIDENT]

00:59:38 Updated

00:59:39 Updated

01:00:29 Unit HUNT3211 [K1 : PROCEEDING TO INCIDENT]

01:00:52 WELNETWORKS CALLING BACK WITH ETA

01:01:41 Unit NGAR331 [KC : UNIT CALLING]

01:02:15 Unit NGAR331 [SITREP :] CAN YOU CHECK IF HUNT321 ALSO NEED OUR TANKER FOR THIS

01:02:15 ?

01:02:25 GMWAIKA03 WOULD LIKE THE SITREP PAGED OUT

01:02:40 Unit HUNT327 [KE : UNABLE TO PROCEED (STATE REASON)] ENTERED BY FIRECOM - NO CR

01:02:40 EW

01:03:47 Phone used to Initiate Alerting.

01:03:48 ALERTING_COMPLETED NGAR3311

01:03:59 Unit NGAR331 [COMCEN COM : MESSAGE] WILL CHECK WITH HUNT321 AS SOON AS THEY PASS

01:03:59 SITREP

01:04:13 Unit NGAR331 [SITREP :] COPY WILL JUST ATTACH IT FOR NOW, CREW ON STATION.

01:06:53 Unit HUNT321 [KC : UNIT CALLING]

01:06:56 Unit HUNT3211 [K2 : IN ATTENDANCE AT INCIDENT]

01:07:50 Unit HUNT321 [SITREP :] ONE HOUSE INVOLVED IN FIRE DOUBLE STOREY APPROX 20M BY

01:07:50 15M AT WORK ONE LPD TWO IN BA AWAITING ON FURTHER RESOURCES

01:08:12 Unit NGAR3311 [K1 : PROCEEDING TO INCIDENT]

01:08:17 Unit HUNT321 [COMCEN COM : MESSAGE] YOU HAVE NGAR331 K1 AND ALSO NGARJAWAHIA TAN

01:08:17 KER ALSO K1, DO YOU NEED ANY FURTHER RESOURCES?

01:09:04 Unit HUNT321 [COMCEN COM : MESSAGE] FIRECOM CALLS VIA RT - NIL RESPONSE

01:10:23 Unit NGAR331 [KC : UNIT CALLING]

01:11:09 Unit NGAR331 [SITREP :] ALMOST ON SCENE DID YOU NEED ANY INFORMATION

01:11:29 Unit NGAR331 [KC : UNIT CALLING]

01:11:30 Unit NGAR331 [COMCEN COM : MESSAGE] AFFIRM JUST TRYING TO CONFIRM IF ANY OTHER R

01:11:30 ESOURCES REQUIRED AND ALSO CONFIRM OIC

01:11:39 Unit HUNT321 [KC : UNIT CALLING]

01:11:43 Unit NGAR331 [COMCEN COM : MESSAGE] ALSO BE ADVISED POWER AUTHORITY NOTIFIED

01:12:05 Unit NGAR331 [SITREP :] MK PUMPS 3 AND SO Out of Scope IN CHARGE

01:12:23 INC INFO: HOUSE FIRE - K99 - MK PUMPS 3 TANKERS 2

01:12:28 ** Requirement PUMP added for alarm level 1

01:12:32 ** Recommended unit TEKA317 for requirement PUMP (>19.7 km)

01:12:51 Station Selcal used to Initiate Alerting. (TEKA317 at 1631 TE KAUWHATA 184313)

01:12:54 ALERTING_COMPLETED TEKA317

01:16:08 ENTERED BY FIRECOM AS PER AVL

01:16:08 Unit NGAR331 [K2 : IN ATTENDANCE AT INCIDENT] ENTERED BY FIRECOM AS PER AVL

01:16:33 Unit NGAR331 [KC : UNIT CALLING]

01:17:23 Unit NGAR331 [KC : UNIT CALLING]

01:17:31 Unit NGAR331 [K11P : POLICE REQUIRED] ROAD CLOSURES

01:18:10 FIR2POL YOUR ATTENDANCE REQUIRED ASAP PLEASE FOR ROAD CLOSURES. WE HAVE A HOUSE

01:18:10 TOTALLY INVOLVED IN FIRE

01:18:13 ** Event P060558421 of NZP/HR copied from F4083978 of NZFS/WK at: 09/11/24 01:18

01:18:13 :13

01:18:33 Unit TEKA317 [K1 : PROCEEDING TO INCIDENT]

01:18:42 Unit TEKA317 [K1 : PROCEEDING TO INCIDENT]

01:18:48 FIR2POL ROAD CLOSURE WILL BE FOR RIVERVIEW RD

01:18:50 Unit TEKA317 [K1 : PROCEEDING TO INCIDENT]

01:19:51 Unit TEKA317 [K1 : PROCEEDING TO INCIDENT]

01:19:58 FIR2POL COPY THANKS

01:21:34 Unit TEKA317 [KC : UNIT CALLING]

01:22:19 Unit TEKA317 [K35 : VERIFY ADDRESS OF CALL] DETAILS PASSED

01:23:26 Unit NGAR3311 [K2 : IN ATTENDANCE AT INCIDENT]

01:23:35 Unit NGAR3311 [K2 : IN ATTENDANCE AT INCIDENT]

01:24:43 Alarm Timer Extended: 0

01:25:05 Phone used to Initiate Alerting.

01:25:06 ALERTING_COMPLETED TEKA3111

01:25:12 Unit TEKA3111 [K1 : PROCEEDING TO INCIDENT]

01:25:12 Unit TEKA3111 [K38 : ASSOCIATE THIS APPLIANCE TO EVENT (STATE EVENT ADDRESS)]

01:26:33 Unit HUNT321 [KC : UNIT CALLING]

01:27:15 Unit HUNT321 [SITREP :] ALL CREWS FULLY UTILISED MK PUMPS 4

01:27:24 Unit HUNT321 [COMCEN COM : MESSAGE] FYI THAT WILL MAKE THIS 2ND ALARM

01:27:40 INC INFO: HOUSE FIRE - K99 - 2ND ALARM

01:27:53 **** 2ND ALARM ****

01:27:57 ** Requirement PUMP removed for alarm level 1

01:27:59 ** Requirement PUMP removed for alarm level 1

01:28:00 ** Requirement HUNT3211 removed for alarm level 1

01:28:12 ** Requirement PUMP added for alarm level 1

01:28:17 ** Requirement PUMP added for alarm level 1

01:28:21 ** Requirement PUMP added for alarm level 1

01:28:24 ** Alarm level updated to 2

01:28:24 ** Recommended unit NGAR337 for requirement PUMP (>10.1 km)

01:28:25 Station Selcal used to Initiate Alerting. (NGAR337 at 1633 NGARUAWAHIA 184333)

01:28:28 ALERTING_COMPLETED NGAR337

01:29:52 FIR2POL FYI THIS IS NOW A 2ND ALARM

01:30:20 FIR2AMB 2ND ALARM HOUSE FIRE - FYI FOR NOW

01:30:26 ** Event A01268070 of AMBO/N copied from F4083978 of NZFS/WK at: 09/11/24 01:30:

01:30:26 26

01:30:29 AMBO EVENT 0076-1-2024/11/09-FIR LINKED AT 09/11/2024 01:30:29

01:31:07 Pager used to Initiate Alerting.

01:31:08 ALERTING_COMPLETED GMWAIKA03

01:33:03 Unit NGAR337 [K1 : PROCEEDING TO INCIDENT]

01:33:47 Unit GMWAIKA03 [K1 : PROCEEDING TO INCIDENT]

01:35:39 Unit TEKA317 [K2 : IN ATTENDANCE AT INCIDENT]

01:36:18 WAIKATO HEALTH PROTECTION OFFICER **9(2)(a)** REQUESTED EVENT NUMBER TO BE EMAILED TO

01:36:18 xxxxxx.xxxxxxxxxx@xxxxxxxxxx.xxxxxx.xx

01:42:31 Unit HUNT321 [KC : UNIT CALLING]

01:43:21 Unit HUNT321 [SITREP :] 2 LPD"S INTERTNAL ATTACK 1HPD EXTERNAL ATTACK

01:45:34 Unit NGAR337 [K2 : IN ATTENDANCE AT INCIDENT]

01:49:35 Unit HUNT321 [KC : UNIT CALLING]

01:50:05 Unit HUNT321 [SITREP :] SO **Out of Scope** IM SAFETY OFFICER OF THIS HOUSE FIRE

01:52:34 Alarm Timer Extended: 0

01:52:34 Alarm Timer Extended: 0

01:53:54 Unit GMWAIKA03 [K2 : IN ATTENDANCE AT INCIDENT]

02:00:18 Unit HUNT327 [K7 : AT NORMAL STATION]

02:07:05 Alarm Timer Extended: 0

02:07:05 Alarm Timer Extended: 0

02:07:05 Alarm Timer Extended: 0

02:07:17 Unit HUNT321 [KC : UNIT CALLING]

02:08:10 Unit HUNT321 [K11F : SPECIALIST FIRE INVESTIGATOR REQUIRED] ALSO ADVISE OUR VSO

02:08:10 WE WILL NEED CYLINDERS AND LEVEL 2 KIT

02:10:46 INC INFO: HOUSE FIRE - K99 - 2ND ALARM - TOC 0041 TOA 0058

02:13:06 Unit HUNT321 [KC : UNIT CALLING]
02:13:46 Unit HUNT321 [SITREP :] REQUESTING CANTEEN
02:14:02 Unit HUNT321 [KC : UNIT CALLING]
02:14:31 Unit HUNT321 [SITREP :] WORKING 3 LP 1HP 2 BA CREW
02:15:47 Station Selcal used to Initiate Alerting. (NGAR3326 at 1633 NGARUAWAHIA 184333)
02:15:49 ALERTING_COMPLETED NGAR3326
02:17:37 Pager used to Initiate Alerting.
02:17:38 ALERTING_COMPLETED VSOWAIKA06
02:17:47 Unit VSOWAIKA06 [K38 : ASSOCIATE THIS APPLIANCE TO EVENT (STATE EVENT ADDRESS)]
02:18:24 FIWAIKA02 ACK PAGE AND TRANSFERRED TO HUNT321
02:21:00 AL: PAGING ACK TIMED OUT FOR STATION: 1650 at 09-11-24 02:21:00
02:21:09 Unit HUNT321 [KC : UNIT CALLING]
02:21:56 Unit HUNT321 [SITREP :] WHO IS THE ON CALL VSO AND I WILL CALL HIM
02:22:07 Unit HUNT321 [COMCEN COM : MESSAGE] Out of Scope
02:29:36 Unit VSOWAIKA06 [K1 : PROCEEDING TO INCIDENT]
02:32:52 Unit HUNT321 [COMCEN COM : MESSAGE] ARE YOU AFTER A FULL COOK UP OR LIGHT REFRES
02:32:52 HMENTS. HOW MANY PEOPLE
02:33:10 Unit HUNT321 [SITREP :] FULL COOK UP APPROX 35
02:34:51 Unit NGAR3326 [K1 : PROCEEDING TO INCIDENT]
02:45:44 Unit HUNT321 [KC : UNIT CALLING]
02:46:13 Unit HUNT321 [SITREP :] MAIN FIRE EXT BRIGADE MOPPING UP HOT SPOTS
02:46:19 Unit TEKA3111 [K2 : IN ATTENDANCE AT INCIDENT]
02:52:49 Unit TEKA317 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
02:52:53 Unit TEKA3111 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
02:54:46 Unit GMWAIKA03 [K6 : ON PAGER (STATE LOCATION)]
03:06:33 Alarm Timer Extended: 0
03:08:42 Unit VSOWAIKA06 [K1 : PROCEEDING TO INCIDENT]
03:21:05 Unit NGAR331 [K2 : IN ATTENDANCE AT INCIDENT]
03:21:38 Unit NGAR331 [KC : UNIT CALLING]
03:21:41 Unit NGAR3311 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
03:22:17 Unit NGAR331 [SITREP :] LEAVING SCENE
03:23:08 Unit NGAR3326 [K2 : IN ATTENDANCE AT INCIDENT]
03:26:56 Unit NGAR331 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
03:43:45 Unit HUNT321 [KC : UNIT CALLING]
03:45:03 Unit HUNT321 [SITREP :] BRIGADE SCALING BACK OPERATIONS 1HP 1LP 1 BA CREW
04:10:47 Alarm Timer Extended: 0
04:15:24 Unit NGAR3326 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
04:20:27 Unit HUNT321 [KC : UNIT CALLING]
04:21:01 Unit HUNT321 [SITREP :] 1H 1L TIC IN USE EXT HOT SPOTS

04:44:48 VSOWAIK06 WELFARE CHECK.

04:45:01 Unit VSOWAIKA06 [KC : UNIT CALLING]

04:46:13 Unit VSOWAIKA06 [SITREP :] ACK WELFARE CHECK. GOING TO TE KAUWHATA THEN TO HUN

04:46:13 TLY THEN NGARUWAHIA THEN INTO HAMILTON

05:00:18 Unit VSOWAIKA06 [K2 : IN ATTENDANCE AT INCIDENT]

05:06:44 Unit HUNT3211 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]

05:09:13 Unit NGAR337 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]

05:10:31 Unit HUNT321 [KC : UNIT CALLING]

05:11:08 Unit HUNT321 [STOP : MESSAGE] BRIGADE LEAVING SCENE FI TURNING UP AT ABOUT 7-8A

05:11:08 M

05:11:09 Unit HUNT321 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]

05:41:31 Alarm Timer Extended: 0

06:44:27 Radio used to Initiate Alerting.

06:44:27 ALERTING_COMPLETED FIWAIKA02

06:44:37 Unit FIWAIKA02 [K38 : ASSOCIATE THIS APPLIANCE TO EVENT (STATE EVENT ADDRESS)]

06:44:59 Unit FIWAIKA02 [SITREP :] (VIA PHONE) ETA 60 MIN FROM RAGLAN

06:46:19 Unit FIWAIKA02 [K1 : PROCEEDING TO INCIDENT]

07:06:41 Unit VSOWAIKA06 [K2 : IN ATTENDANCE AT INCIDENT]

07:47:09 Unit FIWAIKA02 [K2 : IN ATTENDANCE AT INCIDENT]

07:57:32 Unit FIWAIKA02 [KC : UNIT CALLING]

07:58:16 Unit FIWAIKA02 [SITREP :] ATTACH A HUNTLY TRUCK TO DEAL WITH HOTSPOTS

07:58:38 INC INFO: HOUSE FIRE - K99 - 2ND ALARM ASSIST FIWAIKA02

07:58:50 Station Selcal used to Initiate Alerting. (HUNT321 at 1632 HUNTLY 184323)

07:58:52 ALERTING_COMPLETED HUNT321

08:02:25 Unit HUNT321 [K1 : PROCEEDING TO INCIDENT]

08:08:14 Unit HUNT321 [K88 : PROPERTY FIRE APPARENTLY SMALL]

08:12:50 Unit HUNT321 [KC : UNIT CALLING]

08:13:32 Unit HUNT321 [SITREP :] DAMPENING DOWN HOTSPOTS 1 HPD K28-1

08:13:47 Unit HUNT321 [K28-1 : RETURN OTHER RESPONDING APPLIANCES]

08:26:33 Alarm Timer Extended: 0

08:27:10 Unit HUNT321 [KC : UNIT CALLING]

08:27:43 Unit HUNT321 [SITREP :] FURTHER HOTSPOTS EXTING BRIG MAKING UP

08:28:00 Alarm Timer Extended: 0

08:42:39 Unit HUNT321 [KC : UNIT CALLING]

08:43:07 Unit HUNT321 [K47 : STOP MESSAGE: MESSAGE UNCHANGED FROM SITREP] SCENE LEFT IN

08:43:07 HANDS OF FI

08:43:09 Unit HUNT321 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]

09:46:52 Unit VSOWAIKA06 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]

10:33:31	** Event Location changed from "9(2)(a) RIVERVIEW RD,HUNTLY, WAIKATO DISTRICT" to "16
10:33:31	4B RIVERVIEW RD,HUNTLY, WAIKATO DISTRICT" at: 09/11/24 10:33:31
10:33:32	** LOI search completed at 09/11/24 10:33:32
10:35:11	Unit FIWAIKA02 [SITREP :] (VIA PHONE) CORRECT ADDRESS IS 164B - NO WELFARE CHE
10:35:11	CKS REQUIRED, HAVE OTHERS WITH ME HERE - WON'T BE TOO MUCH LONGER
11:30:08	Unit FIWAIKA02 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
12:08:43	Unit EVENTNCC2 [K7 : AT NORMAL STATION]

Incident

CAD Number F4083978

Incident Reporter Out of Scope

Incident Controller

Distance Travelled (km)

Delay In Receiving Call

Property Details

Occupant 9(2)(a)

Building Owner Owner occupied

General Property Use Single house

Special Property Use Single house

Purpose Group

Actions

Persons Reported Trapped

Evacuation Status Fully evacuated

Action Prior 1

Action Prior 2

Action Taken Extinguishment only: Includes isolating fuel/power

Civilians

Civilians Rescued	0
Civilians Extricated	0
Civilians Assisted	0
Civilians Evacuated	0

Origin

Location Wall assembly: Concealed wall space

Level 2nd floor

Equipment Used

Quantity	Equipment
1	Hose reel, high pressure delivery
3	Low pressure delivery
1	Foam - Class A Fire-Brake (Green Drums Used)
1	Thermal Imaging Camera (TIC)
1	Ladder for Rescue

Equipment Involved

Equipment Involved

Year

1970

Make

Model

Fire

Arrival Condition Totally involved fire

Heat Source Short circuit arc: Mechanical damage

Termination Stage

First Object Ignited

First Object Material

Second Object Ignited

Second Object Material

Indicated Cause Short circuit, earth fault

Certainty of Cause High

Age of Person No person involved

Ethnicity Unknown

Gender

FAIP Service Offered Unknown

Alarms

Type of Alarm Domestic Smoke Alarms

Initiating Call

Performance of System Alerted occupants - detector in room of origin

Failure/Ineffectiveness of system

Number of sprinkler heads operated

Comments

11/9/2024 6:29:51 AM

Reporter Comments

K99 house fire when first noticed by occupants fire was into ceiling space directly above the meter box on the outside western wall, 3 x LPD, 1 x HPD, 4 x BA crews, TIC hand tools, portable pump.

Out of Scope

RELEASED UNDER THE OFFICIAL INFORMATION ACT 1982