

Drainage design	Pass		SKA
Compliance path	Pass	A means of compliance has been clearly stated in the consent documents.	SKA
Connections	Pass	RFI	SKA

Site Services

1. Please provide overall design site services plan showing building and boundaries and connection to the council mains. Please check and verify all inverts and falls can be achieved and show location of overflow relief gully trap.

2. Please confirm agreement with Public Drainage Samir Hermiz 04 910 3800 021 879 133 for connection to existing public drains to existing Public drains.

3. Please verify the water supplies and type backflow preventer and location has been agreed and approved with Wellington Water Limited Chandra Koswatta phone 04 910 3854, 021 309 496. A double check valve is shown on the drawings but an RPZ is generally required at the boundary unless agreed otherwise with Wellington Water limited.

--- Response - SKA 5 Sep 2016 10:23am ---
2ND RFI SENT

Revised drawings and further clarification received.

inted 6 Sep 2016 3:35pm

Consent 357960

Page 30

Checklist/Elements	Status	Notes	Processed By
		<p>All items confirmed but foul water retention tank arrangement will be covered under a separate consent.</p> <p>The holding tanks are to be removed from the consent as per the agreement between the client and Wellington Water.</p> <p>This is because the public drain is due to be upgraded in 2019 and therefore any upgrade undertaken by our client at considerable cost would be replaced in the near future. It has been agreed by the Wellington City Council and Wellington Water that an amendment will be lodged when the final solution has been agreed between all parties.</p>	