From: Ed Claridge <ed.claridge@aucklandcouncil.govt.nz>
Sent: Monday, 13 February 2017 12:45 PM
To: Davis, Simon; Pauga, Esitone
Cc: Engineers
Subject: 85 Customs St

Hi Simon, Esi

Just to give you a heads up that this building design is in for consent.

I intend to get this design to you as soon as we have the design and modelling electronically.

Given that the top 16 levels are served by only a single means of escape this will need some serious consideration and suggest that you and we will need to be very clear if there are fundamental design issues that impact the viability of the design.

Regards

Ed Claridge | Principal Fire Engineer
Ph (09) 353 9372 | Internal Extn: (46) 9372 | Mobile: 021 722 714
Auckland Council, 35 Graham Street, Auckland
Visit our website: www.aucklandcouncil.govt.nz



Auckland Civil Defence and Emergency Management

Auckland Council

Released under the Official Information Act

CAUTION: This email message and any attachments contain information that may be confidential and may be LEGALLY PRIVILEGED. If you are not the intended recipient, any use, disclosure or copying of this message or attachments is strictly prohibited. If you have received this email message in error please notify us immediately and erase all copies of the message and attachments. We do not accept responsibility for any viruses or similar carried with our email, or any effects our email may have on the recipient computer system or network. Any views expressed in this email may be those of the individual sender and may not necessarily reflect the views of Council.