

# SMS Incident Report

30/05/2017 08:48:12


## Summary

**CAD Number** F2309442 **Status** Closed  
**Station** Auckland City Station  
**Incident Started** 18/05/2017 15:02:11 **Incident Ended** 18/05/2017 16:56:47  
**Incident Type** 1102: Structure fire with no damage  
**Common Name** ACG HOUSE  
**Address** 396 QUEEN STREET AUCKLAND CENTRAL  
**Alarm Method** 111 Telephone **Alarm Level** 3  
**PFA Number**  
**Zone** 142011  
**Map Grid E** 1757228 **Map Grid N** 5919905  
**First Caller** AUCKLAND UNIVERSITY OF TECHNOLOGY- ROB **First Caller Contact** [REDACTED]  
**Incident Closed** 18/05/2017 17:36:50  
**Report Completed** 12:51, Thur 25 May 2017 by Rochelle Martin

## Responses

Call Sign	Type	Station Alert	Enroute Time	Arrival Time	Departed
AUCK207	PR	15:03:26 18 May 2017	15:04:15 18 May 2017	15:05:27 18 May 2017	16:56:53 18 May 2017
AUCK205	HPNP	15:03:33 18 May 2017	15:05:36 18 May 2017	15:07:24 18 May 2017	15:55:43 18 May 2017
AUCK2018	CUHU	15:06:19 18 May 2017	15:07:21 18 May 2017	15:08:56 18 May 2017	16:54:17 18 May 2017
REMU211	P1	15:06:25 18 May 2017	15:08:42 18 May 2017	15:11:13 18 May 2017	16:59:26 18 May 2017
PARN255	HPNP	15:06:20 18 May 2017	15:06:58 18 May 2017	15:12:18 18 May 2017	16:13:12 18 May 2017
GREY261	P1	15:03:29 18 May 2017	15:05:45 18 May 2017	15:12:27 18 May 2017	16:43:55 18 May 2017
AUCKCITY4	OF	15:10:34 18 May 2017	15:10:34 18 May 2017	15:14:04 18 May 2017	17:35:59 18 May 2017
ELLE274	PM	15:06:39 18 May 2017	15:11:31 18 May 2017	15:17:06 18 May 2017	16:40:29 18 May 2017
AVON6015	BA	15:08:22 18 May 2017	15:10:26 18 May 2017	15:19:55 18 May 2017	16:05:06 18 May 2017
TAKA807	PR	15:08:52 18 May 2017	15:10:56 18 May 2017	15:19:59 18 May 2017	16:44:49 18 May 2017
FIKACITY4	FSO	15:12:52 18 May 2017	15:16:16 18 May 2017	15:20:30 18 May 2017	17:16:46 18 May 2017
AVON607	PR	15:08:16 18 May 2017	15:11:20 18 May 2017	15:21:27 18 May 2017	16:35:20 18 May 2017
BIRK821	P1	15:08:39 18 May 2017	15:10:41 18 May 2017	15:21:32 18 May 2017	16:46:37 18 May 2017
AUCKCITY1	OF	15:08:51 18 May 2017	15:08:51 18 May 2017	15:22:42 18 May 2017	16:57:42 18 May 2017
WAITEMATA3	OF	15:12:44 18 May 2017	15:12:45 18 May 2017	15:23:25 18 May 2017	16:43:33 18 May 2017
TEAT664	PM	15:08:21 18 May 2017	15:12:15 18 May 2017	15:24:04 18 May 2017	16:08:19 18 May 2017

AUCKOSU1	SV	15:10:45 18 May 2017	15:10:45 18 May 2017	15:24:35 18 May 2017	16:47:40 18 May 2017
COUNTIES3	OF	15:21:49 18 May 2017	15:23:46 18 May 2017	15:28:35 18 May 2017	16:47:03 18 May 2017
PARN251	P1	15:03:37 18 May 2017	15:06:01 18 May 2017	15:31:15 18 May 2017	16:55:22 18 May 2017
PAPA344	PM	15:08:19 18 May 2017	15:09:38 18 May 2017	15:32:07 18 May 2017	15:58:48 18 May 2017
AUCKOSU2	SV	15:12:44 18 May 2017	15:32:19 18 May 2017	15:42:23 18 May 2017	17:01:38 18 May 2017
BALM611	P1	15:38:46 18 May 2017	15:39:10 18 May 2017	15:42:36 18 May 2017	15:58:55 18 May 2017
FENORTH4	OT	15:46:41 18 May 2017	15:46:53 18 May 2017	15:46:54 18 May 2017	17:18:32 18 May 2017
COUNTIES4	OF	15:20:16 18 May 2017	15:21:28 18 May 2017	15:50:25 18 May 2017	16:30:54 18 May 2017
AUCKCITY5	OF	15:10:49 18 May 2017	15:11:37 18 May 2017	15:50:25 18 May 2017	16:55:56 18 May 2017
AUCKOSU4	CV	15:07:49 18 May 2017	15:48:46 18 May 2017	16:02:36 18 May 2017	17:01:24 18 May 2017
AUCKCITY2	OF	15:10:49 18 May 2017			15:19:25 18 May 2017



**Elapsed Times**

Call Sign	Start To Alert	Alert To Arrival	Start To Arrival	Start To Departed
AUCK207	00:01:15	00:02:01	00:03:16	01:54:42
AUCK205	00:01:22	00:03:51	00:05:13	00:53:32
AUCK2018	00:04:08	00:02:37	00:06:45	01:52:06
REMU211	00:04:14	00:04:48	00:09:02	01:57:15
PARN255	00:04:09	00:05:58	00:10:07	01:11:01
GREY261	00:01:18	00:08:58	00:10:16	01:41:44
AUCKCITY4	00:08:23	00:03:30	00:11:53	02:33:48
ELLE274	00:04:28	00:10:27	00:14:55	01:38:18
AVON6015	00:06:11	00:11:33	00:17:44	01:02:55
TAKA807	00:06:41	00:11:07	00:17:48	01:42:38
FIACITY4	00:10:41	00:07:38	00:18:19	02:14:35
AVON607	00:06:05	00:13:11	00:19:16	01:33:09
BIRK821	00:06:28	00:12:53	00:19:21	01:44:26
AUCKCITY1	00:06:40	00:13:51	00:20:31	01:55:31
WAITEMATA3	00:10:33	00:10:41	00:21:14	01:41:22
TEAT664	00:06:10	00:15:43	00:21:53	01:06:08
AUCKOSU1	00:08:34	00:13:50	00:22:24	01:45:29
COUNTIES3	00:19:38	00:06:46	00:26:24	01:44:52
PARN251	00:01:26	00:27:38	00:29:04	01:53:11
PAPA344	00:06:08	00:23:48	00:29:56	00:56:37

Caution: The information contained in this report is subject to the provisions of the Official Information Act 1982 and the Privacy Act 1993. Neither the information nor the report should be released to any person outside the NZ Fire Service or the National Rural Fire Authority without prior approval

AUCKOSU2	00:10:33	00:29:39	00:40:12	01:59:27
BALM611	00:36:35	00:03:50	00:40:25	00:56:44
FENORTH4	00:44:30	00:00:13	00:44:43	02:16:21
COUNTIES4	00:18:05	00:30:09	00:48:14	01:28:43
AUCKCITY5	00:08:38	00:39:36	00:48:14	01:53:45
AUCKOSU4	00:05:38	00:54:47	01:00:25	01:59:13
AUCKCITY2	00:08:38			00:17:14

**Notifications**

Date	Time	Party Notified
18 May 2017	15:07:32	AAC AUCKLAND CITY PER PAGER RE 3RD ALARM
18 May 2017	15:07:41	AAC COUNTIES MANUKAU 3 (MIKE SHAW) PER PAGER RE 3RD ALARM
18 May 2017	15:07:50	VECTOR
18 May 2017	15:07:59	AAC WAITEMATA3 (VAUGHAN MACKERETH) PERP AGER RE 3RD ALARM
18 May 2017	15:08:15	AUCKALND CITY AREA 3RD ALARM PER PAGER RE 3RD ALARM
18 May 2017	15:08:54	VECTOR RE 3RD ALARM.
18 May 2017	15:09:54	PARNELL FIRE FAILED ON TUNOUT - SELCAL APPLIED
18 May 2017	15:10:01	ELLERSLIE FIRE FAILED ON TUNOUT - SELCAL APPLIED
18 May 2017	15:10:11	TE ATATU FIRE FAILED ON TUNOUT - SELCAL APPLIED
18 May 2017	15:10:41	AC COUNTIES 1 (GEOFF PURCELL) ACK;'D PAGE. RCVD VIA GREATER ALARM.
18 May 2017	15:10:47	AAC
18 May 2017	15:11:21	VAUGHAN MACKERETH ADVISES DAVE WOON WILL NOT BE RESPONDING
18 May 2017	15:15:29	VECTOR: 15 - 20 MINUTES ETA....SFP PASSED
18 May 2017	15:18:30	ATOC VIA PHONE: ASSISTANCE OFFERED FOR ROADING/TRAFFIC MANAGEMENT IF
18 May 2017	15:19:57	CHRIS DELFOS REQUESTS COMMITAL
18 May 2017	15:20:50	HENDERSON VOLUNTEERS PHONE IN TO SAY HEND651 MAY CREW IF REQUIRED FOR COVER
18 May 2017	15:22:31	COUNTIES 3 - MIKE SHAW - PER PHONE - DETAILS PASSED.
18 May 2017	15:26:16	MATHEW FROM CIVIL DEFENCE OFFICE PHONES IN - THEY ARE LISTENING OUT IF THEY
18 May 2017	15:32:55	VECTOR: ADDRESS REQUIRED... ADDRESS PASSED.
18 May 2017	15:48:56	SO BUCHANAN VIA PHONE: K25 HEND651 TO HENDERSON FIRE PLEASE.
18 May 2017	15:56:55	AUCKLAND COUNCIL
18 May 2017	15:59:16	AUCKLAND COUNCIL: DETAILS PASSED TO EDITH WHO WILL TRY TO PHONE NICK AND
18 May 2017	16:11:14	AUCKLAND COUNCIL VIA PHONE: ON HOLD WITH [REDACTED] ... TRYING TO ASCERTAIN AN
18 May 2017	16:13:06	AUCKLAND COUNCIL VIA PHONE: STILL ON HOLD @1613.....
18 May 2017	16:18:50	HEND657 PHONE TO ADVISE AUCK205 IS BACK ON STN, CAN THEY GO HOME. FCOMMS
18 May 2017	16:20:31	AUCKLAND COUNCIL COMPLIANCE OFFICER [REDACTED] PHONES IN - HE CAN HAVE AN

18 May 2017	16:28:54	AUCKLAND COUNCIL PHONE IN TO CONFIRM COMPLIANCE OFFICER ENROUTE
18 May 2017	16:37:33	ONEH221 - K28 COVER MOVE
18 May 2017	16:42:06	OTAH311 - K28 COVER MOVEW
18 May 2017	16:48:33	DEVO811 - K28 COVER MOVE

### Message Log

Time	Message
15:03:03	INC INFO: FIRE ON TOP OF BUILDING
15:03:07	** LOI search completed at 18/05/17 15:03:07
15:03:13	** Recommended unit AUCK205 for requirement AERIAL (>0.4 km)
15:03:13	** Recommended unit AUCK207 for requirement PUMP (>0.4 km)
15:03:13	** Recommended unit GREY261 for requirement PUMP (>2.4 km)
15:03:13	** Recommended unit PARN251 for requirement PUMP (>2.0 km)
15:03:21	CALLER DESCRIBED AS BLUE GLASS BUILDING UNSURE OF NAME
15:03:36	THE SMOKE IS BLACK COMING FROM THE TOP ELEVATOR
15:03:38	Duplicate Event:Location = MAYORAL DR,/QUEEN ST,AUCKLAND CENTRAL,AUCKLAND, Type = STRU - STRUCTURE FIRE, Caller Name = AUCKLAND UNIVERSITY OF TECHNOLOGY, Caller Ph Number = [REDACTED], Caller Address = [REDACTED], AUCKLAND CENTRAL, AUCKLAND CITY, Call Source = 111Inc InfoFIRE ON SIDE OF BUILDING , Event Source = Fire 111
15:03:38	INC INFO: FIRE ON SIDE OF BUILDING
15:03:39	End of Duplicate Event data
15:04:15	INC INFO: BLACK SMOKE IN VICINITY
15:04:15	Duplicate Event:Location = MAYORAL DR,/QUEEN ST,AUCKLAND CENTRAL,AUCKLAND, Type = STRU - STRUCTURE FIRE, Caller Ph Number = [REDACTED], Call Source = 111Inc InfoBLACK SMOKE IN VICINITY, Event Source = Fire 111
15:04:15	End of Duplicate Event data
15:04:16	Unit AUCK207 [ K1 : PROCEEDING TO INCIDENT]
15:04:20	Duplicate Event:Location = QUEEN ST,/MAYORAL DR,AUCKLAND CENTRAL,AUCKLAND, Type = STRU - STRUCTURE FIRE, Caller Name = FLIGHT CENTRE NEW ZEALAND LIMITED, Caller MULTIPLE SUBSCRIBERS FOR CALLER NUMBER [REDACTED]. TESA LOOKUP RECOMMENDED. Ph Number = [REDACTED], Caller Address = [REDACTED], NORTHCOTE, AUCKLAND CITY, Call Source = 111Inc InfoBUILDING FIRE, Event Source = Fire 111
15:04:20	INC INFO: BUILDING FIRE
15:04:20	End of Duplicate Event data
15:04:20	USED TO BE SOFATEL
15:04:20	Unit AUCK207 [ KP : PRIORITY MESSAGE]
15:04:20	Unit AUCK207 [ KP : PRIORITY MESSAGE]
15:04:20	Duplicate Event:Location = MAYORAL DR,/QUEEN ST,AUCKLAND CENTRAL,AUCKLAND, Type

15:04:51 = STRU - STRUCTURE FIRE, Caller Name = AUCKLAND UNIVERSITY OF TECHNOLOGY, Caller  
15:04:51 INC INFO: SMOKE SHOWING FROM BUILDING  
15:04:51 Ph Number = [REDACTED], Caller Address = [REDACTED], AUCKLAND CENTRAL,  
15:04:51 AUCKLAND CITY, Call Source = 111Inc InfoSMOKE SHOWING FROM BUILDING, Event  
15:04:51 Source = Fire 111  
15:04:52 End of Duplicate Event data  
15:04:55 INC INFO: BLACK SMOKE COMING FRON BULDING  
15:04:55 Duplicate Event:Location = MAYORAL DR,/QUEEN ST,AUCKLAND CENTRAL,AUCKLAND, Type  
15:04:55 = STRU - STRUCTURE FIRE, Caller Ph Number = [REDACTED], Call Source = 111Inc  
15:04:55 InfoBLACK SMOKE COMING FRON BULDING , Event Source = Fire 111  
15:04:56 End of Duplicate Event data  
15:05:28 Unit AUCK207 [ K88 : PROPERTY SMALL]  
15:05:30 \*\* Alarm level updated to 2  
15:05:30 \*\* Recommended unit PARN255 for requirement AERIAL (>2.0 km)  
15:05:30 \*\* Recommended unit AUCK2018 for requirement COMU (>5.7 km)  
15:05:30 \*\* Recommended unit REMU211 for requirement PUMP (>3.9 km)  
15:05:30 \*\* Recommended unit ELLE274 for requirement PUMP (>6.3 km)  
15:05:37 Unit AUCK205 [ K1 : PROCEEDING TO INCIDENT]  
15:05:38 INC INFO: BUILDING FIRE  
15:05:38 Duplicate Event:Location = MAYORAL DR,/QUEEN ST,AUCKLAND CENTRAL,AUCKLAND, Type  
15:05:38 = STRU - STRUCTURE FIRE, Caller Name = STATISTICS NEW ZEALAND (AUCK), Caller Ph  
15:05:38 Number = [REDACTED], Caller Address = [REDACTED], GRAFTON, AUCKLAND CITY,  
15:05:38 Call Source = 111Inc InfoBUILDING FIRE, Event Source = Fire 111  
15:05:38 End of Duplicate Event data  
15:05:40 INC INFO: FIRE ON TOP OF BUILDING - TX 3RD ALARM  
15:05:41 Unit AUCK207 [ KP : PRIORITY MESSAGE] TRANSMIT 3RD ALARM  
15:05:46 Unit GREY261 [ K1 : PROCEEDING TO INCIDENT]  
15:05:51 BLUE WINDOWS  
15:05:51 Duplicate Event:Location = MAYORAL DR,/QUEEN ST,AUCKLAND CENTRAL,AUCKLAND, Type  
15:05:51 = STRU - STRUCTURE FIRE, Caller Name = AUCKLAND UNIVERSITY OF TECHNOLOGY, Caller  
15:05:51 INC INFO: SMOKE SHOWING FROM BUILDING  
15:05:51 Ph Number = [REDACTED], Caller Address = [REDACTED], AUCKLAND CENTRAL,  
15:05:51 AUCKLAND CITY, Call Source = 111Inc InfoSMOKE SHOWING FROM BUILDING, Event  
15:05:51 Source = Fire 111  
15:05:51 End of Duplicate Event data  
15:05:57 Duplicate Event:Location = MAYORAL DR,/QUEEN ST,AUCKLAND CENTRAL,AUCKLAND, Type  
15:05:57 = STRU - STRUCTURE FIRE, Caller Ph Number = [REDACTED] Call Source = 111Inc  
15:05:57 InfoFIRE ON BLUE WINDOWED BLUILDING , Event Source = Fire 111  
15:05:58 INC INFO: FIRE ON BLUE WINDOWED BLUILDING  
15:05:58 End of Duplicate Event data

15:06:00 Duplicate Event:Location = MAYORAL DR,/QUEEN ST,AUCKLAND CENTRAL,AUCKLAND, Type  
15:06:00 = STRU - STRUCTURE FIRE, Caller Name = UNIVERSITY OF AUCKLAND, Caller Ph Number  
15:06:00 = [REDACTED], Caller Address = [REDACTED], AUCKLAND CENTRAL, AUCKLAND CITY,  
15:06:00 Call Source = 111Inc InfoBLACK SMOKE , Event Source = Fire 111  
15:06:01 INC INFO: BLACK SMOKE  
15:06:01 End of Duplicate Event data  
15:06:02 Unit PARN251 [ K1 : PROCEEDING TO INCIDENT]  
15:06:07 Unit PARN251 [ K1 : PROCEEDING TO INCIDENT]  
15:06:09 Unit AUCK207 [ KC : UNIT CALLING]  
15:06:11 INC INFO: SMOKE IN VICINITY  
15:06:11 Duplicate Event:Location = MAYORAL DR,AUCKLAND CENTRAL,AUCKLAND, Type = MIN -  
15:06:11 MINOR, Caller Name = SJECL & CECL SHARED SERVICES, Caller Ph Number =  
15:06:11 [REDACTED], Caller Address = [REDACTED], MOUNT WELLINGTON, AUCKLAND CITY,  
15:06:11 Call Source = 111Inc InfoSMOKE IN VICINITY , Event Source = NZFS AES  
15:06:11 End of Duplicate Event data  
15:06:30 Unit AUCK207 [ KC : UNIT CALLING]  
15:06:33 Unit PARN251 [ K1 : PROCEEDING TO INCIDENT]  
15:06:44 Duplicate Event:Location = MAYORAL DR,/QUEEN ST,AUCKLAND CENTRAL,AUCKLAND, Type  
15:06:44 INC INFO: BUILDING FIRE  
15:06:44 = STRU - STRUCTURE FIRE, Caller Name = AUCKLAND UNIVERSITY OF TECHNOLOGY, Caller  
15:06:44 Ph Number = [REDACTED], Caller Address = [REDACTED], AUCKLAND CENTRAL,  
15:06:44 AUCKLAND CITY, Call Source = 111Inc InfoBUILDING FIRE, Event Source = Fire 111  
15:06:44 End of Duplicate Event data  
15:06:46 Duplicate Event:Location = QUEEN ST,AUCKLAND CENTRAL,AUCKLAND, Caller Ph Number  
15:06:46 INC INFO:  
15:06:46 = [REDACTED], Call Source = 111, Event Source = Fire 111  
15:06:46 End of Duplicate Event data  
15:06:59 Unit PARN255 [ K1 : PROCEEDING TO INCIDENT]  
15:07:02 INC INFO: COMMERCIAL BUILDING FIRE  
15:07:02 Duplicate Event:Location = QUEEN ST,AUCKLAND CENTRAL,AUCKLAND, Type = STRU -  
15:07:02 STRUCTURE FIRE, Caller Ph Number = [REDACTED], Call Source = 111Inc  
15:07:02 InfoCOMMERCIAL BUILDING FIRE, Event Source = Fire 111  
15:07:02 End of Duplicate Event data  
15:07:07 Duplicate Event:Location = MAYORAL DR,AUCKLAND CENTRAL,AUCKLAND, Type = MIN -  
15:07:07 INC INFO: SMOKE IN VICINITY  
15:07:07 MINOR, Caller Name = SKY CITY AUCKLAND LIMITED, Caller Ph Number = [REDACTED]  
15:07:07 Caller Address = [REDACTED], AUCKLAND CENTRAL, AUCKLAND CITY, Call Source  
15:07:07 = 111Inc InfoSMOKE IN VICINITY, Event Source = Fire 111  
15:07:07 End of Duplicate Event data  
15:07:15 Unit PARN251 [ K1 : PROCEEDING TO INCIDENT]

15:07:15 \*\* Alarm level updated to 3

15:07:15 \*\* Recommended unit TEAT664 for requirement AERIAL (>10.0 km)

15:07:15 \*\* Recommended unit PAPA344 for requirement AERIAL (>17.6 km)

15:07:15 \*\* Recommended unit AVON6015 for requirement BAT (>7.3 km)

15:07:15 \*\* Recommended unit AUCKOSU4 for requirement CANT (>11.7 km)

15:07:15 \*\* Recommended unit AVON607 for requirement PUMP (>7.3 km)

15:07:15 \*\* Recommended unit TAKA807 for requirement PUMP (>8.7 km)

15:07:15 \*\* Recommended unit BIRK821 for requirement PUMP (>6.4 km)

15:07:21 Unit AUCK2018 [ K1 : PROCEEDING TO INCIDENT]

15:07:24 Unit AUCK205 [ K2 : IN ATTENDANCE AT INCIDENT]

15:07:26 Duplicate Event:Location = QUEEN ST,/MAYORAL DR,AUCKLAND CENTRAL,AUCKLAND, Type  
15:07:26 INC INFO: SMOKE SHOWING  
15:07:26 = STRU - STRUCTURE FIRE, Caller Ph Number = [REDACTED], Call Source = 111Inc  
15:07:26 InfoSMOKE SHOWING , Event Source = Fire 111  
15:07:27 End of Duplicate Event data  
15:07:36 INC INFO: FIRE SEEN FROM TOP OF QUEEN STREET  
15:07:36 Duplicate Event:Location = MAYORAL DR,/QUEEN ST,AUCKLAND CENTRAL,AUCKLAND, Type  
15:07:36 = STRU - STRUCTURE FIRE, Caller Ph Number = [REDACTED], Call Source = 111Inc  
15:07:36 InfoFIRE SEEN FROM TOP OF QUEEN STREET, Event Source = Fire 111  
15:07:36 End of Duplicate Event data  
15:07:40 Unit AUCK207 [ KC : UNIT CALLING]  
15:07:44 FIR2POL: 3RD ALARM BUILDING FIRE  
15:07:50 Unit PARN255 [ K1 : PROCEEDING TO INCIDENT]  
15:07:52 Unit AUCK207 [ KC : UNIT CALLING]  
15:07:54 Duplicate Event:Location = QUEEN ST,/MAYORAL DR,AUCKLAND CENTRAL,AUCKLAND, Type  
15:07:54 = STRU - STRUCTURE FIRE, Caller Ph Number = [REDACTED], Call Source = 111Inc  
15:07:54 InfoSMOKE SHOWING , Event Source = Fire 111  
15:07:56 FIR2AMB: 3RD ALARM BUILDING FIRE  
15:07:58 INC INFO: SMOKE SHOWING  
15:07:59 End of Duplicate Event data  
15:08:03 Unit PARN255 [ K1 : PROCEEDING TO INCIDENT]  
15:08:06 Unit AUCK2018 [ K1 : PROCEEDING TO INCIDENT]  
15:08:08 Unit PARN251 [ K1 : PROCEEDING TO INCIDENT]  
15:08:09 Unit PARN251 [ K1 : PROCEEDING TO INCIDENT]  
15:08:10 Unit AUCK207 [ KC : UNIT CALLING]  
15:08:10 Unit AUCK207 [ KC : UNIT CALLING]  
15:08:11 Duplicate Event:Location = QUEEN ST,AUCKLAND CENTRAL,AUCKLAND, Type = STRU -  
15:08:11 STRUCTURE FIRE, Caller Ph Number = [REDACTED], Call Source = 111Inc  
15:08:11 InfoCOMMERCIAL BUILDING FIRE, Event Source = Fire 111  
15:08:12 INC INFO: COMMERCIAL BUILDING FIRE

15:08:12 End of Duplicate Event data

15:08:13 Unit AUCK207 [ KC : UNIT CALLING]

15:08:13 AMBO EVENT 0573-1-2017/05/18-FIR LINKED AT 18/05/2017 15:08:13

15:08:13 Unit AUCK207 [ KC : UNIT CALLING]

15:08:26 Duplicate Event:Location = MAYORAL DR,/QUEEN ST,AUCKLAND CENTRAL,AUCKLAND, Type  
INC INFO: BLACK SMOKE SHOWING  
= STRU - STRUCTURE FIRE, Caller Ph Number = [REDACTED], Call Source = 111Inc  
InfoBLACK SMOKE SHOWING , Event Source = Fire 111

15:08:26 End of Duplicate Event data

15:08:27 Unit AUCK2018 [ K1 : PROCEEDING TO INCIDENT]

15:08:28 Duplicate Event:Location = QUEEN ST,AUCKLAND CENTRAL,AUCKLAND, Caller Ph Number  
INC INFO:  
= [REDACTED], Call Source = 111, Event Source = Fire 111

15:08:28 End of Duplicate Event data

15:08:33 Unit PARN255 [ K1 : PROCEEDING TO INCIDENT]

15:08:33 Duplicate Event:Location = MAYORAL DR,/QUEEN ST,AUCKLAND CENTRAL,AUCKLAND, Type  
INC INFO: SMOKE SEEN  
= MIN - MINOR, Caller Ph Number = [REDACTED], Call Source = 111Inc InfoSMOKE  
SEEN, Event Source = Fire 111

15:08:33 End of Duplicate Event data

15:08:43 Unit REMU211 [ K1 : PROCEEDING TO INCIDENT]

15:08:51 Unit AUCKCITY1 [ K1 : PROCEEDING TO INCIDENT]

15:08:57 Unit AUCK2018 [ K2 : IN ATTENDANCE AT INCIDENT]

15:09:23 [FIR] amb will stage at SFP Queen & Turner

15:09:24 Duplicate Event:Location = QUEEN ST,AUCKLAND CENTRAL,AUCKLAND, Caller Ph Number  
INC INFO:  
= [REDACTED], Call Source = 111, Event Source = Fire 111

15:09:24 End of Duplicate Event data

15:09:31 Unit PARN251 [ K1 : PROCEEDING TO INCIDENT]

15:09:38 Unit AUCK2018 [ K1 : PROCEEDING TO INCIDENT]

15:09:39 Unit PAPA344 [ K1 : PROCEEDING TO INCIDENT]

15:09:47 Unit PAPA344 [ K1 : PROCEEDING TO INCIDENT]

15:09:51 Duplicate Event:Location = QUEEN ST,AUCKLAND CENTRAL,AUCKLAND, Type = STRU -  
INC INFO: BUILDING FIRE  
STRUCTURE FIRE, Caller Ph Number = [REDACTED], Call Source = 111Inc  
InfoBUILDING FIRE , Event Source = Fire 111

15:09:51 End of Duplicate Event data

15:10:06 Duplicate Event:Location = QUEEN ST,AUCKLAND CENTRAL,AUCKLAND, Caller Name =  
INC INFO:  
UNIVERSITY OF AUCKLAND, Caller Ph Number = [REDACTED], Caller Address = 12



15:10:06	GRAFTON ROAD, AUCKLAND CENTRAL, AUCKLAND CITY, Call Source = 111, Event Source =
15:10:06	Fire 111
15:10:06	End of Duplicate Event data
15:10:09	Duplicate Event:Location = QUEEN ST,/MAYORAL DR,AUCKLAND CENTRAL,AUCKLAND, Type
15:10:09	INC INFO: SMOKE SHOWING
15:10:09	= STRU - STRUCTURE FIRE, Caller Name = PREPAID/PREPAID, Caller Ph Number =
15:10:09	[REDACTED], Caller Address = TELECOM CELLULAR 027, KARORI, WELLINGTON CITY,
15:10:09	Call Source = 111Inc InfoSMOKE SHOWING , Event Source = Fire 111
15:10:09	End of Duplicate Event data
15:10:10	Unit PAPA344 [ K1 : PROCEEDING TO INCIDENT]
15:10:16	Unit AUCK2018 [ K1 : PROCEEDING TO INCIDENT]
15:10:21	INC INFO: COMMERCIAL BUILDING FIRE
15:10:21	Duplicate Event:Location = QUEEN ST,AUCKLAND CENTRAL,AUCKLAND, Type = STRU -
15:10:21	STRUCTURE FIRE, Caller Ph Number = [REDACTED], Call Source = 111Inc
15:10:21	InfoCOMMERCIAL BUILDING FIRE, Event Source = Fire 111
15:10:21	End of Duplicate Event data
15:10:22	Unit AUCK205 [ K2 : IN ATTENDANCE AT INCIDENT]
15:10:27	Unit AVON6015 [ K1 : PROCEEDING TO INCIDENT]
15:10:35	Unit AUCKCITY4 [ K1 : PROCEEDING TO INCIDENT]
15:10:41	Unit BIRK821 [ K1 : PROCEEDING TO INCIDENT]
15:10:41	MONITORING
15:10:45	Unit AUCKOSU1 [ K1 : PROCEEDING TO INCIDENT]
15:10:47	AL: PAGING ACK TIMED OUT FOR STATION: 1466 at 18/05/17 15:10:47
15:10:57	Unit TAKA807 [ K1 : PROCEEDING TO INCIDENT]
15:11:01	Unit PARN255 [ K1 : PROCEEDING TO INCIDENT]
15:11:01	AAC WAITEMATA3 (VAUGHAN MACKERETH) ACK'D PAGE...
15:11:07	Unit AUCKCITY1 [ SITREP : ] COPY SITREO
15:11:07	Duplicate Event:Location = MAYORAL DR,/QUEEN ST,AUCKLAND CENTRAL,AUCKLAND, Type
15:11:07	= STRU - STRUCTURE FIRE, Caller Name = UNIVERSITY OF AUCKLAND, Caller Ph Number
15:11:07	= [REDACTED], Caller Address = [REDACTED], AUCKLAND CENTRAL, AUCKLAND CITY,
15:11:07	Call Source = 111Inc InfoSOKE SHOWING , Event Source = Fire 111
15:11:10	INC INFO: SOKE SHOWING
15:11:11	End of Duplicate Event data
15:11:15	Unit REMU211 [ K2 : IN ATTENDANCE AT INCIDENT]
15:11:21	INC INFO:
15:11:21	Unit AVON607 [ K1 : PROCEEDING TO INCIDENT]
15:11:21	Duplicate Event:Location = QUEEN ST,AUCKLAND CENTRAL,AUCKLAND, Caller Ph Number
15:11:21	= 102102328974, Call Source = 111, Event Source = Fire 111
15:11:21	End of Duplicate Event data
15:11:22	Unit AUCKCITY5 [ KC : UNIT CALLING]

15:11:26 Unit AVON607 [ K1 : PROCEEDING TO INCIDENT]  
15:11:32 Unit ELLE274 [ K1 : PROCEEDING TO INCIDENT]  
15:11:35 INC INFO: SMOKE SHOWING  
15:11:35 Duplicate Event:Location = QUEEN ST,/MAYORAL DR,AUCKLAND CENTRAL,AUCKLAND, Type  
15:11:35 = STRU - STRUCTURE FIRE, Caller Ph Number = [REDACTED], Call Source = 111Inc  
15:11:35 InfoSMOKE SHOWING , Event Source = Fire 111  
15:11:35 End of Duplicate Event data  
15:11:38 Unit AUCKCITY5 [ K1 : PROCEEDING TO INCIDENT]  
15:11:46 INC INFO: SMOKE IN VICINITY  
15:11:46 Duplicate Event:Location = MAYORAL DR,/QUEEN ST,AUCKLAND CENTRAL,AUCKLAND, Type  
15:11:46 = MIN - MINOR, Caller Ph Number = [REDACTED], Call Source = 111Inc InfoSMOKE IN  
15:11:46 VICINITY, Event Source = Fire 111  
15:11:46 End of Duplicate Event data  
15:12:15 Unit TEAT664 [ K1 : PROCEEDING TO INCIDENT]  
15:12:18 Unit PARN255 [ K2 : IN ATTENDANCE AT INCIDENT]  
15:12:23 INC INFO: BUILDING FIRE  
15:12:23 Unit PARN255 [ K2 : IN ATTENDANCE AT INCIDENT]  
15:12:23 Duplicate Event:Location = MAYORAL DR,/QUEEN ST,AUCKLAND CENTRAL,AUCKLAND, Type  
15:12:23 = STRU - STRUCTURE FIRE, Caller Ph Number = [REDACTED], Call Source = 111Inc  
15:12:23 InfoBUILDING FIRE, Event Source = Fire 111  
15:12:23 End of Duplicate Event data  
15:12:27 Unit GREY261 [ K2 : IN ATTENDANCE AT INCIDENT]  
15:12:45 Unit WAITEMATA3 [ K1 : PROCEEDING TO INCIDENT]  
15:12:54 INC INFO: FIRE ON TOP OF BLDG - TX 3RD TOC1503 TOA1505  
15:13:35 Unit AUCK2018 [ K2 : IN ATTENDANCE AT INCIDENT]  
15:13:43 Duplicate Event:Location = MAYORAL DR,/QUEEN ST,AUCKLAND CENTRAL,AUCKLAND, Type  
15:13:43 = STRU - STRUCTURE FIRE, Caller Ph Number = [REDACTED], Call Source = 111Inc  
15:13:43 InfoLARGE AMOUNT OF SMOKE SHOWING, Event Source = Fire 111  
15:13:44 INC INFO: LARGE AMOUNT OF SMOKE SHOWING  
15:13:44 End of Duplicate Event data  
15:13:57 Duplicate Event:Location = 120 MAYORAL DR,AUCKLAND CENTRAL,AUCKLAND: @AUT CITY  
15:13:57 INC INFO: SMOKE SEEN FROM BUILDING ACROSS RD  
15:13:57 CAMPUS WY BUILDING, Type = STRU - STRUCTURE FIRE, Caller Ph Number =  
15:13:57 [REDACTED], Call Source = 111Inc InfoSMOKE SEEN FROM BUILDING ACROSS RD, Event  
15:13:57 Source = Fire 111  
15:13:57 End of Duplicate Event data  
15:14:05 Unit AUCKCITY4 [ K2 : IN ATTENDANCE AT INCIDENT]  
15:14:08 COVERING UNIT DEVO811 DISPATCHED TO STATION TAKAPUNA  
15:14:08 D0710063  
15:14:15 INC INFO: BUILDING FIRE

15:14:15 Duplicate Event:Location = QUEEN ST,/MAYORAL DR,AUCKLAND CENTRAL,AUCKLAND, Type  
15:14:15 = STRU - STRUCTURE FIRE, Caller Name = JUCEBOX LIMITED, Caller Ph Number =  
15:14:15 [REDACTED] Caller Address = TELECOM CELLULAR 027, BLENHEIM, MARLBOROUGH  
15:14:15 DISTRICT, Call Source = 111Inc InfoBUILDING FIRE, Event Source = Fire 111  
15:14:15 End of Duplicate Event data  
15:14:57 COVERING UNIT BALM611 DISPATCHED TO STATION AUCKLAND  
15:14:57 D0710063  
15:15:09 NEAR THETOWN HALL  
15:15:09 Duplicate Event:Location = QUEEN ST,/MAYORAL DR,AUCKLAND CENTRAL,AUCKLAND, Type  
15:15:09 INC INFO: SMOKE IN THE VICINITY  
15:15:09 = MIN - MINOR, Caller Ph Number = [REDACTED], Call Source = 111Inc InfoSMOKE  
15:15:09 IN THE VICINITY, Event Source = Fire 111  
15:15:10 End of Duplicate Event data  
15:15:36 Duplicate Event:Location = QUEEN ST,/MAYORAL DR,AUCKLAND CENTRAL,AUCKLAND, Type  
15:15:36 INC INFO: SMOKE SHOWING  
15:15:36 = STRU - STRUCTURE FIRE, Caller Name = [REDACTED], Caller Ph Number =  
15:15:36 [REDACTED] Caller Address = TELECOM CELLULAR 027, KAIPARA FLATS, AUCKLAND  
15:15:36 CITY, Call Source = 111Inc InfoSMOKE SHOWING , Event Source = Fire 111  
15:15:36 End of Duplicate Event data  
15:15:38 COVERING UNIT HEND657 DISPATCHED TO STATION AUCKLAND  
15:15:38 D0710063  
15:16:16 Unit FIAKCITY4 [ K1 : PROCEEDING TO INCIDENT]  
15:16:40 COVERING UNIT MTRO621 DISPATCHED TO STATION BALMORAL  
15:16:40 D0710063  
15:16:51 Duplicate Event:Location = QUEEN ST,/MAYORAL DR,AUCKLAND CENTRAL,AUCKLAND, Type  
15:16:51 = STRU - STRUCTURE FIRE, Caller Name = DESIGNWORKS (NZ) LTD (MOBILES), Caller Ph  
15:16:51 Number = [REDACTED], Caller Address = [REDACTED], AUCKLAND CENTRAL,  
15:16:51 AUCKLAND CITY, Call Source = 111Inc InfoMOKE SHOWING , Event Source = Fire 111  
15:16:52 INC INFO: MOKE SHOWING  
15:16:52 End of Duplicate Event data  
15:16:55 Duplicate Event:Location = MAYORAL DR,AUCKLAND CENTRAL,AUCKLAND, Type = STRU -  
15:16:55 INC INFO: FIRE SEEN  
15:16:55 STRUCTURE FIRE, Caller Name = UNIVERSITY OF AUCKLAND, Caller Ph Number =  
15:16:55 [REDACTED] Caller Address = TELECOM CELLULAR 027, EPSOM, AUCKLAND CITY, Call  
15:16:55 Source = 111Inc InfoFIRE SEEN, Event Source = Fire 111  
15:16:55 End of Duplicate Event data  
15:17:06 Unit ELLE274 [ K2 : IN ATTENDANCE AT INCIDENT]  
15:17:37 COVERING UNIT ONEH221 DISPATCHED TO STATION ELLERSLIE  
15:17:37 D0710063  
15:18:30 REQUIRED - IF SO, PLEASE PHONE AND LET THEM KNOW.

15:18:40 INC INFO:  
15:18:40 Duplicate Event:Location = QUEEN ST,AUCKLAND CENTRAL,AUCKLAND, Caller Ph Number  
15:18:40 = [REDACTED] Call Source = 111, Event Source = Fire 111  
15:18:40 End of Duplicate Event data  
15:18:43 Duplicate Event:Location = MAYORAL DR,AUCKLAND CENTRAL,AUCKLAND, Type = MIN -  
15:18:43 MINOR, Caller Name = UNIVERSITY OF AUCKLAND, Caller Ph Number = [REDACTED],  
15:18:43 Caller Address = [REDACTED], AUCKLAND CENTRAL, AUCKLAND CITY, Call Source =  
15:18:43 111Inc InfoSMOKE IN THE VICINITY, Event Source = Fire 111  
15:18:44 INC INFO: SMOKE IN THE VICINITY  
15:18:44 End of Duplicate Event data  
15:18:50 Unit AUCKOSU1 [ K1 : PROCEEDING TO INCIDENT]  
15:19:07 Unit AUCKCITY5 [ K6 : ON TELEPAGER]  
15:19:22 Unit AUCKCITY5 [ K1 : PROCEEDING TO INCIDENT]  
15:19:26 Unit AUCKCITY2 [ K6 : ON TELEPAGER]  
15:19:29 Unit TEAT664 [ KC : UNIT CALLING]  
15:19:55 Unit TEAT664 [ SITREP : ] SFP (PASSED)  
15:19:55 Unit AVON6015 [ K2 : IN ATTENDANCE AT INCIDENT]  
15:19:59 Duplicate Event:Location = QUEEN ST,/MAYORAL DR,AUCKLAND CENTRAL,AUCKLAND, Type  
15:19:59 INC INFO: BUILDING FIRE  
15:19:59 Unit TAKA807 [ K2 : IN ATTENDANCE AT INCIDENT]  
15:19:59 = STRU - STRUCTURE FIRE, Caller Ph Number = [REDACTED], Call Source = 111Inc  
15:19:59 InfoBUILDING FIRE, Event Source = Fire 111  
15:19:59 End of Duplicate Event data  
15:20:21 Unit AVON6015 [ K2 : IN ATTENDANCE AT INCIDENT]  
15:20:31 Unit FIAKCITY4 [ K2 : IN ATTENDANCE AT INCIDENT]  
15:20:50 TO HENDERSON FIRE STATION  
15:21:08 Unit AUCK2018 [ KC : UNIT CALLING]  
15:21:28 Unit COUNTIES4 [ K1 : PROCEEDING TO INCIDENT] RESPONDING FROM QUEEN STREET  
15:21:28 Unit AVON607 [ K2 : IN ATTENDANCE AT INCIDENT]  
15:21:32 Unit BIRK821 [ K2 : IN ATTENDANCE AT INCIDENT]  
15:21:38 Unit AUCK207 [ SITREP : ] SSO MARTIN - ;ARGE VOLUMES OF SMOEK SHOWING FROM ROOF  
15:21:38 OF BUILDING. ATTEMPTING OT GAIN ACCESS. BUILDING POSSIBLY UNDER CONTRUSTUION  
15:22:02 Unit COUNTIES3 [ K38 : ASSOCIATE THIS UNIT TO EVENT - EVENT ADDRESS] (PER PHONE)  
15:22:10 Unit COUNTIES3 [ K39 : RE-TRANSMIT YOUR CURRENT STATUS] (PER PHONE)  
15:22:14 Unit AUCK2018 [ K44 : COMMAND OR CONTROL POINT ESTABLISHED - OIC AND LOCATION]  
15:22:14 MAYORAL COMMAND - AAC TWOMEY  
15:22:26 Unit AUCK2018 [ K45 : COMMAND RESPONSIBILITY CHANGED TO - NAME] AC TWOMEY  
15:22:41 Unit AUCK2018 [ KC : UNIT CALLING]  
15:22:42 Unit AUCKCITY1 [ K2 : IN ATTENDANCE AT INCIDENT]  
15:22:59 Unit AUCK2018 [ SITREP : ] 369 QUEEN STREET

15:23:08	** Event Location changed from "MAYORAL DR,/QUEEN ST,AUCKLAND CENTRAL,AUCKLAND"
15:23:08	to "396 QUEEN ST,AUCKLAND CENTRAL,AUCKLAND: @ACG HOUSE" at: 18/05/17 15:23:08
15:23:10	** LOI search completed at 18/05/17 15:23:10
15:23:26	Unit WAITEMATA3 [ K2 : IN ATTENDANCE AT INCIDENT]
15:23:47	Unit COUNTIES3 [ K1 : PROCEEDING TO INCIDENT]
15:23:51	Unit COUNTIES3 [ K1 : PROCEEDING TO INCIDENT]
15:24:00	Unit COUNTIES3 [ K1 : PROCEEDING TO INCIDENT]
15:24:04	Unit TEAT664 [ K2 : IN ATTENDANCE AT INCIDENT]
15:24:08	Duplicate Event:Location = MAYORAL DR,/QUEEN ST,AUCKLAND CENTRAL,AUCKLAND, Type
15:24:08	INC INFO: BUILDING FIRE
15:24:08	= STRU - STRUCTURE FIRE, Caller Ph Number = [REDACTED], Call Source = 111Inc
15:24:08	InfoBUILDING FIRE, Event Source = Fire 111
15:24:08	End of Duplicate Event data
15:24:36	Unit AUCKOSU1 [ K2 : IN ATTENDANCE AT INCIDENT]
15:24:51	Unit AUCK2018 [ KC : UNIT CALLING]
15:25:38	Unit AUCK2018 [ SITREP : ] AC TWOMEY - 21 STORY BUILDING. FIRE LOCATED ON ROOF
15:25:38	OF BUILDING IN LARGE METAL BOX. ATTEMPTING TO GET WATER TO TOP FLOOR THROUGH
15:25:38	RISER
15:26:16	ARE NEEDED - ASK IF BUILDING IS RESIDENTIAL OR COMMERCIAL - ADVISED CANNOT
15:26:16	CONFIRM BUT ADDRESS OS 396 QUEEN ST PASSED (ACG HOUSE)
15:27:28	COVERING UNIT TITI691 DISPATCHED TO STATION BALMORAL AT
15:27:28	D0710063
15:28:34	COVERING UNIT PAPA387 DISPATCHED TO STATION OTAHUHU AT
15:28:34	D0710063
15:28:36	Unit COUNTIES3 [ K2 : IN ATTENDANCE AT INCIDENT]
15:28:44	Unit COUNTIES3 [ K2 : IN ATTENDANCE AT INCIDENT]
15:29:37	COVERING UNIT STHE241 DISPATCHED TO STATION PARNELL AT
15:29:37	D0710063
15:29:47	Unit AUCK2018 [ KC : UNIT CALLING]
15:30:23	Unit AUCK2018 [ SITREP : ] RISER NOT FUNCTIONING ABOVE 4TH FLOOR. RUNNING
15:30:23	HOSELINES FROM 4TH FLOOR TO ROOF.
15:31:15	Unit PARN251 [ K2 : IN ATTENDANCE AT INCIDENT]
15:32:07	Unit PAPA344 [ K2 : IN ATTENDANCE AT INCIDENT]
15:32:20	Unit AUCKOSU2 [ K1 : PROCEEDING TO INCIDENT]
15:33:14	COVERING UNIT ONEH221 DISPATCHED TO STATION GREY LYNN
15:33:14	D0710063
15:33:25	Duplicate Event:Location = QUEEN ST,/MAYORAL DR,AUCKLAND CENTRAL,AUCKLAND, Type
15:33:25	INC INFO: SMOKE SHOWING
15:33:25	= STRU - STRUCTURE FIRE, Caller Ph Number = [REDACTED], Call Source = 111Inc
15:33:25	InfoSMOKE SHOWING , Event Source = Fire 111

15:33:25	End of Duplicate Event data
15:33:53	COVERING UNIT OTAH311 DISPATCHED TO STATION ELLERSLIE
15:33:53	D0710063
15:34:49	Unit AUCKOSU2 [ K1 : PROCEEDING TO INCIDENT]
15:39:11	Unit BALM611 [ K1 : PROCEEDING TO INCIDENT]
15:39:45	Unit AUCKOSU4 [ KC : UNIT CALLING]
15:40:12	Unit AUCKOSU4 [ K38 : ASSOCIATE THIS UNIT TO EVENT - EVENT ADDRESS]
15:40:26	Unit AUCKOSU4 [ KP : PRIORITY MESSAGE]
15:40:52	Unit AUCKOSU4 [ SITREP : ] PRESSED IN ERROR
15:41:32	Unit AUCK2018 [ KC : UNIT CALLING]
15:42:23	Unit AUCKOSU2 [ K2 : IN ATTENDANCE AT INCIDENT]
15:42:29	Unit AUCK2018 [ STOP : MESSAGE] 21 STOREY BUILDING - 50X20M - FIRE ON ROOF.
15:42:29	BUILDIGN RISER SYSTEM NON OPERATIONAL. LPDS BEING ESTABLISHED FROM GROUND LEVEL
15:42:37	Unit BALM611 [ K2 : IN ATTENDANCE AT INCIDENT]
15:43:21	Unit AUCK2018 [ SITREP : ] BUILDING IS UNDER RENOVATION
15:45:52	Unit AUCK2018 [ KC : UNIT CALLING]
15:46:01	Unit AUCK2018 [ KC : UNIT CALLING]
15:46:23	Unit AUCK2018 [ SITREP : ] ATTACH FIRE ENGINEER NORTHERN 4 TO THIS INCIDENT
15:46:54	Unit FENORTH4 [ K2 : IN ATTENDANCE AT INCIDENT]
15:48:40	COVERING UNIT GLEN641 DISPATCHED TO STATION AVONDALE
15:48:40	D0710063
15:48:46	Unit AUCKOSU4 [ K1 : PROCEEDING TO INCIDENT]
15:49:23	COVERING UNIT HEND651 DISPATCHED TO STATION HENDERSON
15:49:23	D0710063
15:50:25	Unit AUCKCITY5 [ K2 : IN ATTENDANCE AT INCIDENT]
15:50:26	Unit COUNTIES4 [ K2 : IN ATTENDANCE AT INCIDENT]
15:55:09	Unit AUCK2018 [ KC : UNIT CALLING]
15:55:17	Unit AUCK2018 [ KC : UNIT CALLING]
15:55:45	Unit AUCK205 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]
15:56:36	Unit AUCK2018 [ SITREP : ] URGENTLY REQUIRE COUNCIL COMPLIANCE OFFICER NICK
15:56:36	BARHAM IF NOT AVAILABLE ANY OFFICER WILL SO
15:57:07	Unit PAPA344 [ K2 : IN ATTENDANCE AT INCIDENT]
15:58:49	Unit PAPA344 [ K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]
15:58:56	Unit BALM611 [ K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]
15:59:16	PHONE BACK WITH AN ETA.
16:01:53	Unit AUCKOSU1 [ KC : UNIT CALLING]
16:02:36	Unit AUCKOSU4 [ K2 : IN ATTENDANCE AT INCIDENT] VIA OSU1
16:04:20	Unit AUCK2018 [ KC : UNIT CALLING]
16:04:50	Unit AUCK2018 [ SITREP : ] INCIDNET UNDER CONTROL - FIRE EXT. 3RD ALARM

16:04:50 APPLIANCES BEING RELEASED

16:05:08 Unit AVON6015 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]

16:06:25 Unit AVON607 [ SITREP : ] (PER PHONE) WE'RE ON OUR WAY HOME. AVON6015 WILL

16:06:25 REMAIN AVAILABLE HOWEVER WE WILL REMAIN K2.

16:08:21 Unit TEAT664 [ K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]

16:09:10 Unit FIAKCITY4 [ SITREP : ] ( [REDACTED] ) THE COMMAND UNIT MADE A

16:09:10 REQUEST FOR AN AUCKLAND COUNCIL COMPLIANCE OFFICER, DID YOU MAKE CONTACT

16:09:10 WITH

16:09:10 THEM?

16:10:14 Unit FIAKCITY4 [COMCEN COM : MESSAGE] (PER PHONE) AFFIRM. DETAILS PASSED TO

16:10:14 COUNCIL AFTER REQUEST, THEY WERE ATTEMPTING TO GET A HOLD OF NICK OR WHICH

16:10:14 EVER

16:10:14 OFFICER WAS AVAILABLE

16:10:54 Unit FIAKCITY4 [ SITREP : ] (PER PHONE) COULD YOU PHONE THEM BACK AND REQUEST

16:10:54 FOR A COMPLIANCE OFFICER ETA AND PHONE ME DIRECTLY VIA MY CELLPHONE PLEASE

16:11:14 ETA.

16:13:14 Unit PARN255 [ K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]

16:17:53 Unit AUCK2018 [ KC : UNIT CALLING]

16:18:30 Unit PARN251 [ K2 : IN ATTENDANCE AT INCIDENT]

16:18:39 Unit AUCK2018 [ SITREP : ] ETA FOR COUNCIL OFFICER (TRANSERRING THROUGH TO

16:18:39 RUSSEL DICKSON)

16:18:50 REQUESTS THEY STAY

16:20:31 AFTER HOURS REP THERE IN LESS THAN 30MINS - TRANSFERRED TO FIAKCITY4 (RUSSELL

16:20:31 DICKSON) ON [REDACTED]

16:21:01 PHONE NUMBER FOR [REDACTED] FROM AUCKLAND COUNCIL COMPLIANCE IS [REDACTED]

16:30:56 Unit COUNTIES4 [ K6 : ON TELEPAGER]

16:35:21 Unit AVON607 [ K7 : AT NORMAL STATION]

16:38:52 Unit AUCK2018 [ KC : UNIT CALLING]

16:39:42 Unit AUCK2018 [ K45 : COMMAND RESPONSIBILITY CHANGED TO - NAME] SSO MARTIN -

16:39:42 AUCK207

16:40:30 Unit ELLE274 [ K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]

16:43:34 Unit WAITEMATA3 [ K6 : ON TELEPAGER]

16:43:56 Unit GREY261 [ K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]

16:44:50 Unit TAKA807 [ K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]

16:46:38 Unit BIRK821 [ K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]

16:47:04 Unit COUNTIES3 [ K6 : ON TELEPAGER]

16:47:41 Unit AUCKOSU1 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]

16:54:18 Unit AUCK2018 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]

16:54:51 Unit PARN251 [ KC : UNIT CALLING]

16:55:24 Unit PARN251 [ K10 : RECOMMISSIONING]

16:55:56 Unit AUCKCITY5 [ K6 : ON TELEPAGER]

16:56:22	Unit AUCK207 [ KC : UNIT CALLING]
16:56:47	Unit AUCK207 [ K47 : STOP MESSAGE: MESSAGE UNCHANGED FROM INFORMATIVE]
16:56:55	Unit AUCK207 [ K10 : RECOMMISSIONING]
16:57:43	Unit AUCKCITY1 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]
16:59:13	Unit REMU211 [ KC : UNIT CALLING]
16:59:28	Unit REMU211 [ K10 : RECOMMISSIONING]
17:01:25	Unit AUCKOSU4 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]
17:01:39	Unit AUCKOSU2 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]
17:16:47	Unit FIAKCITY4 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]
17:18:34	Unit FENORTH4 [ K6 : ON TELEPAGER]
17:36:00	Unit AUCKCITY4 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]
17:36:39	UNIT FENORTH4 RESPONSE TIME [NULL] ADJUSTED TO
17:36:49	** Assigned Result Code: STRU, Detailed Event Type: 1100, Qualifier 1: Q1,
17:36:49	UNIT AUCKCITY1 ALERT TIME [NULL] ADJUSTED TO
17:36:49	Qualifier 2:
17:36:50	UNIT AUCKOSU2 ALERT TIME [NULL] ADJUSTED TO
17:36:50	UNIT WAITEMATA3 ALERT TIME [NULL] ADJUSTED TO
17:36:50	UNIT AUCKCITY4 ALERT TIME [NULL] ADJUSTED TO
17:36:50	UNIT AUCKOSU1 ALERT TIME [NULL] ADJUSTED TO

**Incident**

<b>CAD Number</b>	F2309442
<b>Incident Reporter</b>	Rochelle Martin
<b>Incident Controller</b>	Rochelle Martin
<b>Distance Travelled (km)</b>	
<b>Delay In Receiving Call</b>	

**Property Details**

<b>Occupant</b>	Under renovation
<b>Building Owner</b>	Owner occupied
<b>General Property Use</b>	Construction, Renovation, Demolition site
<b>Special Property Use</b>	Building under renovation
<b>Purpose Group</b>	

**Actions**

<b>Persons Reported Trapped</b>	No
<b>Evacuation Status</b>	Evacuation in progress
<b>Action Prior 1</b>	Portable extinguisher (all types)
<b>Action Prior 2</b>	Portable extinguisher (all types)



Action Taken Extinguishment only: Includes isolating fuel/power supply

**Civilians**

Civilians Rescued	0
Civilians Extricated	0
Civilians Assisted	0
Civilians Evacuated	

**Origin**

Location Machinery room/area, Engine room, Refrigeration room, Pump room, Lift motor room  
 Level Above the 15th floor

**Equipment Used**

Quantity	Equipment
1	Low pressure delivery

**Equipment Involved**

Equipment Involved

Year

Make

Model

**Fire**

Arrival Condition Small fire  
 Heat Source Gas or liquid powered cutting torch: Spark, Ember, Flame  
 Termination Stage Flame  
 First Object Ignited Multiple items  
 First Object Material Multiple materials first ignited  
 Second Object Ignited Multiple items  
 Second Object Material Multiple materials first ignited  
 Indicated Cause Carelessness with heat source - not classified above  
 Certainty of Cause High  
 Age of Person Persons: 17 - 64 yrs  
 Ethnicity European/Pakeha  
 Gender Male  
 FAIP Service Offered No

FAIP Service Accepted No

**Comments**

5/25/2017 12:47:52 PM

Reporter Comments

Demolition contractor using a gas axe cut into large metal box (3X2m) on top of roof adjacent to the plant/lift room.  
There was multiple unknown items of debris, rubbish in the structure being cut - when a cut of approximately 10cm had been made there was an explosion and as a result the items inside the box ignited and continued to burn from 1503hrs approximately until 1604hrs.  
This time frame was due to an inactive riser main. Method of delivery was from ground level up through internal stairway to roof - 10 lengths.

**Rochelle Martin**

Released under the Official Information Act