

SMS Incident Report

12/06/2017 15:01:02


Summary

CAD Number F2314524 **Status** Closed
Station Auckland City Station
Incident Started 26/05/2017 11:08:53 **Incident Ended** 26/05/2017 18:07:12
Incident Type 1102: Structure fire with no damage
Common Name CLEARPOINT HOUSE
Address 7 FANSHAWE STREET AUCKLAND CENTRAL
Alarm Method Automatic PFA Call **Alarm Level** 3
PFA Number 111001
Zone 142006
Map Grid E 1756956 **Map Grid N** 5920847
First Caller **First Caller Contact**
Incident Closed 26/05/2017 18:07:12
Report Completed 11:1, Mon 12 Jun 2017 by Rochelle Martin

Responses

Call Sign	Type	Station Alert	Enroute Time	Arrival Time	Departed
AUCK207	PR	11:09:21 26 May 2017	11:11:00 26 May 2017	11:12:50 26 May 2017	14:55:31 26 May 2017
AUCK205	HPNP	11:09:28 26 May 2017	11:10:52 26 May 2017	11:14:27 26 May 2017	13:40:32 26 May 2017
PARN251	P1	11:09:28 26 May 2017	11:11:12 26 May 2017	11:15:30 26 May 2017	14:46:03 26 May 2017
AUCK2018	CUHU	11:14:23 26 May 2017	11:15:40 26 May 2017	11:19:52 26 May 2017	15:00:16 26 May 2017
PARN255	HPNP	11:14:11 26 May 2017	11:14:30 26 May 2017	11:20:12 26 May 2017	13:57:41 26 May 2017
BALM611	P1	11:09:24 26 May 2017	11:10:24 26 May 2017	11:20:35 26 May 2017	14:06:40 26 May 2017
REMU211	P1	11:14:15 26 May 2017	11:15:21 26 May 2017	11:21:04 26 May 2017	14:45:00 26 May 2017
AUCKCITY4	OF	11:18:24 26 May 2017	11:18:25 26 May 2017	11:22:07 26 May 2017	16:33:53 26 May 2017
ALBA851	P1	11:16:07 26 May 2017	11:19:49 26 May 2017	11:28:06 26 May 2017	11:39:57 26 May 2017
AUCKOSU1	SV	11:19:17 26 May 2017	11:20:00 26 May 2017	11:39:24 26 May 2017	15:19:43 26 May 2017
AUCKCITY1	OF	11:18:21 26 May 2017	11:18:21 26 May 2017	11:41:34 26 May 2017	14:13:50 26 May 2017
TAKA807	PR	11:20:34 26 May 2017	11:22:19 26 May 2017	11:55:31 26 May 2017	14:34:21 26 May 2017
HEND657	PR	11:15:56 26 May 2017	11:17:50 26 May 2017	11:56:21 26 May 2017	14:25:33 26 May 2017
GREY261	P1	11:55:42 26 May 2017	11:55:43 26 May 2017	12:00:15 26 May 2017	13:31:07 26 May 2017
TEAT664	PM	11:15:56 26 May 2017	11:17:46 26 May 2017	12:01:54 26 May 2017	16:31:45 26 May 2017
DEVO811	P1	11:53:52 26 May 2017	11:53:52 26 May 2017	12:04:03 26 May 2017	14:47:20 26 May 2017

AVON607	PR	11:15:53 26 May 2017	11:18:46 26 May 2017	12:07:05 26 May 2017	14:36:39 26 May 2017
AVON6015	BA	11:16:03 26 May 2017	11:22:08 26 May 2017	12:07:34 26 May 2017	14:20:05 26 May 2017
FIACITY4	FSO	11:57:17 26 May 2017	12:03:10 26 May 2017	12:11:35 26 May 2017	18:04:11 26 May 2017
PAPA344	PM	11:16:00 26 May 2017	11:18:13 26 May 2017	12:12:40 26 May 2017	12:30:07 26 May 2017
MTRO621	P1	11:14:19 26 May 2017	11:17:08 26 May 2017	12:33:33 26 May 2017	14:29:30 26 May 2017
AUCKCITY2	OF	11:15:01 26 May 2017	11:15:37 26 May 2017	12:33:56 26 May 2017	13:42:24 26 May 2017
AUCKOSU4	CV	11:15:56 26 May 2017	12:26:31 26 May 2017	12:45:16 26 May 2017	15:16:47 26 May 2017
COUNTIES4	OF	12:00:42 26 May 2017	12:01:07 26 May 2017	13:53:04 26 May 2017	15:04:56 26 May 2017



Elapsed Times

Call Sign	Start To Alert	Alert To Arrival	Start To Arrival	Start To Departed
AUCK207	00:00:28	00:03:29	00:03:57	03:46:38
AUCK205	00:00:35	00:04:59	00:05:34	02:31:39
PARN251	00:00:35	00:06:02	00:06:37	03:37:10
AUCK2018	00:05:30	00:05:29	00:10:59	03:51:23
PARN255	00:05:18	00:06:01	00:11:19	02:48:48
BALM611	00:00:31	00:11:11	00:11:42	02:57:47
REMU211	00:05:22	00:06:49	00:12:11	03:36:07
AUCKCITY4	00:09:31	00:03:43	00:13:14	05:25:00
ALBA851	00:07:14	00:11:59	00:19:13	00:31:04
AUCKOSU1	00:10:24	00:20:07	00:30:31	04:10:50
AUCKCITY1	00:09:28	00:23:13	00:32:41	03:04:57
TAKA807	00:11:41	00:34:57	00:46:38	03:25:28
HEND657	00:07:03	00:40:25	00:47:28	03:16:40
GREY261	00:46:49	00:04:33	00:51:22	02:22:14
TEAT664	00:07:03	00:45:58	00:53:01	05:22:52
DEVO811	00:44:59	00:10:11	00:55:10	03:38:27
AVON607	00:07:00	00:51:12	00:58:12	03:27:46
AVON6015	00:07:10	00:51:31	00:58:41	03:11:12
FIACITY4	00:48:24	00:14:18	01:02:42	06:55:18
PAPA344	00:07:07	00:56:40	01:03:47	01:21:14
MTRO621	00:05:26	01:19:14	01:24:40	03:20:37
AUCKCITY2	00:06:08	01:18:55	01:25:03	02:33:31
AUCKOSU4	00:07:03	01:29:20	01:36:23	04:07:54

Caution: The information contained in this report is subject to the provisions of the Official Information Act 1982 and the Privacy Act 1993. Neither the information nor the report should be released to any person outside the NZ Fire Service or the National Rural Fire Authority without prior approval

COUNTIES4	00:51:49	01:52:22	02:44:11	03:56:03
-----------	----------	----------	----------	----------

Notifications

Date	Time	Party Notified
26 May 2017	11:15:07	VECTOR
26 May 2017	11:15:16	VECTOR 2ND ALARM BUILDING FIRE
26 May 2017	11:15:17	AAC WOON PER PHONE - RESPONDING..
26 May 2017	11:16:49	AUCKLAND CITY AREA 3RD ALARM PER PAGER..
26 May 2017	11:17:05	VECTOR 3RD ALARM
26 May 2017	11:18:39	AAC CALLISTER ACK PAGER - RESPONDING..
26 May 2017	11:19:05	AC TWOMEY PER PHONE - RESPONDING
26 May 2017	11:22:10	AC PURCELL / AAC DELFOS PER PHONE - MONITORING..
26 May 2017	11:23:35	AC TRAVERS RE-3RD ALARM..
26 May 2017	11:25:47	AC TRAVERS ACK PAGER..
26 May 2017	11:34:16	AUCKOSU4 PER PAGER - K28..
26 May 2017	11:41:47	AAC MACKERETH UPDATES PASSED
26 May 2017	11:55:58	GREATER ALARM ATTENDANCE SHEET SENT @ 1155
26 May 2017	12:00:37	COUNTIES 4ACK PAGE- ENROUTE
26 May 2017	12:02:34	AC TWOMEY - ACK PAGE - ATTACH ME TO CALL
26 May 2017	12:14:26	ANC COCKER PER PHONE - REQUEST FULL SITREP..
26 May 2017	12:24:45	BIRK821 AT TAKAPUNA STATION
26 May 2017	12:27:45	██████████ - REQUEST BIRK822 K25 TO BIRKENHEAD - HAVE A CREW AVAIL
26 May 2017	13:07:33	HAVE CALLED COUNCIL 4 TIMES AND PHONE GOES ON HOLD, THEN RINGS ONCE AND
26 May 2017	13:09:35	ON HOLD WITH COUNCIL
26 May 2017	13:20:09	VIA PHONE ██████████ WHO IS A COUNCIL ENVIRONMENTAL REP WILL CALL IN
26 May 2017	13:22:55	VIA PHONE FROM ██████████ CALLED WILL TRY TO PUT HIM THROUGH TO THE
26 May 2017	13:23:58	VIA PHONE THEY HAVE DARY THOMPSON ON SCENE
26 May 2017	13:52:17	VIA PHONE FROM RICHARD TWOOMEY: FOR MEDIA: THERE HAS BEEN A FIRE ON THE 4TH
26 May 2017	13:53:16	AUCKLAND REGIONAL PUBLIC HEALTH REP - ██████████ OR ██████████
26 May 2017	15:02:19	VECTOR - WILL CALL BACK WITH AN ETA
26 May 2017	15:17:50	VECTOR ADV THEY WILL CONTACT THEIR CONTRACTOR TO ATTEND
26 May 2017	15:31:03	SUSPICIOUS
26 May 2017	16:29:55	VECTOR ETA - CONTRACTORS ON DOMINION ROAD. TRAFFIC IS BAD DUE TO RUGBY GAMES
26 May 2017	16:40:33	FIACITY4 ADHOC PAGE RE VECTOR ETA AND WELFARE CHEK
26 May 2017	16:42:34	FIACITY4 - ALL OK NO FURTHER CHECKS REQUIRED

Message Log

Time	Message
11:08:54	AL: 111001 11:08:53 INITIAL - AL
11:08:54	PANEL: FOYER
11:08:55	** LOI search completed at 26/05/17 11:08:55
11:09:04	** Recommended unit AUCK205 for requirement AERIAL (>1.3 km)
11:09:04	** Recommended unit AUCK207 for requirement PUMP (>1.3 km)
11:09:04	** Recommended unit PARN251 for requirement PUMP (>1.3 km)
11:09:04	** Recommended unit BALM611 for requirement PUMP (>4.7 km)
11:10:05	Duplicate Event:Location = 7 FANSHAWE ST,AUCKLAND CENTRAL,AUCKLAND: @CLEARPOINT
11:10:05	HOUSE, Type = STRU - STRUCTURE FIRE, Caller Ph Number = [REDACTED], Call Source
11:10:05	= 111Inc InfoFIRE FROM ROOF, Event Source = Fire 111
11:10:06	INC INFO: FIRE FROM ROOF
11:10:06	End of Duplicate Event data
11:10:25	Unit BALM611 [K1 : PROCEEDING TO INCIDENT]
11:10:49	Duplicate Event:Location = 7 FANSHAWE ST,AUCKLAND CENTRAL,AUCKLAND: @CLEARPOINT
11:10:49	HOUSE, Type = STRU - STRUCTURE FIRE, Caller Name = GOODMAN FIELDER NZ LTD,
11:10:49	Caller Ph Number = [REDACTED], Caller Address = TELECOM CELLULAR 027, KAIPARA
11:10:49	FLATS, AUCKLAND CITY, Call Source = 111Inc InfoROOF FIRE, Event Source = Fire
11:10:49	111
11:10:50	INC INFO: ROOF FIRE
11:10:50	End of Duplicate Event data
11:10:53	Unit AUCK205 [K1 : PROCEEDING TO INCIDENT]
11:10:58	Duplicate Event:Location = 7 FANSHAWE ST,AUCKLAND CENTRAL,AUCKLAND: @CLEARPOINT
11:10:58	INC INFO:
11:10:58	HOUSE, Caller Ph Number = [REDACTED], Call Source = 111, Event Source = Fire 111
11:10:59	End of Duplicate Event data
11:11:01	Duplicate Event:Location = 7 FANSHAWE ST,AUCKLAND CENTRAL,AUCKLAND: @CLEARPOINT
11:11:01	Unit AUCK207 [K1 : PROCEEDING TO INCIDENT]
11:11:01	HOUSE, Type = STRU - STRUCTURE FIRE, Caller Name = GOODMAN FIELDER NZ
11:11:01	LTD-BAKINGDIVISION, Caller Ph Number = [REDACTED], Caller Address = [REDACTED]
11:11:01	STREET, AUCKLAND CENTRAL, AUCKLAND CITY, Call Source = 111Inc InfoSMOKE SHOWING
11:11:01	FROM BLDG, Event Source = Fire 111
11:11:02	INC INFO: SMOKE SHOWING FROM BLDG
11:11:02	End of Duplicate Event data
11:11:05	##
11:11:12	Unit PARN251 [K1 : PROCEEDING TO INCIDENT]
11:11:16	CALLER FROM BLDG OPPOSITE SAYS SMOKE SHOWING FROM THIS BLDG
11:11:17	##
11:11:18	INC INFO: SMOKE SHOWING FROM BALCONY OF 5TH FLOOR

11:11:18 Duplicate Event:Location = LVL 6\7 FANSHAWE ST,AUCKLAND CENTRAL,AUCKLAND, Type =
11:11:18 STRU - STRUCTURE FIRE, Caller Name = IAG NZ LTD, Caller Ph Number = [REDACTED],
11:11:18 Caller Address = [REDACTED] FANSHAWE STREET, AUCKLAND CENTRAL, AUCKLAND CITY, Call Source
11:11:18 = 111Inc InfoSMOKE SHOWING FROM BALCONY OF 5TH FLOOR, Event Source = Fire 111
11:11:18 End of Duplicate Event data
11:11:19 Duplicate Event:Location = 7 FANSHAWE ST,AUCKLAND CENTRAL,AUCKLAND: @CLEARPOINT
11:11:19 INC INFO: ROOF FIRE
11:11:19 HOUSE, Type = STRU - STRUCTURE FIRE, Caller Ph Number = [REDACTED], Call Source
11:11:19 = 111Inc InfoROOF FIRE, Event Source = Fire 111
11:11:19 End of Duplicate Event data
11:11:21 Unit PARN251 [K1 : PROCEEDING TO INCIDENT]
11:11:29 Duplicate Event:Location = FANSHAWE ST,AUCKLAND CENTRAL,AUCKLAND, Caller Ph
11:11:29 INC INFO:
11:11:29 Number = [REDACTED], Call Source = 111, Event Source = Fire 111
11:11:30 End of Duplicate Event data
11:11:53 INC INFO: FIRE ON THE ROOF
11:11:53 Duplicate Event:Location = 7 FANSHAWE ST,AUCKLAND CENTRAL,AUCKLAND: @CLEARPOINT
11:11:53 HOUSE, Type = STRU - STRUCTURE FIRE, Caller Ph Number = [REDACTED], Call Source
11:11:53 = 111Inc InfoFIRE ON THE ROOF, Event Source = Fire 111
11:11:54 End of Duplicate Event data
11:11:57 Duplicate Event:Location = LVL 6\7 FANSHAWE ST,AUCKLAND CENTRAL,AUCKLAND, Type =
11:11:57 INC INFO: BUILDING FIRE
11:11:57 STRU - STRUCTURE FIRE, Caller Ph Number = [REDACTED], Call Source = 111Inc
11:11:57 InfoBUILDING FIRE , Event Source = Fire 111
11:11:57 End of Duplicate Event data
11:12:12 Duplicate Event:Location = FANSHAWE ST,AUCKLAND CENTRAL,AUCKLAND, Caller Name =
11:12:12 WORK COMMUNICATIONS LIMITED, Caller Ph Number = [REDACTED], Caller Address =
11:12:12 TELECOM CELLULAR 027, OAMARU, WAITAKI DISTRICT, Call Source = 111, Event Source
11:12:12 = Fire 111
11:12:13 INC INFO:
11:12:13 End of Duplicate Event data
11:12:21 Unit AUCK207 [COMCEN COM : MESSAGE] MULTIPLE CALLS FIRE SHOWING FROM ROOF -
11:12:21 HYDRANT INFO PASSED
11:12:23 Duplicate Event:Location = 7 FANSHAWE ST,AUCKLAND CENTRAL,AUCKLAND: @CLEARPOINT
11:12:23 HOUSE, Type = STRU - STRUCTURE FIRE, Caller Ph Number = [REDACTED], Call Source
11:12:23 = 111Inc InfoFIRE ON THE ROOF , Event Source = Fire 111
11:12:24 INC INFO: FIRE ON THE ROOF
11:12:24 End of Duplicate Event data
11:12:33 Duplicate Event:Location = 7 FANSHAWE ST,AUCKLAND CENTRAL,AUCKLAND: @CLEARPOINT
11:12:33 INC INFO: FIRE ON ROOF OF BUILDING

11:12:33 HOUSE, Type = STRU - STRUCTURE FIRE, Caller Name = OCG CONSULTING LTD, Caller Ph
11:12:33 Number = [REDACTED], Caller Address = 76 LNP FICT,, Call Source = 111Inc
11:12:33 InfoFIRE ON ROOF OF BUILDING, Event Source = Fire 111
11:12:33 End of Duplicate Event data
11:12:50 Unit AUCK207 [K88 : PROPERTY SMALL]
11:12:56 THERE IS ASBESTOS REMOVAL WORK ON 4TH FLOOR AT PRESENT
11:12:56 Duplicate Event:Location = 7 FANSHAWE ST,AUCKLAND CENTRAL,AUCKLAND: @CLEARPOINT
11:12:56 PETER
11:12:56 HOUSE, Type = STRU - STRUCTURE FIRE, Caller Name = PACIFIC DECONTAMINATION
11:12:56 SERVICES LIMITED, Caller Ph Number = [REDACTED], Caller Address = TELECOM
11:12:56 INC INFO: FIRE IN BUILDING
11:12:56 CELLULAR 027,, Call Source = 111Inc InfoFIRE IN BUILDING, Event Source = Fire
11:12:56 111
11:12:56 End of Duplicate Event data
11:13:31 Unit AUCK207 [SITREP :] TX 2ND ALARM
11:13:46 INC INFO: BUILDING FIRE 2ND ALARM TX
11:13:58 ** Alarm level updated to 2
11:13:58 ** Recommended unit PARN255 for requirement AERIAL (>2.2 km)
11:13:58 ** Recommended unit AUCK2018 for requirement COMU (>1.2 km)
11:13:58 ** Recommended unit REMU211 for requirement PUMP (>4.3 km)
11:13:58 ** Recommended unit MTRO621 for requirement PUMP (>6.8 km)
11:14:06 Unit AUCK207 [KP : PRIORITY MESSAGE]
11:14:06 AMBO EVENT 0363-1-2017/05/26-FIR LINKED AT 26/05/2017 11:14:06
11:14:12 FIR2POL 2ND ALARM BUILDING FIRE
11:14:17 FIR2AMB 2ND ALARM BUILDING FIRE
11:14:24 RRRR
11:14:27 Unit AUCK205 [K2 : IN ATTENDANCE AT INCIDENT]
11:14:30 Unit PARN255 [K1 : PROCEEDING TO INCIDENT]
11:14:49 Location = 7 Fanshawe St,AUCKLAND CENTRAL,:@CLEARPOINT HOUSE: #111001
11:14:49 AMBO update to 0363-1-2017/05/26-FIR:
11:14:49 Caller Name = , Caller Phone = UNKNOWN, Headline = BUILDING FIRE 2ND ALARM TX
11:14:49 @CLEARPOINT HOUSE: #111001
11:14:53 Problem changed to: NOTIFICATION - Fire Event
11:14:54 Caller Name = ., Caller Phone = UNKNOWN, Headline = BUILDING FIRE 2ND ALARM TX
11:15:21 Unit REMU211 [K1 : PROCEEDING TO INCIDENT]
11:15:31 Unit PARN251 [K2 : IN ATTENDANCE AT INCIDENT]
11:15:34 Unit AUCK207 [SITREP :] SSO MARTIN TX 3RD ALARM
11:15:37 Unit AUCKCITY2 [K1 : PROCEEDING TO INCIDENT]
11:15:40 ** Alarm level updated to 3
11:15:40 ** Recommended unit TEAT664 for requirement AERIAL (>9.9 km)

11:15:40	** Recommended unit PAPA344 for requirement AERIAL (>18.6 km)
11:15:40	** Recommended unit AVON6015 for requirement BAT (>7.8 km)
11:15:40	** Recommended unit AUCKOSU4 for requirement CANT (>12.6 km)
11:15:40	** Recommended unit AVON607 for requirement PUMP (>9.8 km)
11:15:40	** Recommended unit ALBA851 for requirement PUMP (>7.7 km)
11:15:40	** Recommended unit HEND657 for requirement PUMP (>9.9 km)
11:15:41	Unit AUCK2018 [K1 : PROCEEDING TO INCIDENT]
11:15:44	Unit PARN251 [K2 : IN ATTENDANCE AT INCIDENT]
11:17:09	Unit MTRO621 [K1 : PROCEEDING TO INCIDENT]
11:17:47	Unit TEAT664 [K1 : PROCEEDING TO INCIDENT]
11:17:51	Unit HEND657 [K1 : PROCEEDING TO INCIDENT]
11:17:51	FIR2POL YOUR ATTENDANCE REQUIRED FOR 3RD ALARM FIRE
11:18:04	FIR2AMB YOUR ATTENDANCE REQUIRED FOR 3RD ALARM STRUCTURE FIRE
11:18:10	Unit REMU211 [K1 : PROCEEDING TO INCIDENT]
11:18:13	Unit PAPA344 [K1 : PROCEEDING TO INCIDENT]
11:18:20	Unit REMU211 [K1 : PROCEEDING TO INCIDENT]
11:18:21	Unit AUCKCITY1 [K1 : PROCEEDING TO INCIDENT]
11:18:25	Unit AUCKCITY4 [K1 : PROCEEDING TO INCIDENT]
11:18:25	Unit HEND657 [K1 : PROCEEDING TO INCIDENT]
11:18:31	[FIR] amb copies thanks
11:18:32	Unit HEND657 [K1 : PROCEEDING TO INCIDENT]
11:18:34	AMBO update to 0363-1-2017/05/26-FIR:
11:18:34	Location = 7 Fanshawe St,AUCKLAND CENTRAL,;@CLEARPOINT HOUSE: #111001
11:18:35	Caller Name = ., Caller Phone = UNKNOWN, Headline = BUILDING FIRE 2ND ALARM TX
11:18:39	Unit HEND657 [K1 : PROCEEDING TO INCIDENT]
11:18:41	Problem changed to: RED - Fire Event
11:18:46	Unit AVON607 [K1 : PROCEEDING TO INCIDENT]
11:18:56	AMBO update to 0363-1-2017/05/26-FIR:
11:18:57	Location = 7 Fanshawe St,AUCKLAND CENTRAL,;@CLEARPOINT HOUSE: #111001
11:18:57	Caller Name = ., Caller Phone = UNKNOWN, Headline = BUILDING FIRE 2ND ALARM TX
11:19:02	Problem changed to: RED - Carbon Monoxide/Inhalation/HAZMAT/CBRN
11:19:11	Unit AVON607 [K1 : PROCEEDING TO INCIDENT]
11:19:14	** Event Type changed from FIR2POL to 1F(2) at: 26/05/17 11:19:14
11:19:16	** Requirement PUMP added for alarm level 3
11:19:17	AL: PAGING ACK TIMED OUT FOR STATION: 1466 at 26/05/17 11:19:17
11:19:24	** Recommended unit TAKA807 for requirement ADHOC PUMP (>7.7 km)
11:19:50	Unit ALBA851 [K1 : PROCEEDING TO INCIDENT]
11:19:53	Unit AUCK2018 [K2 : IN ATTENDANCE AT INCIDENT]
11:20:01	Unit AUCKOSU1 [K1 : PROCEEDING TO INCIDENT]
11:20:09	Unit AUCKOSU1 [K1 : PROCEEDING TO INCIDENT]

11:20:12	Unit PARN255 [K2 : IN ATTENDANCE AT INCIDENT]
11:20:13	INC INFO: SMOKE SHOWING
11:20:13	Duplicate Event:Location = 7 FANSHAWE ST,AUCKLAND CENTRAL,AUCKLAND: @CLEARPOINT
11:20:13	HOUSE, Type = STRU - STRUCTURE FIRE, Caller Name = [REDACTED], Caller Ph
11:20:13	Number = [REDACTED], Caller Address = TELECOM CELLULAR 027, BLENHEIM,
11:20:13	MARLBOROUGH DISTRICT, Call Source = 111Inc InfoSMOKE SHOWING , Event Source =
11:20:13	Fire 111
11:20:13	End of Duplicate Event data
11:20:36	Unit BALM611 [K2 : IN ATTENDANCE AT INCIDENT]
11:20:41	Unit BALM611 [K2 : IN ATTENDANCE AT INCIDENT]
11:20:49	1120 NCA3 AWARE MONITORING
11:20:56	Unit BALM611 [K2 : IN ATTENDANCE AT INCIDENT]
11:21:09	Unit REMU211 [K2 : IN ATTENDANCE AT INCIDENT]
11:21:12	Unit BALM611 [K2 : IN ATTENDANCE AT INCIDENT]
11:21:13	Unit BALM611 [K2 : IN ATTENDANCE AT INCIDENT]
11:21:16	Unit BALM611 [K2 : IN ATTENDANCE AT INCIDENT]
11:21:20	Unit BALM611 [K2 : IN ATTENDANCE AT INCIDENT]
11:21:26	Unit BALM611 [K2 : IN ATTENDANCE AT INCIDENT]
11:21:50	SPEAKING TO MEMBER OF PUBLIC IT IS ON LEVEL 4
11:21:57	ASBESTOS REMOVAL FROM THAT AREA
11:22:08	Unit AVON6015 [K1 : PROCEEDING TO INCIDENT]
11:22:08	Unit AUUCKCITY4 [K2 : IN ATTENDANCE AT INCIDENT]
11:22:20	Unit TAKA807 [K1 : PROCEEDING TO INCIDENT]
11:22:54	INC INFO: BUILDING FIRE 3RD ALARM TX
11:27:23	Unit AUUCK207 [KC : UNIT CALLING]
11:28:05	Unit AUUCK207 [SITREP :] SSO MARTIN CANCEL 3RD ALARM APPLIANCES
11:28:06	Unit ALBA851 [K2 : IN ATTENDANCE AT INCIDENT]
11:28:56	Unit AVON6015 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
11:29:02	Unit AVON607 [K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]
11:29:07	Unit TEAT664 [K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]
11:29:23	Unit PAPA344 [K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]
11:29:23	Unit HEND657 [K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]
11:31:18	Unit TAKA807 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
11:31:30	COVERING UNIT TAKA807 DISPATCHED TO STATION AUCKLAND
11:31:30	TERMINAL: D0710063
11:32:42	Unit AUUCK2018 [KC : UNIT CALLING]
11:33:25	Unit AUUCK2018 [K44 : COMMAND OR CONTROL POINT ESTABLISHED - OIC AND LOCATION]
11:33:25	FANSHAWE COMMAND AAC WOON
11:33:33	Unit AUUCK2018 [K45 : COMMAND RESPONSIBILITY CHANGED TO - NAME] AAC WOON
11:33:42	Unit AUUCK2018 [KC : UNIT CALLING]

11:36:50 ONE ON 4TH ONE ON 6TH FLOOR IS 1C
11:36:53 CRIME 10-2
11:37:24 Unit AUCK207 [COMCEN COM : MESSAGE] PASSED DETAILS OF ASBOSTOS REMOVAL PRIOR TO
11:37:24 SECOND ALARM TX
11:39:09 Unit AUCKOSU4 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
11:39:25 Unit AUCKOSU1 [K2 : IN ATTENDANCE AT INCIDENT]
11:39:58 Unit ALBA851 [K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]
11:41:25 Unit AUCKCITY1 [K1 : PROCEEDING TO INCIDENT]
11:41:34 Unit AUCKCITY1 [K2 : IN ATTENDANCE AT INCIDENT]
11:41:44 Unit AUCKCITY1 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
11:46:38 Unit AUCKOSU1 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
11:49:11 Unit AUCK2018 [COMCEN COM : MESSAGE] PASS YOUR SITREP
11:49:33 Unit AUCK2018 [SITREP :] STAND BY
11:50:38 Unit AUCK2018 [KP : PRIORITY MESSAGE]
11:51:33 Unit AUCK2018 [SITREP :] SMOKE LOGGING FURTHER FIRE SEATS FOUND ON LEVELS 4
11:51:33 AND 6 RE TX 3RD ALARM
11:52:18 ** Requirement PUMP added for alarm level 3
11:52:27 ** Recommended unit TEAT664 for requirement AERIAL (>7.1 km)
11:52:27 ** Recommended unit PAPA344 for requirement AERIAL (>18.8 km)
11:52:27 ** Recommended unit AVON6015 for requirement BAT (>7.8 km)
11:52:27 ** Recommended unit AUCKOSU4 for requirement CANT (>12.6 km)
11:52:27 ** Recommended unit TAKA807 for requirement PUMP (>1.2 km)
11:52:27 ** Recommended unit GREY261 for requirement PUMP (>2.9 km)
11:52:27 ** Recommended unit HEND657 for requirement PUMP (>3.5 km)
11:52:27 ** Recommended unit AVON607 for requirement ADHOC PUMP (>9.6 km)
11:52:27 ** Recommended unit DEVO811 for requirement ADHOC PUMP (>8.2 km)
11:52:36 Unit TAKA807 [K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]
11:53:13 Unit AUCK2018 [KC : UNIT CALLING]
11:53:21 Unit AUCK2018 [KC : UNIT CALLING]
11:53:53 Unit DEVO811 [K1 : PROCEEDING TO INCIDENT]
11:53:57 Unit PAPA344 [K1 : PROCEEDING TO INCIDENT]
11:54:03 Unit PAPA344 [K1 : PROCEEDING TO INCIDENT]
11:54:07 Unit DEVO811 [K1 : PROCEEDING TO INCIDENT]
11:54:11 Unit HEND657 [K1 : PROCEEDING TO INCIDENT]
11:54:12 Unit PAPA344 [K1 : PROCEEDING TO INCIDENT]
11:54:19 Unit PAPA344 [K1 : PROCEEDING TO INCIDENT]
11:54:20 Unit HEND657 [K1 : PROCEEDING TO INCIDENT]
11:54:28 Unit TAKA807 [K1 : PROCEEDING TO INCIDENT]
11:55:28 Unit AVON607 [K1 : PROCEEDING TO INCIDENT]

11:55:32 Unit TAKA807 [K2 : IN ATTENDANCE AT INCIDENT]
11:55:43 Unit GREY261 [K1 : PROCEEDING TO INCIDENT]
11:56:00 Unit AVON6015 [K1 : PROCEEDING TO INCIDENT]
11:56:06 Unit AUCK2018 [SITREP :] DO YOU HAVE A LIST OF APPLIANCES ATTENDING THIS
11:56:06 AL: PAGING ACK TIMED OUT FOR STATION: 1466 at 26/05/17 11:56:06
11:56:06 INCIDENT?
11:56:21 Unit AUCK2018 [COMCEN COM : MESSAGE] WILL SEND IT SHORTLY
11:56:22 Unit HEND657 [K2 : IN ATTENDANCE AT INCIDENT]
11:56:26 Unit AUCK2018 [COMCEN COM : MESSAGE] GREATER ALARM ATTENDANCE SHEET SENT @
1155
11:56:26 (PHONE)
11:56:29 Unit HEND657 [K2 : IN ATTENDANCE AT INCIDENT]
11:56:51 INC INFO: BUILDING FIRE 3RD ALARM TOC: 1108 TOA: 1112
11:56:51 Unit DEVO811 [K1 : PROCEEDING TO INCIDENT]
11:57:36 FIR2POL - 3RD ALARM HAS BEEN RETRANSMITTED
11:57:42 FIR2AMB - 3RD ALARM HAS BEEN RETRANSMITTED
11:57:50 AMBO EVENT 0420-1-2017/05/26-FIR LINKED AT 26/05/2017 11:57:50
11:58:12 Unit HEND657 [K2 : IN ATTENDANCE AT INCIDENT]
11:59:25 Unit AUCK2018 [KC : UNIT CALLING]
12:00:16 Unit AUCK2018 [SITREP :] PLEASE ADVISE 3RD ALARM APPLIANCES TO RPEORYT TO
12:00:16 Unit GREY261 [K2 : IN ATTENDANCE AT INCIDENT]
12:00:16 INCIDENT CONTROL POINT WITH BA
12:00:21 Unit GREY261 [K2 : IN ATTENDANCE AT INCIDENT]
12:01:07 Unit COUNTIES4 [K1 : PROCEEDING TO INCIDENT]
12:01:33 Unit TEAT664 [KC : UNIT CALLING]
12:01:36 Unit TEAT664 [K1 : PROCEEDING TO INCIDENT]
12:01:55 Unit TEAT664 [K2 : IN ATTENDANCE AT INCIDENT]
12:02:04 Unit COUNTIES4 [K1 : PROCEEDING TO INCIDENT]
12:03:11 Unit FIAKCITY4 [K1 : PROCEEDING TO INCIDENT]
12:04:03 Unit DEVO811 [K2 : IN ATTENDANCE AT INCIDENT]
12:05:01 Unit AUCKCITY1 [K2 : IN ATTENDANCE AT INCIDENT]
12:07:06 Unit AVON607 [K2 : IN ATTENDANCE AT INCIDENT]
12:07:35 Unit AVON6015 [K2 : IN ATTENDANCE AT INCIDENT]
12:09:20 Unit AUCKOSU1 [K38 : ASSOCIATE THIS UNIT TO EVENT - EVENT ADDRESS]
12:09:23 Unit AUCKOSU1 [K1 : PROCEEDING TO INCIDENT]
12:09:27 Unit AUCKOSU1 [K39 : RE-TRANSMIT YOUR CURRENT STATUS]
12:10:35 Unit AUCK2018 [KC : UNIT CALLING]
12:11:35 Unit FIAKCITY4 [K2 : IN ATTENDANCE AT INCIDENT]
12:11:59 Unit AUCK2018 [SITREP :] PRECEUATIONA DECON CARRIED OUT CAN YOU CONFIRM FIRE
12:11:59 INV RESPONDING AND ETA?

12:12:40 Unit PAPA344 [K2 : IN ATTENDANCE AT INCIDENT]

12:15:02 Unit AUCK2018 [KC : UNIT CALLING]

12:15:40 Unit AUCK2018 [COMCEN COM : MESSAGE] FROM ANC COCKER PASS FULL SITREP

12:15:53 Unit AUCK2018 [K45 : COMMAND RESPONSIBILITY CHANGED TO - NAME] AC TWOMEY

12:16:12 COVERING UNIT ELLE274 DISPATCHED TO STATION AUCKLAND

12:16:12 TERMINAL: D0710063

12:18:21 COVERING UNIT OTAH311 DISPATCHED TO STATION GREY LYNN

12:18:21 D0710063

12:26:14 Unit AUCK2018 [SITREP :] VIA PHONE, FI REQUEST INITIAL CALLER INFO, ADV PFA

12:26:14 AND GIVEN FIRST CELLPHONE NUMBER

12:26:32 Unit AUCKOSU4 [K1 : PROCEEDING TO INCIDENT]

12:26:41 COVERING UNIT BIRK822 DISPATCHED TO STATION BIRKENHEAD

12:26:41 D0710061

12:29:17 Unit AUCK2018 [KC : UNIT CALLING]

12:30:08 Unit PAPA344 [K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]

12:30:58 Unit AUCK2018 [SITREP :] AC TWOMEY OFFICE BUILDING 6 FLOOR 20M X 20M FIRE ON

12:30:58 LEVELS 4 5 AND 6 2LPDS PRECAUTIONARY DECON FOR ASBESTOS ON LEVELS 4 AND 5

12:30:58 AERIAL

12:30:58 FOR OBSERVATION. INTERIOR OFFENSIVE ATTACK

12:33:33 Unit MTRO621 [K2 : IN ATTENDANCE AT INCIDENT] ENTERED BY FCOM PER AVL

12:33:57 Unit AUCKCITY2 [K2 : IN ATTENDANCE AT INCIDENT] ENTERED BY FCOM PER FANSHAWE

12:33:57 COMMAND SITREP

12:45:17 Unit AUCKOSU4 [K2 : IN ATTENDANCE AT INCIDENT]

12:45:54 Unit AUCKOSU1 [K2 : IN ATTENDANCE AT INCIDENT]

12:46:05 COVERING UNIT PAPA344 DISPATCHED TO STATION OTAHUHU AT

12:46:05 D0710063

12:47:08 COVERING UNIT ONEH221 DISPATCHED TO STATION GREY LYNN

12:47:08 D0710063

12:53:03 COVERING UNIT OTAH311 DISPATCHED TO STATION MT ROSKILL

12:53:03 D0710063

13:02:14 Unit AUCK2018 [KC : UNIT CALLING]

13:02:51 Unit AUCK2018 [SITREP :] ETA REQUIRED FOR COUNCIL ENVIRONMNETAL OFFICER

13:04:56 Unit AUCKOSU1 [K2 : IN ATTENDANCE AT INCIDENT]

13:07:33 DISCONNECTS, TRYING DIFFERENT NUMBER.

13:22:55 COMMAND UNIT

13:27:51 Unit AUCK2018 [KC : UNIT CALLING]

13:28:17 Unit AUCK2018 [SITREP :] FIRE EXT. SLAVAGE AND DECON

13:31:08 Unit GREY261 [K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]

13:36:03 COVERING UNIT BIRK822 DISPATCHED TO STATION TAKAPUNA AT

13:36:03 D0710061

13:37:01	COVERING UNIT ONEH221 DISPATCHED TO STATION BALMORAL
13:37:01	D0710061
13:39:09	COVERING UNIT ONEH221 DISPATCHED TO STATION ALBANY AT
13:39:09	D0710061
13:39:52	COVERING UNIT SILV907 DISPATCHED TO STATION ALBANY AT
13:39:52	D0710061
13:40:33	Unit AUUCK205 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
13:41:19	COVERING UNIT ONEH221 DISPATCHED TO STATION HENDERSON
13:41:19	D0710061
13:42:25	Unit AUUCKCITY2 [K6 : ON TELEPAGER]
13:42:37	COVERING UNIT HOWI321 DISPATCHED TO STATION REMUERA AT
13:42:37	D0710061
13:45:17	COVERING UNIT HOWI321 DISPATCHED TO STATION BALMORAL
13:45:17	D0710061
13:49:54	COVERING UNIT PAPA387 DISPATCHED TO STATION OTAHUHU AT
13:49:54	D0710061
13:50:47	Incident Closed. Reason: 510 ACC Assess and Treat Only
13:50:48	** Cancel Event:Event Canceled by InterCAD
13:52:17	FLOOR THAT HAS SPREAD TO THE 6TH FLOOR, THE AREA WHERE THE FIRE WAS THERE WAS
13:52:17	ASPESTOS REMOVAL TAKING PLACE WHICH MEANS OUR STAFF HAVE BEEN ROTATED OUT OFTHE
13:52:17	BUILDING AND DECONTAMINATED. OUR INV ARE NOW DETERMINING WHAT STARTED THE FIRE,
13:52:17	ONCE OUR OPERATIONS ARE FINISHED HERE WE WILL HAND IT OVER TO AUCKLAND CITY
13:52:17	COUCIL, WE HAVE HAD 14 APPLIANCE AND ABOUT 60 PEOPLE ON SCENE
13:53:04	Unit COUNTIES4 [K2 : IN ATTENDANCE AT INCIDENT]
13:53:16	CALLED IN FOR INFO AND TO ADVS PUBLIC HEALTH WILL BE RESPOND AS REQUESTED BY
13:53:16	AUCKLAND COUNCIL [REDACTED] DUE TO ASBESTOS RISK.
13:57:42	Unit PARN255 [K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]
14:02:39	Unit BALM611 [K2 : IN ATTENDANCE AT INCIDENT]
14:02:44	Unit BALM611 [K2 : IN ATTENDANCE AT INCIDENT]
14:02:50	Unit BALM611 [K2 : IN ATTENDANCE AT INCIDENT]
14:02:56	Unit BALM611 [K2 : IN ATTENDANCE AT INCIDENT]
14:03:01	Unit BALM611 [K2 : IN ATTENDANCE AT INCIDENT]
14:04:30	Unit BALM611 [K2 : IN ATTENDANCE AT INCIDENT]
14:04:36	Unit BALM611 [K2 : IN ATTENDANCE AT INCIDENT]
14:05:40	Unit AUUCK2018 [KC : UNIT CALLING]
14:05:43	Unit BALM611 [KC : UNIT CALLING]
14:05:48	Unit BALM611 [KC : UNIT CALLING]
14:06:10	Unit BALM611 [KC : UNIT CALLING]

14:06:21	Unit AUCK2018 [K45 : COMMAND RESPONSIBILITY CHANGED TO - NAME] AAC CALLISTER
14:06:41	Unit BALM611 [K10 : RECOMMISSIONING]
14:13:51	Unit AUCKCITY1 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
14:20:07	Unit AVON6015 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
14:25:06	Unit HEND657 [KC : UNIT CALLING]
14:25:34	Unit HEND657 [K10 : RECOMMISSIONING]
14:29:15	Unit MTRO621 [K2 : IN ATTENDANCE AT INCIDENT]
14:29:31	Unit MTRO621 [K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]
14:33:28	Unit TEAT664 [KC : UNIT CALLING]
14:34:22	Unit TAKA807 [K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]
14:36:41	Unit AVON607 [K7 : AT NORMAL STATION]
14:38:25	Unit REMU211 [KC : UNIT CALLING]
14:40:40	Unit AUCK2018 [KC : UNIT CALLING]
14:42:16	Unit REMU211 [KC : UNIT CALLING]
14:44:45	Unit REMU211 [KC : UNIT CALLING]
14:45:02	Unit REMU211 [K10 : RECOMMISSIONING]
14:45:39	Unit PARN251 [KC : UNIT CALLING]
14:46:05	Unit PARN251 [K10 : RECOMMISSIONING]
14:47:21	Unit DEVO811 [K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]
14:54:32	Unit AUCK207 [KC : UNIT CALLING]
14:55:32	Unit AUCK207 [K10 : RECOMMISSIONING]
14:59:47	Unit AUCK2018 [SITREP :] PER PHONE: WATER DISCOVERED TO BE LEAKING INTO HIGH
14:59:47	VOLTAGE ROOM. ADVS VECTOR THEY WILL NEED TO ATTEND TO CHECK FOR SAFETY
14:59:47	QUOTE
14:59:47	C1315 (SWITCHROOM NUMBER)
15:00:17	Unit AUCK2018 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
15:02:26	Unit AUCK2018 [STOP : MESSAGE] AAC CALLISTER - SCENE HANDED OVER TO AUCKLAND
15:02:26	COUNCIL ENVIRONMENTAL SERVICES
15:04:57	Unit COUNTIES4 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
15:16:49	Unit AUCKOSU4 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
15:19:45	Unit AUCKOSU1 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
15:26:24	Unit BALM611 [SITREP :] WE WILL BE BACK ON NORMAL TURNOUT IN ABOUT 15 MINS
15:29:00	** Event Type changed from 1F(2) to 5110(2) at: 26/05/17 15:29:00
15:31:09	** Event Type changed from 5110(2) to 1F(2) at: 26/05/17 15:31:09
16:25:41	Unit AUCKCITY4 [SITREP :] NOT VIA PHONE: WORKSAFE NZ HAS ARRIVED ON SCENE AND
16:25:41	HAS TAKEN OVER THE SCENE FROM AUCKLAND COUNCIL ENVIRONMENTAL. (CALL
16:25:41	DISCONNECTED
16:25:41	BEFORE HE FINISHED)
16:26:34	Unit AUCKCITY4 [K11E : ELECTRICAL AUTHORITY REQUIRED]
16:31:47	Unit TEAT664 [K7 : AT NORMAL STATION]
16:33:54	Unit AUCKCITY4 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]

16:37:22	Unit FIAKCITY4 [COMCEN COM : MESSAGE] VECTOR ETA - NO REPLY
16:40:43	Unit FIAKCITY4 [COMCEN COM : MESSAGE]
17:53:47	Unit FIAKCITY4 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
18:03:04	Unit FIAKCITY4 [SITREP :] PHONE) LEAVING THE SCENE,HAVE NOT BEEN ABLE TO ENTER
18:03:04	. WAITING ON CONTACT FROM WORKSAFE WITH RESULTS FROM TESTING FOR LEVEL OF
18:03:04	ASBESTOS IN THE AIR. THE AREA IS SMOKE TIGHT AND SMOKE IS STILL CONTAINED
18:03:04	WITHIN. UNSURE WHEN I WILL BE RETURNING MAY BE A COUPLE OF DAYS AND WILL REQUIRE
18:03:04	A CREW TO ATTEND WITH ME
18:04:12	Unit FIAKCITY4 [K6 : ON TELEPAGER]
18:07:11	UNIT AUUCKCITY1 ALERT TIME [NULL] ADJUSTED TO
18:07:11	UNIT AUUCKCITY1 ALERT TIME [NULL] ADJUSTED TO
18:07:11	** Assigned Result Code: STRU, Detailed Event Type: 1100, Qualifier 1: Q1,
18:07:11	Qualifier 2:
18:07:12	UNIT DEVO811 ALERT TIME [NULL] ADJUSTED TO
18:07:12	UNIT AUUCKCITY4 ALERT TIME [NULL] ADJUSTED TO
18:07:12	UNIT GREY261 ALERT TIME [NULL] ADJUSTED TO

Incident

CAD Number	F2314524
Incident Reporter	Rochelle Martin
Incident Controller	Rochelle Martin
Distance Travelled (km)	
Delay In Receiving Call	

Property Details

Occupant	Goodma Fielder NZ
Building Owner	Rented property
General Property Use	Office, Bank, Embassy, Fire/Ambulance/Police station
Special Property Use	Office: General business
Purpose Group	

Actions

Persons Reported Trapped	Yes
Evacuation Status	Fully evacuated
Action Prior 1	No action taken by Civilian/Occupant/Passerby
Action Prior 2	No action taken by Civilian/Occupant/Passerby
Action Taken	Extinguishment and ventilation

Civilians

Civilians Rescued	0
Civilians Extricated	0
Civilians Assisted	1
Civilians Evacuated	

Origin

Location	Hallway, Passageway, Corridor, Walkway in mall
Level	3rd or 4th floor

Equipment Used

Quantity	Equipment
2	Low pressure delivery

Equipment Involved

Equipment Involved

Year

Make

Model

Fire

Arrival Condition	Small fire
Heat Source	Information not recorded/Unknown
Termination Stage	Flame
First Object Ignited	Electrical wire, Wiring insulation
First Object Material	PVC eg. Floor Tiles, Guttering/Pipes, Plastic Bags, Elec. Insulation
Second Object Ignited	Electrical wire, Wiring insulation
Second Object Material	PVC eg. Floor Tiles, Guttering/Pipes, Plastic Bags, Elec. Insulation
Indicated Cause	Undetermined
Certainty of Cause	Medium
Age of Person	Unknown
Ethnicity	Unknown
Gender	Male
FAIP Service Offered	No

FAIP Service Accepted No

Alarms

Type of Alarm Initiating Call	Manual Fire Alarm
Performance of System	Alerted occupants - detector not in room of origin

Failure/Ineffectiveness of system
Number of sprinkler heads operated

Comments

6/12/2017 11:01:33 AM

Reporter Comments

Point of origin of fire identified, actual cause of fire undetermined at this point by FRM.

Rochelle Martin

Released under the Official Information Act