

SMS Incident Report


30/05/2017 14:03:11

Summary

CAD Number F2313150 **Status** Closed
Station St Heliers Station
Incident Started 24/05/2017 11:42:06 **Incident Ended** 24/05/2017 12:00:42
Incident Type 7105: False alarm: Excess Smoke, Heat
Common Name PANMURE BRIDGE CHILDCARE CENTRE
Address 43 CAEN ROAD PANMURE
Alarm Method Manual PFA Call **Alarm Level** 1
PFA Number 118175
Zone 142311
Map Grid E 1766009 **Map Grid N** 5914488
First Caller **First Caller Contact**
Incident Closed 24/05/2017 12:17:20
Report Completed 15:37, Thur 25 May 2017 by Hamish MacDonald

Responses

Call Sign	Type	Station Alert	Enroute Time	Arrival Time	Departed
HOWI321	P1	11:43:07 24 May 2017	11:44:10 24 May 2017	11:51:03 24 May 2017	11:55:59 24 May 2017
STHE241	P1	11:43:10 24 May 2017	11:44:22 24 May 2017	11:51:04 24 May 2017	12:00:47 24 May 2017



Elapsed Times

Call Sign	Start To Alert	Alert To Arrival	Start To Arrival	Start To Departed
HOWI321	00:01:01	00:07:56	00:08:57	00:13:53
STHE241	00:01:04	00:07:54	00:08:58	00:18:41

Message Log

Time	Message
11:42:06	AL: 118175 11:42:06 INITIAL - AL
11:42:06	PANEL: ENTRANCE
11:42:07	** LOI search completed at 24/05/17 11:42:07
11:42:23	T3 T/O F2313149
11:42:28	T3 TURNING OUT F2313147
11:42:59	** Recommended unit STHE241 for requirement PUMP (>4.3 km)
11:42:59	** Recommended unit HOWI321 for requirement PUMP (>5.2 km)
11:43:18	Duplicate Event:Location = 43 CAEN RD,PANMURE,AUCKLAND: @PANMURE BRIDGE
11:43:18	INC INFO: ALARM ACTIVATION - COMMERCIAL
11:43:18	CHILDCARE CENTRE, Type = STRU - STRUCTURE FIRE, Call Source = 111Inc InfoALARM
11:43:18	ACTIVATION - COMMERCIAL
11:43:18	End of Duplicate Event data
11:43:21	BURN TOAST
11:44:04	T3 : T/OUT F2313147
11:44:11	Unit HOWI321 [K1 : PROCEEDING TO INCIDENT]
11:44:23	Unit STHE241 [K1 : PROCEEDING TO INCIDENT]
11:44:28	Unit STHE241 [K1 : PROCEEDING TO INCIDENT]
11:44:33	Unit STHE241 [K1 : PROCEEDING TO INCIDENT]
11:44:41	Unit STHE241 [K1 : PROCEEDING TO INCIDENT]
11:51:04	Unit HOWI321 [K77 : NOTHING SHOWING]
11:51:06	Unit STHE241 [K77 : NOTHING SHOWING]
11:51:12	Unit STHE241 [K77 : NOTHING SHOWING]
11:52:58	Unit STHE241 [KC : UNIT CALLING]
11:53:25	Unit STHE241 [SITREP :] SO MCDONALD. PS FIRE. REPORTS OF BURNT TOAST
11:54:03	Unit HOWI321 [K2 : IN ATTENDANCE AT INCIDENT]
11:55:12	Unit STHE241 [KC : UNIT CALLING]
11:55:48	Unit STHE241 [SITREP :] VENTILATION. PPV FAN IN USE
11:56:01	Unit HOWI321 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
12:00:24	Unit STHE241 [KC : UNIT CALLING]
12:00:42	Unit STHE241 [K47 : STOP MESSAGE: MESSAGE UNCHANGED FROM INFORMATIVE]
12:00:49	Unit STHE241 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
12:17:20	** Assigned Result Code: STRU, Detailed Event Type: 1500, Qualifier 1: Q1,
12:17:20	Qualifier 2:

Incident

CAD Number	F2313150
Incident Reporter	Hamish MacDonald
Incident Controller	SO MacDonald

Distance Travelled (km)

Delay In Receiving Call

False Alarm

Detector Type Smoke detector
False Alarm Cause Building Usage | Fumes from toasters
Other Cause

Property Details

Occupant
Building Owner
General Property Use School: Pre-school through to Secondary/High
Special Property Use Day care centre, Playcentre, Creche
Purpose Group CS - Crowd Small

Comments

Burnt toast in the kitchen area

5/25/2017 3:37:11 PM **Reporter Comments**
Hamish MacDonald

Released under the Official Information Act