

SMS Incident Report


30/06/2017 08:17:24

Summary

CAD Number F2330229 **Status** Closed
Station East Coast Bays Station
Incident Started 22/06/2017 22:35:30 **Incident Ended** 22/06/2017 22:52:47
Incident Type 7103: False alarm: Defective
Common Name VAUGHAN PARK ANGLICAN RETREAT
Address 1043 BEACH ROAD TORBAY
Alarm Method Automatic PFA Call **Alarm Level** 1
PFA Number 115268
Zone 14838501
Map Grid E 1756505 **Map Grid N** 5938120
First Caller **First Caller Contact**
Incident Closed 22/06/2017 22:59:22
Report Completed 16:52, Thur 29 Jun 2017 by Nick Penfold

Responses

Call Sign	Type	Station Alert	Enroute Time	Arrival Time	Departed
EAST831	P1	22:36:02 22 Jun 2017	22:37:10 22 Jun 2017	22:45:31 22 Jun 2017	22:55:41 22 Jun 2017
ALBA851	P1	22:36:05 22 Jun 2017	22:37:18 22 Jun 2017	22:49:29 22 Jun 2017	22:53:12 22 Jun 2017
TAKA807	PR	22:36:08 22 Jun 2017	22:37:34 22 Jun 2017	22:49:59 22 Jun 2017	22:53:01 22 Jun 2017
EAST832	P2	22:35:58 22 Jun 2017	22:44:42 22 Jun 2017	22:52:00 22 Jun 2017	22:52:46 22 Jun 2017



Elapsed Times

Call Sign	Start To Alert	Alert To Arrival	Start To Arrival	Start To Departed
EAST831	00:00:32	00:09:29	00:10:01	00:20:11
ALBA851	00:00:35	00:13:24	00:13:59	00:17:42
TAKA807	00:00:38	00:13:51	00:14:29	00:17:31

EAST832	00:00:28	00:16:02	00:16:30	00:17:16
---------	----------	----------	----------	----------

Message Log

Time	Message
22:35:31	AL: 115268 22:35:30 INITIAL - AL
22:35:31	PANEL: MAIN BUILDING
22:35:37	** LOI search completed at 22/06/17 22:35:37
22:35:39	ACCESS NO: -83-52
22:35:45	DIRECTIONS: NEAR LONG BAY DR
22:35:50	** Recommended unit EAST831 for requirement PUMP (>4.1 km)
22:35:50	** Recommended unit EAST832 for requirement PUMP (>4.1 km)
22:35:50	** Recommended unit ALBA851 for requirement PUMP (>8.1 km)
22:35:50	** Recommended unit TAKA807 for requirement CANBACKUP (>9.7 km)
22:37:11	Unit EAST831 [K1 : PROCEEDING TO INCIDENT]
22:37:18	Unit ALBA851 [K1 : PROCEEDING TO INCIDENT]
22:37:34	Unit TAKA807 [K1 : PROCEEDING TO INCIDENT]
22:44:15	Duplicate Event:Location = 44 WAI AU ST AUCKLAND Cross Street 1 ASHCRAIG CT Cross
22:44:15	Street 2 MORLIE PL, Type = ADV 2I ADVISED INFORMATION, Subtype = default 2,
22:44:15	Caller Name = [REDACTED], Caller Ph Number = [REDACTED] Caller Address = [REDACTED]
22:44:15	[REDACTED], TORBAY, AUCKLAND, Call Source = POLICE Alarm Level 1 Inc Info INFMT CAN HEAR
22:44:15	SIRENS GOING OFF AT BEACH - UK WHAT IT IS FOR , Event Source = Police 111
22:44:16	** Cross Referenced to Event # F2330231 at: 22/06/17 22:44:16
22:44:16	TD NOW
22:44:16	End of Duplicate Event data
22:44:16	HEADLINE: INFMT CAN HEAR SIRENS GOING OFF AT BEACH - UK WHAT IT IS FOR
22:44:16	RRRR
22:44:16	COMING FROM LONG BAY DIRECTION
22:44:16	C/T CAN HEAR THEM ALSO
22:44:16	SOUNDS LIKE CIVIL DEFENCE SIRENS
22:44:16	INFMT ASKING IF THERE IS ANYTHING OF CONCERN IN THE AREA
22:44:16	INFMT SAYS IT SOUNDS LIKE MORE THAN ONE SIREN IN DIFFERENT AREAS
22:44:16	.
22:44:16	(POL2FIR) - ANYTHING YOU ARE AWARE OF?
22:44:16	FIR2POL: AFFIRM - WE ARE RESPONDING TO A FIRE ALARM ACTIVATION AT THE ANGLICAN
22:44:16	RETREAT
22:44:16	** LOI search completed at 22/06/17 22:43:53
22:44:16	** Event Type changed from POL2FIR to ADV at: 22/06/17 22:44:01
22:44:16	** Event Priority changed from 2 to 9 at: 22/06/17 22:44:01

22:44:43	Unit EAST832 [K1 : PROCEEDING TO INCIDENT]
22:44:49	Unit EAST832 [KC : UNIT CALLING]
22:45:18	Unit EAST831 [KC : UNIT CALLING]
22:45:23	Unit EAST831 [KC : UNIT CALLING]
22:45:29	Unit EAST832 [SITREP :] RESPONDING SFF IN CHARGE PLUS 3
22:45:32	Unit EAST831 [K77 : NOTHING SHOWING]
22:45:35	Unit EAST831 [SITREP :] COPY
22:49:04	Unit EAST831 [KC : UNIT CALLING]
22:49:29	Unit ALBA851 [K2 : IN ATTENDANCE AT INCIDENT]
22:49:33	Unit EAST831 [SITREP :] SO PENFOLD - PS MAIN BUILDING - LOWER GROUND
22:49:59	Unit TAKA807 [K2 : IN ATTENDANCE AT INCIDENT]
22:52:00	Unit EAST832 [K2 : IN ATTENDANCE AT INCIDENT]
22:52:24	Unit EAST831 [KC : UNIT CALLING]
22:52:47	Unit EAST832 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
22:52:48	Unit EAST831 [K46-3 : STOP MESSAGE: FALSE ALARM DEFECTIVE APPARATUS] K28-1
22:52:54	Unit EAST831 [K28-1 : RETURN OTHER RESPONDING UNITS]
22:53:02	Unit TAKA807 [K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]
22:53:13	Unit ALBA851 [K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]
22:55:42	Unit EAST831 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
22:59:21	** Assigned Result Code: STRU, Detailed Event Type: 7100, Qualifier 1: Q1,
22:59:21	Qualifier 2:

Incident

CAD Number	F2330229
Incident Reporter	Nick Penfold
Incident Controller	N Penfold
Distance Travelled (km)	5
Delay In Receiving Call	

False Alarm

Detector Type	Smoke detector
False Alarm Cause	Equipment Unable to classify
Other Cause	The alarms in the area indicated were checked and non had operated.

Property Details

Occupant	
Building Owner	
General Property Use	Church, Cemetery, Religious use
Special Property Use	Residential Property - not classified above

Purpose Group

SA - Sleeping Transient Accommodation

Released under the Official Information Act