

SMS Incident Report


12/07/2017 09:42:12

Summary

CAD Number F2339922 **Status** Closed
Station Auckland City Station
Incident Started 10/07/2017 09:03:11 **Incident Ended** 10/07/2017 09:19:07
Incident Type 7103: False alarm: Defective
Common Name CIT HOUSE
Address 309 BROADWAY NEWMARKET
Alarm Method Automatic PFA Call **Alarm Level** 1
PFA Number 110431
Zone 142111
Map Grid E 1758354 **Map Grid N** 5917858
First Caller **First Caller Contact**
Incident Closed 10/07/2017 10:12:24
Report Completed 11:42, Mon 10 Jul 2017 by Sulu Devoe

Responses

Call Sign	Type	Station Alert	Enroute Time	Arrival Time	Departed
AUCK207	PR	09:03:30 10 Jul 2017	09:04:55 10 Jul 2017	09:08:41 10 Jul 2017	09:24:34 10 Jul 2017
PARN251	P1	09:03:27 10 Jul 2017	09:04:58 10 Jul 2017	09:09:01 10 Jul 2017	09:18:34 10 Jul 2017



Elapsed Times

Call Sign	Start To Alert	Alert To Arrival	Start To Arrival	Start To Departed
AUCK207	00:00:19	00:05:11	00:05:30	00:21:23
PARN251	00:00:16	00:05:34	00:05:50	00:15:23

Message Log

Time	Message
09:03:12	AL: 110431 09:03:11 INITIAL - AL
09:03:12	PANEL: BROADWAY STH END
09:03:16	** LOI search completed at 10/07/17 09:03:16
09:03:20	** Recommended unit PARN251 for requirement PUMP (>2.6 km)
09:03:20	** Recommended unit AUCK207 for requirement PUMP (>2.3 km)
09:04:55	Unit AUCK207 [K1 : PROCEEDING TO INCIDENT]
09:04:58	Unit PARN251 [K1 : PROCEEDING TO INCIDENT]
09:08:42	Unit AUCK207 [K77 : NOTHING SHOWING]
09:09:01	Unit PARN251 [K2 : IN ATTENDANCE AT INCIDENT]
09:11:10	Unit AUCK207 [KC : UNIT CALLING]
09:11:41	Unit AUCK207 [SITREP :] SSO DEVOE. PS FIRE. NO ZONE INDICATED.
09:18:34	Unit PARN251 [K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]
09:18:47	Unit AUCK207 [KC : UNIT CALLING]
09:19:08	Unit AUCK207 [K46-3 : STOP MESSAGE: FALSE ALARM DEFECTIVE APPARATUS]
09:24:35	Unit AUCK207 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
10:12:24	** Assigned Result Code: STRU, Detailed Event Type: 7100, Qualifier 1: Q1,
10:12:24	Qualifier 2:

Incident

CAD Number F2339922
Incident Reporter Sulu Devoe
Incident Controller SSO Devoe
Distance Travelled (km)
Delay In Receiving Call

False Alarm

Detector Type Thermal detector
False Alarm Cause Equipment | Defect fire alarm panel
Other Cause

Property Details

Occupant
Building Owner
General Property Use Shop, Shopping mall, Supermarket, Service station, Car yard, Other sales use
Special Property Use Commercial Property - not classified above
Purpose Group WM - Working, Business or Storage Moderate Fire Hazard

Released under the Official Information Act