

# SMS Incident Report


24/07/2017 14:49:24

## Summary

**CAD Number** F2346975 **Status** Closed  
**Station** Auckland City Station  
**Incident Started** 20/07/2017 14:59:51 **Incident Ended** 20/07/2017 15:11:24  
**Incident Type** 7105: False alarm: Excess Smoke, Heat  
**Common Name** AUCKLAND HOSPITAL BUILDING 08 ONCOLOGY SERVICES  
**Address** MA12 / 2 PARK ROAD GRAFTON  
**Alarm Method** Automatic PFA Call **Alarm Level** 1  
**PFA Number** 114563  
**Zone** 14200501  
**Map Grid E** 1757888 **Map Grid N** 5919186  
**First Caller** **First Caller Contact**  
**Incident Closed** 20/07/2017 15:35:41  
**Report Completed** 18:22, Thur 20 Jul 2017 by Phil Grace

## Responses

Call Sign	Type	Station Alert	Enroute Time	Arrival Time	Departed
AUCK207	PR	15:00:18 20 Jul 2017	15:01:46 20 Jul 2017	15:05:33 20 Jul 2017	15:12:29 20 Jul 2017
GREY261	P1	15:00:27 20 Jul 2017	15:01:58 20 Jul 2017	15:06:26 20 Jul 2017	15:07:41 20 Jul 2017
PARN251	P1	15:00:22 20 Jul 2017	15:01:27 20 Jul 2017		15:10:18 20 Jul 2017



## Elapsed Times

Call Sign	Start To Alert	Alert To Arrival	Start To Arrival	Start To Departed
AUCK207	00:00:27	00:05:15	00:05:42	00:12:38
GREY261	00:00:36	00:05:59	00:06:35	00:07:50
PARN251	00:00:31			00:10:27

**Message Log**

Time	Message
14:59:51	AL: 114563 14:59:51 INITIAL - AL
14:59:52	** LOI search completed at 20/07/17 14:59:52
15:00:06	** Recommended unit AUCK207 for requirement PUMP (>1.1 km)
15:00:06	ACCESS NO: -C20-306H
15:00:06	** Recommended unit GREY261 for requirement PUMP (>2.9 km)
15:00:06	** Recommended unit PARN251 for requirement PUMP (>1.7 km)
15:01:17	INC INFO: ALARM SOUNDING
15:01:17	Duplicate Event:Location = 2 PARK RD,GRAFTON,AUCKLAND: @AUCKLAND CITY HOSPITAL
15:01:17	BUILDING 08 ONCOLOGY SERVICES, Type = STRU - STRUCTURE FIRE, Caller Name =
15:01:17	GREENLANE HOSPITAL, Caller Ph Number = [REDACTED], Caller Address = 210 GREEN
15:01:17	LANE, EPSOM, AUCKLAND CITY, Call Source = 111Inc InfoALARM SOUNDING, Event
15:01:17	Source = Fire 111
15:01:17	End of Duplicate Event data
15:01:28	Unit PARN251 [ K1 : PROCEEDING TO INCIDENT]
15:01:46	Unit AUCK207 [ K1 : PROCEEDING TO INCIDENT]
15:01:58	Unit GREY261 [ K1 : PROCEEDING TO INCIDENT]
15:05:34	Unit AUCK207 [ K77 : NOTHING SHOWING]
15:06:27	Unit GREY261 [ K2 : IN ATTENDANCE AT INCIDENT]
15:06:39	Unit AUCK207 [ KC : UNIT CALLING]
15:07:09	Unit AUCK207 [ SITREP : ] SSO GRACE IPS LOWER GROUND RIGHT REAR REPORT OF BURNT
15:07:09	TOAST
15:07:42	Unit GREY261 [ K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]
15:09:54	Unit PARN251 [ KC : UNIT CALLING]
15:10:19	Unit PARN251 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]
15:11:08	Unit AUCK207 [ KC : UNIT CALLING]
15:11:24	Unit AUCK207 [ K46-2 : STOP MESSAGE: FALSE ALARM ACCIDENTAL] TOAST
15:12:30	Unit AUCK207 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]
15:35:41	** Assigned Result Code: SPRNKLR, Detailed Event Type: 7100, Qualifier 1: Q1,
15:35:41	Qualifier 2:

**Incident**

<b>CAD Number</b>	F2346975
<b>Incident Reporter</b>	Phil Grace
<b>Incident Controller</b>	SSO Phil Grace
<b>Distance Travelled (km)</b>	

Delay In Receiving Call

**False Alarm**

**Detector Type** Smoke alarm (mains powered)  
**False Alarm Cause** Building Usage | Fumes from toasters  
**Other Cause**

**Property Details**

**Occupant**  
**Building Owner**  
**General Property Use** Hospital, Hospice, Rest home, Rehabilitation centre  
**Special Property Use** General hospital: Public and private  
**Purpose Group** SC - Sleeping Care

**Comments**

	7/20/2017 6:22:01 PM	Reporter Comments
Smoke Detector - Lower Ground - Toaster		Phil Grace

Released under the Official Information Act