

SMS Incident Report


11/08/2017 11:56:23

Summary

CAD Number F2354027 **Status** Closed
Station Silverdale Station
Incident Started 31/07/2017 12:18:46 **Incident Ended** 31/07/2017 13:19:30
Incident Type 4101: Liquid, Gas leak or spill: No fire
Common Name
Address / 13 Tavern Road Silverdale
Alarm Method 111 Telephone **Alarm Level** 1
PFA Number
Zone 149001
Map Grid E 1749756 **Map Grid N** 5945764
First Caller **First Caller Contact** XXXXXXXXXX
Incident Closed 31/07/2017 13:19:30
Report Completed 15:27, Wed 09 Aug 2017 by Jake Kennedy

Responses

Call Sign	Type	Station Alert	Enroute Time	Arrival Time	Departed
SILV901	P1	12:20:45 31 Jul 2017	12:25:32 31 Jul 2017	12:28:07 31 Jul 2017	12:38:00 31 Jul 2017
SILV907	PR	12:20:41 31 Jul 2017	12:21:36 31 Jul 2017	12:28:32 31 Jul 2017	12:38:34 31 Jul 2017
EAST831	P1	12:20:48 31 Jul 2017	12:21:32 31 Jul 2017		12:32:00 31 Jul 2017



Elapsed Times

Call Sign	Start To Alert	Alert To Arrival	Start To Arrival	Start To Departed
SILV901	00:01:59	00:07:22	00:09:21	00:19:14
SILV907	00:01:55	00:07:51	00:09:46	00:19:48
EAST831	00:02:02			00:13:14

Notifications

Date	Time	Party Notified
31 Jul 2017	12:34:39	SILVERDALE STATION ADVISE THERE IS A FULL CREW ON STATION FOR SILV901 TO

Message Log

Time	Message
12:20:22	OUTSIDE THE HOUSE ON THE BACK WALL
12:20:22	INC INFO: 9KG LPG CYLINGER LEAKING
12:20:24	** LOI search completed at 31/07/17 12:20:24
12:20:33	** Recommended unit SILV907 for requirement SILVERDALESPECIALDAY (>2.2 km)
12:20:33	** Recommended unit SILV901 for requirement PUMP (>2.2 km)
12:20:33	** Recommended unit EAST831 for requirement CANBACKUP (>13.2 km)
12:20:49	CALLED IN BY DON MCERLICH - HOUSE OWNER RANG DON
12:21:32	Unit EAST831 [K1 : PROCEEDING TO INCIDENT]
12:21:36	Unit SILV907 [K1 : PROCEEDING TO INCIDENT]
12:23:33	Unit SILV907 [COMCEN COM : MESSAGE] 9KG LPG CYLINFDER AGAINST THE BACK WALL OF THE HOUSE - LEAKING
12:23:33	THE HOUSE - LEAKING
12:23:38	Unit SILV907 [K35 : VERIFY ADDRESS OF EVENT]
12:23:48	Unit SILV907 [COMCEN COM : MESSAGE] 13 TAVERN ROAD
12:25:33	Unit SILV901 [K1 : PROCEEDING TO INCIDENT]
12:25:39	Unit SILV901 [KC : UNIT CALLING]
12:26:27	Unit SILV901 [SITREP :] RESPONDING QFF AND 2
12:26:36	Unit SILV907 [SITREP :] COPIED
12:28:07	Unit SILV901 [K77 : NOTHING SHOWING]
12:28:33	Unit SILV907 [K2 : IN ATTENDANCE AT INCIDENT]
12:28:38	Unit SILV907 [K2 : IN ATTENDANCE AT INCIDENT]
12:29:44	Unit SILV907 [KC : UNIT CALLING]
12:30:21	Unit SILV907 [SITREP :] SSO KENNEDY. 13 TAVERN ROAD. REPORT OF 9KG GAS CYLINDER LEAKING. VALVE ISOLATED. INVESTIGATING
12:30:21	CYLINDER LEAKING. VALVE ISOLATED. INVESTIGATING
12:30:53	Unit SILV907 [COMCEN COM : MESSAGE] ANOTHER CALL TO KNOTT ROAD ATANMORE BAY - ALBANY RESPONDING AS SECOND PUMP
12:30:53	ALBANY RESPONDING AS SECOND PUMP
12:31:29	Unit SILV907 [KC : UNIT CALLING]
12:31:43	Unit SILV907 [K28-1 : RETURN OTHER RESPONDING UNITS]
12:32:01	Unit EAST831 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
12:34:39	UPLIFT IF THEY ARE REQ FOR ANOTHER CALL
12:36:50	Unit SILV907 [K22-2 : HAVE YOU ANY UNITS THAT CAN BE RELEASED]
12:37:13	Unit SILV907 [SITREP :] STANDBY
12:38:01	Unit SILV901 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
12:38:05	Unit SILV907 [KC : UNIT CALLING]

12:38:35	Unit SILV907 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
12:38:39	Unit SILV907 [STOP : MESSAGE] GAS CYLINDER ISOLATED. SILV907 & SILV901
12:38:39	AVAILABLE
13:19:30	** Assigned Result Code: STRU, Detailed Event Type: 7100, Qualifier 1: Q1,
13:19:30	Qualifier 2:

Incident

CAD Number	F2354027
Incident Reporter	Jake Kennedy
Incident Controller	J.Kennedy
Distance Travelled (km)	3
Delay In Receiving Call	

Property Details

Occupant	
Building Owner	Owner occupied
General Property Use	Single house
Special Property Use	Single house
Purpose Group	

Actions

Persons Reported Trapped	No
Evacuation Status	Fully evacuated
Action Prior 1	No action taken by Civilian/Occupant/Passerby
Action Prior 2	
Action Taken	Isolating Power or Fuel Supply

Civilians

Civilians Rescued	0
Civilians Extricated	0
Civilians Assisted	0
Civilians Evacuated	

Origin

Location	Patio, Court, Terrace, Gazebo
Level	

Equipment Used

Quantity	Equipment
0	No equipment used

Equipment Involved

Equipment Involved

Year

Make

Model

Hazardous Materials

Control	Controlled incident: No evacuation of immediate area
Activation of detection and control systems	No other action determined
Extent of Spread on Arrival	Spread not confined to property of origin
Wind Direction on Arrival	No wind
Wind Speed on Arrival	Calm
Cause of Leakage	Inadequate control of hazardous materials
Environ. Contamination	Air/Ground/Sea Water: No environmental contamination
Population Density	Residential: Low density
Primary Advice	Fire Service information
Secondary Advice	

Chemicals

Trade Name	METHANE, COMPRESSED or NATURAL GAS, COMPRESSED (1971)
Hazard Class	2.1
UNSI	1971
Quantity of Leakage	Less than 10 litres
Substance Leaking From	Cylinder valve
Number of Containers	
Container Labeling	Yes
Method of Disposal	Evaporated
Org. Responsible for Disposal	Incident completed by Fire Service only
Place of Disposal	Substance vaporised in air

1

Released under the Official Information Act