

SMS Incident Report


11/08/2017 09:05:19

Summary

CAD Number F2355255 **Status** Closed
Station Grey Lynn Station
Incident Started 02/08/2017 10:36:01 **Incident Ended** 02/08/2017 11:27:37
Incident Type 4101: Liquid, Gas leak or spill: No fire
Common Name
Address 8 FONTENOY STREET MOUNT ALBERT
Alarm Method 111 Telephone **Alarm Level** 1
PFA Number
Zone 146006
Map Grid E 1752559 **Map Grid N** 5917443
First Caller **First Caller Contact** ██████████
Incident Closed 02/08/2017 11:42:11
Report Completed 18:48, Thur 10 Aug 2017 by Ken Lousley

Responses

Call Sign	Type	Station Alert	Enroute Time	Arrival Time	Departed
GREY261	P1	10:37:51 02 Aug 2017	10:39:25 02 Aug 2017	10:43:47 02 Aug 2017	11:27:46 02 Aug 2017
AVON607	PR	10:37:48 02 Aug 2017	10:38:38 02 Aug 2017	10:44:42 02 Aug 2017	11:24:17 02 Aug 2017
AUCKOSU1	SV	10:42:50 02 Aug 2017	10:42:59 02 Aug 2017	10:59:44 02 Aug 2017	11:21:16 02 Aug 2017



Elapsed Times

Call Sign	Start To Alert	Alert To Arrival	Start To Arrival	Start To Departed
GREY261	00:01:50	00:05:56	00:07:46	00:51:45
AVON607	00:01:47	00:06:54	00:08:41	00:48:16
AUCKOSU1	00:06:49	00:16:54	00:23:43	00:45:15

Notifications

Date	Time	Party Notified
02 Aug 2017	10:40:00	OSU AUCKLAND
02 Aug 2017	10:41:05	VECTOR GAS
02 Aug 2017	10:45:41	GAS
02 Aug 2017	10:45:53	GAS 25MIN @1045

Message Log

Time	Message
10:36:56	INC INFO: GAS PIPE HIT
10:36:57	** LOI search completed at 02/08/17 10:36:57
10:37:07	** Event Priority changed from 2 to 1 at: 02/08/17 10:37:07
10:37:07	** Event Type changed from MIN to HAZ at: 02/08/17 10:37:07
10:37:29	** Event Type changed from HAZ to HAZGAS at: 02/08/17 10:37:29
10:37:29	** Event Priority changed from 1 to 4 at: 02/08/17 10:37:29
10:37:29	INC INFO: GAS PIPE STRIKE
10:37:34	** Recommended unit AVON607 for requirement RESCUE (>2.9 km)
10:37:34	** Recommended unit GREY261 for requirement PUMP (>2.8 km)
10:37:47	//HAZ//
10:38:38	Unit AVON607 [K1 : PROCEEDING TO INCIDENT]
10:39:25	Unit GREY261 [K1 : PROCEEDING TO INCIDENT]
10:40:08	AMBO EVENT 0346-1-2017/08/02-FIR LINKED AT 02/08/2017 10:40:08
10:40:11	POL AND AMB: FOR YOUR INFO ONLY
10:42:59	Unit AUCKOSU1 [K38 : ASSOCIATE THIS UNIT TO EVENT - EVENT ADDRESS]
10:43:00	Unit AUCKOSU1 [K1 : PROCEEDING TO INCIDENT]
10:43:08	Unit AUCKOSU1 [K1 : PROCEEDING TO INCIDENT]
10:43:40	Unit AUCKOSU1 [K1 : PROCEEDING TO INCIDENT]
10:43:48	Unit GREY261 [K55 : SPECIAL SERVICE EVENT]
10:43:52	Unit GREY261 [K55 : SPECIAL SERVICE EVENT]
10:43:58	Unit GREY261 [K55 : SPECIAL SERVICE EVENT]
10:44:43	Unit AVON607 [K2 : IN ATTENDANCE AT INCIDENT]
10:46:49	Unit GREY261 [COMCEN COM : MESSAGE] GAS ETA 25 MIN
10:47:53	Unit GREY261 [SITREP :] SO LOUSLEY HOUSE GAS MAIN DAMAGED WITH HAND SAW WIND
10:47:53	FROM EASTRLY DIRECTION
10:57:22	Unit GREY261 [KC : UNIT CALLING]
10:58:04	Unit GREY261 [SITREP :] EXCAVATION AROUND DAMAGED PIPE CARRIED OUT FIRE SEVICE
10:58:04	ATTEMPTING TO CLAMP
10:59:45	Unit AUCKOSU1 [K2 : IN ATTENDANCE AT INCIDENT]
11:11:08	Unit GREY261 [KC : UNIT CALLING]

11:11:41	Unit GREY261 [SITREP :] SSO LANE VECTOR NOW IN ATTENDANCE
11:21:17	Unit AUCKOSU1 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
11:24:18	Unit AVON607 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
11:26:58	Unit GREY261 [KC : UNIT CALLING]
11:27:37	Unit GREY261 [K47 : STOP MESSAGE: MESSAGE UNCHANGED FROM INFORMATIVE]
11:27:47	Unit GREY261 [K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]
11:42:10	** Assigned Result Code: HAZGAS, Detailed Event Type: 1400, Qualifier 1: Q1,
11:42:10	Qualifier 2:

Incident

CAD Number F2355255
Incident Reporter Ken Lousley
Incident Controller Lousley
Distance Travelled (km)
Delay In Receiving Call

Property Details

Occupant
Building Owner Owner occupied
General Property Use Single house
Special Property Use Single house
Purpose Group

Actions

Persons Reported Trapped No
Evacuation Status Not occupied at time of incident
Action Prior 1 No action taken by Civilian/Occupant/Passerby
Action Prior 2
Action Taken Traffic control/scene protection

Civilians

Civilians Rescued 0
Civilians Extricated 0
Civilians Assisted 2
Civilians Evacuated

Origin

Location Lawn , Park, Sports field

Level

Equipment Used

Quantity	Equipment
1	Scene protection equipment (eg. signs, tarps, lighting, safety wands etc)

Equipment Involved

Equipment Involved

Year

Make

Model

Hazardous Materials

Control	Uncontrolled incident: Evacuation of immediate area
Activation of detection and control systems	No other action determined
Extent of Spread on Arrival	Spread confined to level of origin
Wind Direction on Arrival	East
Wind Speed on Arrival	Light breeze
Cause of Leakage	Pipe damaged
Environ. Contamination	Air/Ground/Sea Water: Air only
Population Density	Residential: Medium density
Primary Advice	Fire Service information
Secondary Advice	No specialised information sought

Chemicals

Trade Name	COMPRESSED GAS, FLAMMABLE, N.O.S. (1954)
Hazard Class	2.1
UNSI	1954
Quantity of Leakage	31 - 250 litres
Substance Leaking From	Pipes
Number of Containers	0
Container Labeling	No
Method of Disposal	Evaporated
Org. Responsible for Disposal	Incident released for disposal - To owner/agent
Place of Disposal	Substance vaporised in air

Released under the Official Information Act