

SMS Incident Report


11/08/2017 10:57:54

Summary

CAD Number F2355193 **Status** Closed
Station Papatoetoe Station
Incident Started 02/08/2017 09:30:27 **Incident Ended** 02/08/2017 09:47:00
Incident Type 7104: False alarm: Accidental operation
Common Name KNIGHTSBRIDGE MOTOR LODGE
Address 112 EAST TAMAKI ROAD PAPATOETOE
Alarm Method Manual PFA Call **Alarm Level** 1
PFA Number 111473
Zone 143134
Map Grid E 1766130 **Map Grid N** 5907423
First Caller **First Caller Contact**
Incident Closed 02/08/2017 09:47:00
Report Completed 20:12, Wed 02 Aug 2017 by Steve Pyke

Responses

Call Sign	Type	Station Alert	Enroute Time	Arrival Time	Departed
PAPA347	PR	09:30:43 02 Aug 2017	09:31:52 02 Aug 2017	09:36:08 02 Aug 2017	09:39:37 02 Aug 2017
PAPA344	PM	09:32:16 02 Aug 2017	09:34:15 02 Aug 2017	09:37:56 02 Aug 2017	09:38:36 02 Aug 2017
HOWI321	P1	09:30:43 02 Aug 2017			09:32:55 02 Aug 2017



Elapsed Times

Call Sign	Start To Alert	Alert To Arrival	Start To Arrival	Start To Departed
PAPA347	00:00:16	00:05:25	00:05:41	00:09:10
PAPA344	00:01:49	00:05:40	00:07:29	00:08:09
HOWI321	00:00:16			00:02:28

Message Log

Time	Message
09:30:28	AL: 111473 09:30:27 INITIAL - AL
09:30:28	PANEL: WINDOW BY MAIN ENTRANCE
09:30:30	** LOI search completed at 02/08/17 09:30:30
09:30:36	** Recommended unit PAPA347 for requirement PUMP (>2.5 km)
09:30:36	** Recommended unit HOWI321 for requirement PUMP (>2.5 km)
09:31:38	Unit HOWI321 [KC : UNIT CALLING]
09:31:53	Unit PAPA347 [K1 : PROCEEDING TO INCIDENT]
09:32:05	** Requirement PUMP added for alarm level 1
09:32:09	** Recommended unit PAPA344 for requirement ADHOC PUMP (>2.5 km)
09:32:56	Unit HOWI321 [K9 : OFF RT - STATE LOCATION]
09:34:16	Unit PAPA344 [K1 : PROCEEDING TO INCIDENT]
09:36:08	Unit PAPA347 [K77 : NOTHING SHOWING]
09:37:56	Unit PAPA344 [K2 : IN ATTENDANCE AT INCIDENT]
09:38:09	Unit PAPA347 [KC : UNIT CALLING]
09:38:37	Unit PAPA344 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
09:39:33	Unit PAPA347 [STOP : MESSAGE] SFF PIKE MANULA CALL POINT ACTIVATED BY CHILD
09:39:38	Unit PAPA347 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
09:47:00	** Assigned Result Code: STRU, Detailed Event Type: 7100, Qualifier 1: Q1,
09:47:00	Qualifier 2:

Incident

CAD Number F2355193
Incident Reporter Steve Pyke
Incident Controller SFF Pyke
Distance Travelled (km) 7
Delay In Receiving Call

False Alarm

Detector Type Manual call point
False Alarm Cause Human Intervention | Accidental alarm activation by (c) other person
Other Cause

Property Details

Occupant
Building Owner
General Property Use Hotel, Motel, Lodge, Timeshare

Special Property Use Hotel, Motel, Lodge: Without liquor licence
Purpose Group SA - Sleeping Transient Accommodation

Comments

8/2/2017 8:12:34 PM

Reporter Comments

Alarm activated by child.

Steve Pyke

Released under the Official Information Act