

SMS Incident Report


11/08/2017 11:07:47

Summary

CAD Number F2355113 **Status** Closed
Station Birkenhead Station
Incident Started 02/08/2017 04:05:45 **Incident Ended** 02/08/2017 04:38:29
Incident Type 7103: False alarm: Defective
Common Name NORTHBRIDGE RESIDENCE FACILITY
Address MA6 / 45 AKORANGA DRIVE NORTHCOTE
Alarm Method Manual PFA Call **Alarm Level** 1
PFA Number 114915
Zone 14800103
Map Grid E 1756632 **Map Grid N** 5926092
First Caller **First Caller Contact**
Incident Closed 02/08/2017 05:07:49
Report Completed 16:16, Tue 08 Aug 2017 by Katie Smart

Responses

Call Sign	Type	Station Alert	Enroute Time	Arrival Time	Departed
BIRK821	P1	04:06:02 02 Aug 2017	04:07:27 02 Aug 2017	04:14:02 02 Aug 2017	04:45:34 02 Aug 2017
DEVO811	P1	04:06:12 02 Aug 2017	04:08:01 02 Aug 2017	04:15:03 02 Aug 2017	04:44:33 02 Aug 2017
ALBA851	P1	04:06:08 02 Aug 2017	04:07:54 02 Aug 2017	04:16:35 02 Aug 2017	04:36:04 02 Aug 2017
BIRK822	P2	04:06:02 02 Aug 2017	04:11:16 02 Aug 2017	04:17:14 02 Aug 2017	04:39:57 02 Aug 2017



Elapsed Times

Call Sign	Start To Alert	Alert To Arrival	Start To Arrival	Start To Departed
BIRK821	00:00:17	00:08:00	00:08:17	00:39:49
DEVO811	00:00:27	00:08:51	00:09:18	00:38:48
ALBA851	00:00:23	00:10:27	00:10:50	00:30:19

BIRK822	00:00:17	00:11:12	00:11:29	00:34:12
---------	----------	----------	----------	----------

Message Log

Time	Message
04:05:46	AL: 114915 04:05:45 INITIAL - AL
04:05:46	PANEL: FRONT OF BUILDING
04:05:48	** LOI search completed at 02/08/17 04:05:48
04:05:53	** Recommended unit BIRK821 for requirement PUMP (>3.8 km)
04:05:53	** Recommended unit BIRK822 for requirement PUMP (>3.9 km)
04:05:53	** Recommended unit ALBA851 for requirement PUMP (>6.9 km)
04:05:53	** Recommended unit DEVO811 for requirement CANBACKUP (>4.5 km)
04:05:59	DIRECTIONS: ACCESS ENTRANCE 2
04:06:01	NO ACCESS NUMBER
04:07:27	Unit BIRK821 [K1 : PROCEEDING TO INCIDENT]
04:07:55	Unit ALBA851 [K1 : PROCEEDING TO INCIDENT]
04:08:02	Unit DEVO811 [K1 : PROCEEDING TO INCIDENT]
04:11:17	Unit BIRK822 [K1 : PROCEEDING TO INCIDENT]
04:14:02	Unit BIRK821 [K77 : NOTHING SHOWING]
04:15:04	Unit DEVO811 [K2 : IN ATTENDANCE AT INCIDENT]
04:16:36	Unit ALBA851 [K2 : IN ATTENDANCE AT INCIDENT]
04:17:06	Unit BIRK821 [KC : UNIT CALLING]
04:17:11	Unit BIRK821 [KC : UNIT CALLING]
04:17:15	Unit BIRK822 [K2 : IN ATTENDANCE AT INCIDENT]
04:17:50	Unit BIRK821 [SITREP :] SO SMART - INDICATOR PANEL SHOWING NORMAL - BUT LIGHTS
04:17:50	ARE ILLUMINATED IN ADMINISTRATION BLOCK AND BLOCK B - INVESTIGATING
04:24:49	Unit BIRK821 [KC : UNIT CALLING]
04:25:14	Unit BIRK821 [SITREP :] NSOF ALARM BELLS RINGING INV FURTHER
04:27:24	Unit BIRK821 [KC : UNIT CALLING]
04:28:06	Unit BIRK821 [SITREP :] IPS AT ADMINISTRATION FIRE ZONE 3 GROUND FLOOR CENTRE
04:28:06	INV
04:30:34	Unit BIRK821 [KC : UNIT CALLING]
04:31:15	Unit BIRK821 [SITREP :] UNABLE TO GAIN ENTRANCE WAITING FOR STAFF MEMBER TO
04:31:15	GAIN ENTRY. EXTERNAL SEARCH CARRIED OUT.
04:33:13	Unit BIRK822 [SITREP :] WERE TRYING TO MAKE ACCESS - CAN YOU FIND OUT IF
04:33:13	TAKAPUNA HAVE A KEY ? (NEGATIVE NO ACCESS NUMBER, DO YOU REQUIRE ALARM
04:33:13	AGENT?)
04:33:13	NO NOT AT THIS STAGE.
04:36:05	Unit ALBA851 [K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]

04:38:13	Unit BIRK821 [KC : UNIT CALLING]
04:38:29	Unit BIRK821 [K46-3 : STOP MESSAGE: FALSE ALARM DEFECTIVE APPARATUS]
04:38:29	UNDETERMINED
04:39:58	Unit BIRK822 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
04:44:34	Unit DEVO811 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
04:45:35	Unit BIRK821 [K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]
05:07:49	** Assigned Result Code: STRU, Detailed Event Type: 7100, Qualifier 1: Q1,
05:07:49	Qualifier 2:

Incident

CAD Number F2355113
Incident Reporter Katie Smart
Incident Controller Katie Smart
Distance Travelled (km)
Delay In Receiving Call

False Alarm

Detector Type Smoke alarm (mains powered)
False Alarm Cause Other | No apparent cause
Other Cause NA

Property Details

Occupant
Building Owner
General Property Use Hospital, Hospice, Rest home, Rehabilitation centre
Special Property Use Office: General business
Purpose Group WL - Working, Business or Storage Light Fire Hazard

Comments

8/8/2017 4:16:28 PM

Reporter Comments

Area searched, two detector heads had gone off. no sign of fire

Katie Smart

Released under the Official Information Act