

HSNO LOCATION TEST CERTIFICATE

Issued pursuant to Section 82 of The Hazardous Substances & New Organisms Act 1996

for

NGA TAONGA SOUND AND VISION

Storage Vault Situated at 47 Thornley St
Whitireia Titahi Bay Porirua
Telephone Nga Taonga Sound and Vision 04 3847647
Cell Head of Standards 021 764470

This HSNO Conditional Location Test Certificate is issued in terms of Regulation 82 of the Hazardous Substances (Classes 1 to 5 Controls) Regulations 2001. This HSNO Conditional Location Test Certificate covers the Classes set out in the Classes & Storage Requirements Table below and is subject to compliance with the conditions as stated in the Classes & Storage Requirements Table.

- 1) Unless surrendered or revoked beforehand, this HSNO Conditional Location Test Certificate shall remain in force until **THURSDAY 24 MAY 2018** & may be renewed thereafter by an Authorised Test Certifier.
- 2) This HSNO Conditional Location Test Certificate must be displayed & produced at the request of an Enforcement Officer appointed under the HSNO Act 1996.
- 3) Classes & Storage Requirements Table

CLASS	QUANTITY	CONDITIONS
4.1.1B	8000 kg	<p>Only Nitrocellulose Based Film with UN Number 1324 to Stages 1 & 2 of deterioration can be stored in the Vault at this location at 47 Thornley Street Whitireia Titahi Bay Porirua.</p> <ol style="list-style-type: none"> 1. The Holder of this HSNO Location Test Certificate must undertake 6 monthly Emergency Training in relation to Nitrocellulose Film following the Training Program outlined in the Email to the Head of Standards Nga Taonga Sound and Vision dated 23 March 2016 which must be attached to this HSNO Location Test Certificate. 2. The Holder of this HSNO Location Test Certificate shall ensure that the lawns inside the boundary fence and a strip adjacent to the fence shall be mown every 6 weeks in high growth seasons or every 2 months. Trees adjacent to the vault shall be maintained so that they do not pose a risk to the Vault or the adjacent environment. 3. The Holder of this HSNO Location Test Certificate shall ensure that a barrel of water is stored in the vicinity of the door to the Vault at all times for use in an emergency involving Nitrate Film. 4. The Holder of this HSNO Location Test Certificate shall ensure that every party who uses the Vault has an Emergency Plan and that each year the Emergency Plan is tested by that party in accordance with the Hazardous Substances and New Organisms Act and Regulations. A copy of the Emergency Plan shall be supplied to the Test Certifier during the term of the HSNO Location Test Certificate along with Evidence of Testing.

Bryan K Williamson

Bryan K Williamson

Test Certifier Registration #92

Issued Tuesday 23 May 2017

QUALITY & SAFETY MANAGEMENT LIMITED

PO BOX 17 117 KARORI 6012 WELLINGTON

Tele 04 938 7042 Cell 021 236 4693

bryan.williamson@quality-safety.co.nz

Disclaimer: This Hazardous Substances Test Certificate is issued pursuant to the Hazardous Substance and New Organism Act 1996 and certifies that at the time of inspection you met the relevant requirements of the HSNO Act 1996. The Test Certificate does not negate any duty or responsibility you may have under the Resource Management Act 1991, the Building Act 2004, or any other Act or Bylaw or District Plan requirements administered by your local Council. Please contact your local council for advice on these matters.