

AS/NZS 3000:2007: Electrical installations (known as the Australian/New Zealand Wiring Rules): including Amendments 1 and 2, subject to the following modifications: 1. In 4.5.2.3.2, change “warning sign shall be installed” to “warning sign shall be installed or fitted in domestic installations but may be omitted from all other installations”. 2. In 4.18.1(b) and (c), change “all live (active and neutral) conductors” to “all active conductors”. 3. Add a new paragraph to 4.18.2: “In New Zealand, only electrical equipment that is directly associated with the gas supply may be installed in the hazardous areas of a domestic installation, shown in figure 4.10.” 4. Replace 4.18.3 with “In New Zealand, only electrical equipment (including metering equipment) that is directly associated with the gas supply may be installed in the exclusion zones of a domestic installation in figure 4.11.”	AS/NZS 3000:2018 Electrical installations - Known as the Australian/New Zealand Wiring Rules	TBC	With the exemption of clause 1.7.3 Reason: the ESR prescribe an equipment regime, it is not up to or appropriate for AS/NZS3000 to prescribe an equipment regime.	Change: 2.3.2.1.2(b) possiblilty delete the clause need to be able to switch the neutral for the EV charging	With the execption of 2.6.2.2.3(b) Ev issue (to allow the type b and type f rcd)	With the exemption of clause 2.6.3.3.2 Exception 2, Bullet point 2. Exemption no longer needed due to change in technology use	Change 4.18.5: delete the words "lighter then air" Reason: So this clause applies to retaliated LPG installations as well. These are mainly located in the South Island.
--	---	-----	--	---	---	--	---

In this clause 4.18.5 the term "hazardous area" has the same meaning as "exclusion zone"	8.3.10 paragraph 2 delete the words "either by the operation of the integral test device, or" EV things Reason: to ensure RCDs are tested to ensure that they are working and that they are not deemed unsafe by Regulation 24 of the ESR due to the trip time.	With the exception of Note 4 in 8.3.10. Reason: to ensure RCDs are tested to ensure that they are working and that they are not deemed unsafe by Regulation 24 of the ESR due to the trip time.

Released under the Official Information Act 1982