

SMS Incident Report


13/07/2017 08:54:42

Summary

CAD Number F2338094 **Status** Closed
Station Otahuhu Station
Incident Started 06/07/2017 16:25:27 **Incident Ended** 06/07/2017 16:40:46
Incident Type 7103: False alarm: Defective
Common Name OTAHUHU BUS RAIL INTERCHANGE
Address UNKN0001 WALMSLEY ROAD OTAHUHU
Alarm Method Manual PFA Call **Alarm Level** 1
PFA Number 101210
Zone 143132
Map Grid E 1763294 **Map Grid N** 5909382
First Caller **First Caller Contact**
Incident Closed 06/07/2017 16:56:17
Report Completed 7:3, Thur 13 Jul 2017 by Chris Lane

Responses

Call Sign	Type	Station Alert	Enroute Time	Arrival Time	Departed
OTAH311	P1	16:25:54 06 Jul 2017	16:27:36 06 Jul 2017	16:30:01 06 Jul 2017	16:41:00 06 Jul 2017
MANG351	P1	16:25:57 06 Jul 2017	16:27:13 06 Jul 2017	16:35:10 06 Jul 2017	16:37:41 06 Jul 2017



Elapsed Times

Call Sign	Start To Alert	Alert To Arrival	Start To Arrival	Start To Departed
OTAH311	00:00:27	00:04:07	00:04:34	00:15:33
MANG351	00:00:30	00:09:13	00:09:43	00:12:14

Message Log

Time	Message
16:25:28	AL: 101210 16:25:27 INITIAL - AL
16:25:28	PANEL: ENTRANCE DOOR TO AMENITIES BUILDING WALMSLEY ROAD
16:25:29	** LOI search completed at 06/07/17 16:25:29
16:25:46	** Recommended unit OTAH311 for requirement PUMP (>1.1 km)
16:25:46	** Recommended unit MANG351 for requirement PUMP (>3.9 km)
16:27:13	Unit MANG351 [K1 : PROCEEDING TO INCIDENT]
16:27:37	Unit OTAH311 [K1 : PROCEEDING TO INCIDENT]
16:29:39	Duplicate Event:Location = WALMSLEY RD,OTAHUHU,AUCKLAND, Type = STRU - STRUCTURE
16:29:39	INC INFO: ALARM ACTIVATION - COMMERCIAL
16:29:39	FIRE, Caller Name = DIGITAL ISLAND LTD (WHOLESALEMOBILE), Caller Ph Number =
16:29:39	[REDACTED], Caller Address = TELECOM CELLULAR 027, SUNNYHILLS, AUCKLAND CITY,
16:29:39	Call Source = 111Inc InfoALARM ACTIVATION - COMMERCIAL, Event Source = Fire 111
16:29:39	End of Duplicate Event data
16:30:01	Unit OTAH311 [K77 : NOTHING SHOWING]
16:30:50	Unit OTAH311 [KC : UNIT CALLING]
16:31:19	Unit OTAH311 [SITREP :] SO LANE IPS FIRE ZONE ONE HEAT SMOKE MANUAL
16:31:19	INVESTIGATING
16:35:10	Unit MANG351 [K2 : IN ATTENDANCE AT INCIDENT]
16:37:42	Unit MANG351 [K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]
16:39:53	Unit OTAH311 [KC : UNIT CALLING]
16:40:46	Unit OTAH311 [K46-3 : STOP MESSAGE: FALSE ALARM DEFECTIVE APPARATUS]
16:41:01	Unit OTAH311 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
16:56:17	** Assigned Result Code: STRU, Detailed Event Type: 7100, Qualifier 1: Q1,
16:56:17	Qualifier 2:

Incident

CAD Number F2338094
Incident Reporter Chris Lane
Incident Controller S.O. Lane
Distance Travelled (km)
Delay In Receiving Call

False Alarm

Detector Type Manual call point
False Alarm Cause Equipment | Defect fire alarm panel
Other Cause

Property Details

Occupant

Building Owner

General Property Use Railway property

Special Property Use Railway station

Purpose Group CO - Crowd Open

Comments

7/13/2017 7:02:33 AM

Reporter Comments

Unable to find any cause for activation in secure indicated area

Chris Lane

Released under the Official Information Act