

SMS Incident Report


18/08/2017 14:45:57

Summary

CAD Number F2355128 **Status** Closed
Station East Coast Bays Station
Incident Started 02/08/2017 07:06:28 **Incident Ended** 02/08/2017 07:18:57
Incident Type 7104: False alarm: Accidental operation
Common Name
Address 100A ROSEDALE ROAD ROSEDALE
Alarm Method 111 Telephone **Alarm Level** 1
PFA Number
Zone 148367
Map Grid E 1753946 **Map Grid N** 5932861
First Caller **First Caller Contact** ██████████
Incident Closed 02/08/2017 08:03:35
Report Completed 14:57, Thur 17 Aug 2017 by Craig Law

Responses

Call Sign	Type	Station Alert	Enroute Time	Arrival Time	Departed
EAST831	P1	07:08:08 02 Aug 2017	07:09:48 02 Aug 2017	07:13:33 02 Aug 2017	07:24:15 02 Aug 2017
ALBA851	P1	07:08:11 02 Aug 2017	07:10:15 02 Aug 2017	07:15:11 02 Aug 2017	07:16:50 02 Aug 2017



Elapsed Times

Call Sign	Start To Alert	Alert To Arrival	Start To Arrival	Start To Departed
EAST831	00:01:40	00:05:25	00:07:05	00:17:47
ALBA851	00:01:43	00:07:00	00:08:43	00:10:22

Message Log

Time	Message
07:07:26	CAUSED BY OVEN SMOKING
07:07:26	INC INFO: FIRE ALARM SOUNDING
07:07:28	** LOI search completed at 02/08/17 07:07:28
07:07:54	** Event Type changed from MIN to STRU at: 02/08/17 07:07:54
07:07:54	** Event Priority changed from 2 to 1 at: 02/08/17 07:07:54
07:08:00	** Recommended unit EAST831 for requirement PUMP (>2.3 km)
07:08:00	** Recommended unit ALBA851 for requirement PUMP (>2.4 km)
07:08:21	LEAPS AND BOUNDS EARLY LEARNING CENTRE
07:09:49	Unit EAST831 [K1 : PROCEEDING TO INCIDENT]
07:10:15	Unit ALBA851 [K1 : PROCEEDING TO INCIDENT]
07:13:33	Unit EAST831 [K77 : NOTHING SHOWING]
07:15:11	Unit ALBA851 [K2 : IN ATTENDANCE AT INCIDENT]
07:16:51	Unit ALBA851 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
07:18:28	Unit EAST831 [KC : UNIT CALLING]
07:18:57	Unit EAST831 [K46-2 : STOP MESSAGE: FALSE ALARM ACCIDENTAL] SO LAW COOKING
07:24:16	Unit EAST831 [K4 : ON RT INSIDE NORMAL TURNOUT AREA]
08:03:35	** Assigned Result Code: STRU, Detailed Event Type: 7100, Qualifier 1: Q1,
08:03:35	Qualifier 2:

Incident

CAD Number F2355128
Incident Reporter Craig Law
Incident Controller craig law
Distance Travelled (km) 2
Delay In Receiving Call

False Alarm

Detector Type Smoke alarm (mains powered)
False Alarm Cause Building Usage | Fumes from food processing (excl. from toasters)
Other Cause

Property Details

Occupant
Building Owner
General Property Use Educational, Health, Institutional - not classified above
Special Property Use Day care centre, Playcentre, Creche

Purpose Group

WL - Working, Business or Storage Light Fire Hazard

Comments

8/17/2017 2:57:19 PM

Reporter Comments

False alarm due to cooking, smoke alarm activation in area adjacent to kitchen.
Evacuation completed and brigade met at entrance by building warden, there is no fire panel on the outside face of the building to indicate an area.

Craig Law

Released under the Official Information Act